

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	
A 000	Initial Comments A Re-Licensure Survey was conducted at Casa Bonita ALF LLC on 10/14/2019. The provider had deficiencies identified at the time of the visit.	A 000		
A 055 SS=D	59A-36.008(6) FAC Medication - Storage and Disposal (6) MEDICATION STORAGE AND DISPOSAL. (a) In order to accommodate the needs and preferences of residents and to encourage residents to remain as independent as possible, residents may keep their medications, both prescription and over-the-counter, in their possession both on or off the facility premises. Residents may also store their medication in their rooms or apartments if either the room is kept locked when residents are absent or the medication is stored in a secure place that is out of sight of other residents. (b) Both prescription and over-the-counter medications for residents must be centrally stored if: 1. The facility administers the medication; 2. The resident requests central storage. The facility must maintain a list of all medications being stored pursuant to such a request; 3. The medication is determined and documented by the health care provider to be hazardous if kept in the personal possession of the person for whom it is prescribed; 4. The resident fails to maintain the medication in a safe manner as described in this paragraph; 5. The facility determines that, because of physical arrangements and the conditions or habits of residents, the personal possession of medication by a resident poses a safety hazard to other residents, or 6. The facility's rules and regulations require	A 055		

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X8) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 055	Continued From page 1 central storage of medication and that policy has been provided to the resident before admission as required in rule 59A-36.006, F.A.C. (c) Centrally stored medications must be: 1. Kept in a locked cabinet; locked cart; or other locked storage receptacle, room, or area at all times; 2. Located in an area free of dampness and abnormal temperature, except that a medication requiring refrigeration must be kept refrigerated. Refrigerated medications must be secured by being kept in a locked container within the refrigerator, by keeping the refrigerator locked, or by keeping the area in which the refrigerator is located locked; 3. Accessible to staff responsible for filling pill-organizers, assisting with self-administration of medication, or administering medication. Such staff must have ready access to keys or codes to the medication storage areas at all times; and, 4. Kept separately from the medications of other residents and properly closed or sealed. (d) Medication that has been discontinued but has not expired must be returned to the resident or the resident's representative, as appropriate, or may be centrally stored by the facility for future use by the resident at the resident's request. If centrally stored by the facility, the discontinued medication must be stored separately from medication in current use, and the area in which it is stored must be marked "discontinued medication." Such medication may be reused if prescribed by the resident's health care provider. (e) When a resident's stay in the facility has ended, the administrator must return all medications to the resident, the resident's family, or the resident's guardian unless otherwise prohibited by law. If, after notification and waiting at least 15 days, the resident's medications are	A 055			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 055	Continued From page 2 still at the facility, the medications are considered abandoned and may disposed of in accordance with paragraph (f). (f) Medications that have been abandoned or have expired must be disposed of within 30 days of being determined abandoned or expired and the disposal must be documented in the resident's record. The medication may be taken to a pharmacist for disposal or may be destroyed by the administrator or designee with one witness. (g) Facilities that hold a Special-ALF permit issued by the Board of Pharmacy may return dispensed medicinal drugs to the dispensing pharmacy pursuant to rule 64B16-28.870, F.A.C. This Statute or Rule is not met as evidenced by: Based on observation and interview the facility failed to ensure that medications for one of six (Resident #3) sampled residents were locked. Findings included: On 10/17/2019 at 9:15 am, observation of the kitchen refrigerator revealed in the right corner next to a locked box was a bottle with label belonging to Resident #3. On 10/17/2019 at 2:30 PM The Administrator checked the refrigerator and acknowledged that Resident #3's medication was unlocked in the refrigerator door. Class III	A 055		
A 084 SS=D	59A-36.011(6) FAC 429.52(6), FS Training - Assis Self-Admin Meds & Med Mgmt 59A-36.011	A 084		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 084	Continued From page 3 (6) ASSISTANCE WITH THE SELF-ADMINISTRATION OF MEDICATION AND MEDICATION MANAGEMENT. Unlicensed persons who will be providing assistance with the self-administration of medications as described in rule 59A-36.008, F.A.C., must meet the training requirements pursuant to section 429.52(6), F.S., prior to assuming this responsibility. Courses provided in fulfillment of this requirement must meet the following criteria: (a) Training must cover state law and rule requirements with respect to the supervision, assistance, administration, and management of medications in assisted living facilities; procedures and techniques for assisting the resident with self-administration of medication including how to read a prescription label; providing the right medications to the right resident; common medications; the importance of taking medications as prescribed; recognition of side effects and adverse reactions and procedures to follow when residents appear to be experiencing side effects and adverse reactions; documentation and record keeping; and medication storage and disposal. Training shall include demonstrations of proper techniques, including techniques for _____ control, and ensure unlicensed staff have adequately demonstrated that they have acquired the skills necessary to provide such assistance. (b) The training must be provided by a registered nurse or licensed pharmacist who shall issue a training certificate to a trainee who demonstrates, in person and both physically and verbally, the ability to: 1. Read and understand a prescription label; 2. Provide assistance with self-administration in accordance with section 429.256, F.S., and rule 59A-36.008, F.A.C., including:	A 084		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 10/17/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

CASA BONITA ALF LLC

**931 NE 17 TERRACE
HOMESTEAD, FL 33033**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 084	Continued From page 4 a. Assist with oral dosage forms, _____ dosage forms, and _____ and dosage forms; b. Measure liquid medications, break scored tablets, and crush tablets in accordance with prescription directions; c. Recognize the need to obtain clarification of an "as needed" prescription order; d. Recognize a medication order which requires judgment or discretion, and to advise the resident, resident's health care provider or facility employer of inability to assist in the administration of such orders; e. Complete a medication observation record; f. Retrieve and store medication; g. Recognize the general signs of adverse reactions to medications and report such reactions; h. Assist residents with _____ syringes that are prefilled with the proper dosage by a pharmacist and _____ that are prefilled by the manufacturer by taking the medication, in its previously dispensed, properly labeled container, from where it is stored, and bringing it to the resident for self-injection; i. Assist with _____; j. Use a _____ to perform _____ testing; k. Assist residents with _____ and continuous positive airway pressure (CPAP) devices, excluding the titration of the _____ levels; l. Apply and remove _____ stockings and hosiery; m. Placement and removal of _____ bags, excluding the removal of the _____ or manipulation of the _____ site; and n. Measurement of _____ rate, temperature, and _____ rate.	A 084		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 084	Continued From page 5 (c) Unlicensed persons, as defined in section 429.256(1)(b), F.S., who provide assistance with self-administered medications and have successfully completed the initial 6 hour training, must obtain, annually, a minimum of 2 hours of continuing education training on providing assistance with self-administered medications and safe medication practices in an assisted living facility. The 2 hours of continuing education training may be provided online. (d) Trained unlicensed staff who, prior to the effective date of this rule, assist with the self-administration of medication and have successfully completed 4 hours of assistance with self-administration of medication training must complete an additional 2 hours of training that focuses on the topics listed in sub-subparagraphs (6)(b)2.h.-n. of this section, before assisting with the self-administration of medication procedures listed in sub-subparagraphs (6)(b)2.h.-n. 429.52 (6) Staff involved with the management of medications and assisting with the self-administration of medications under s. 429.256 must complete a minimum of 6 additional hours of training provided by a registered nurse, a licensed pharmacist, or agency staff. The agency shall establish by rule the minimum requirements of this additional training. This Statute or Rule is not met as evidenced by: Based on record review and interview the facility failed to ensure that one out of two (Staff A) sampled staff completed two hours of continuing education training on providing assistance with self-administered medications and safe medication practices in an assisted living facility.	A 084		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 084	Continued From page 6 Findings included: A review of personnel files for Staff A showed no initial medication training. Further review showed six hours was of training were dated _____ and two hours was dated _____ and expired _____. On _____ at 3:00 PM the Administrator acknowledged after review that she had not received the two hours medication training as required. Class III	A 084		
A 093 SS=D	59A-36.012(2) FAC Food Service - Dietary Standards (2) DIETARY STANDARDS. (a) The meals provided by the assisted living facility must be planned based on the current USDA Dietary Guidelines for Americans, 2010, which are incorporated by reference and available for review at: http://www.frules.org/Gateway/reference.asp?No=Ref-04003 , and the current summary of Dietary Reference Intakes established by the Food and Nutrition Board of the Institute of Medicine of the National Academies, 2010, which are incorporated by reference and available for review at: http://iom.edu/Activities/Nutrition/SummaryDRIs/~media/Files/Activity%20Files/Nutrition/DRIs/New%20Material/5DR1%20Values%20SummaryTables%202014.pdf . Therapeutic diets must meet these nutritional standards to the extent possible. (b) The residents' nutritional needs must be met by offering a variety of meals adapted to the food	A 093		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 093	Continued From page 7 habits, preferences, and physical abilities of the residents, and must be prepared through the use of standardized recipes. For facilities with a licensed capacity of 16 or fewer residents, standardized recipes are not required. Unless a resident chooses to eat less, the facility must serve the standard minimum portions of food according to the Dietary Reference Intakes. (c) All regular and therapeutic menus to be used by the facility must be reviewed annually by a licensed or registered dietitian, a licensed nutritionist, or a registered dietetic technician supervised by a licensed or registered dietitian, or a licensed nutritionist to ensure the meals meet the nutritional standards established in this rule. The annual review must be documented in the facility files and include the original signature of the reviewer, registration or license number, and date reviewed. Portion sizes must be indicated on the menus or on a separate sheet. 1. Daily food servings may be divided among three or more meals per day, including snacks, as necessary to accommodate resident needs and preferences. 2. Menu items may be substituted with items of comparable nutritional value based on the seasonal availability of fresh produce or the preferences of the residents. (d) Menus must be dated and planned at least 1 week in advance for both regular and therapeutic diets. Residents must be encouraged to participate in menu planning. Planned menus must be conspicuously posted or easily available to residents. Regular and therapeutic menus as served, with substitutions noted before or when the meal is served, must be kept on file in the facility for 6 months. (e) Therapeutic diets must be prepared and served as ordered by the health care provider.	A 093			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 093	Continued From page 8 1. Facilities that offer residents a variety of food choices through a select menu, buffet style dining, or family style dining are not required to document what is eaten unless a health care provider's order indicates that such monitoring is necessary. However, the food items that enable residents to comply with the therapeutic diet must be identified on the menus developed for use in the facility. 2. The facility must document a resident's refusal to comply with a therapeutic diet and provide notification to the resident's health care provider of such refusal. (f) For facilities serving three or more meals a day, no more than 14 hours must elapse between the end of an evening meal containing a protein food and the beginning of a morning meal. Intervals between meals must be evenly distributed throughout the day with not less than 2 hours nor more than 6 hours between the end of one meal and the beginning of the next. For residents without access to kitchen facilities, snacks must be offered at least once per day. Snacks are not considered to be meals for the purposes of the time between meals. (g) Food must be served attractively at safe and palatable temperatures. All residents must be encouraged to eat at tables in the dining areas. A supply of eating ware sufficient for all residents, including adaptive equipment if needed by any resident, must be on (h) A 3-day supply of nonperishable food, based on the number of weekly meals the facility has with residents to serve, must be on at all times. The quantity must be based on the resident census and not on licensed capacity. The supply must consist of foods that can be stored safely without refrigeration. Water sufficient for drinking and food preparation must	A 093		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 093	Continued From page 9 also be stored, or the facility must have a plan for obtaining water in an emergency, with the plan coordinated with and reviewed by the local disaster preparedness authority. This Statute or Rule is not met as evidenced by: Based on observation and interview the facility failed to maintain a 3-day supply of non-perishable foods for its census of six residents in the case of an emergency. Findings included: On at 9:15 AM observed the facility's emergency food supply which contained insufficient amounts of meats, canned milk, canned vegetable and two cans of fruit. There were no sources of fruits or other items from the Dietary Guidelines for American available onsite. On at 9:15 AM Staff B stated "we use them daily so that they will not expire." On at 2:30 PM the Administrator acknowledge there was low supply of emergency food and said that she would get more. Class III	A 093			
A 162 SS=D	59A-36.015(3) FAC Records - Resident (3) RESIDENT RECORDS. Resident records must be maintained on the premises and include: (a) Resident demographic data as follows: 1. Name, 2. , 3. Race, 4. Date of birth, 5. Place of birth, if known,	A 162			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 162	Continued From page 10 6. Social security number, 7. Medicaid and/or Medicare number, or name of other health insurance 8. Name, address, and telephone number of next of kin, legal representative, or individual designated by the resident for notification in case of an emergency; and, 9. Name, address, and telephone number of the health care provider and case manager, if applicable. (b) A copy of the Resident Health Assessment form, AHCA Form 1823 described in rule 59A-36.006, F.A.C. (c) Any orders for medications, nursing services, therapeutic diets,, or other services to be provided, supervised, or implemented by the facility that require a health care provider's order. (d) Documentation of a resident's refusal of a therapeutic diet pursuant to rule 59A-36.012, F.A.C., if applicable. (e) The resident care record described in paragraph 59A-36.007(1)(e), F.A.C. (f) A record that is initiated on admission. Information may be taken from AHCA Form 1823 or the resident's health assessment. Residents receiving assistance with the activities of daily living must have their recorded semi-annually. (g) For facilities that will have unlicensed staff assisting the resident with the self-administration of medication, a copy of the written informed consent described in rule 59A-36.006, F.A.C., if such consent is not included in the resident's contract. (h) For facilities that manage a pill organizer, assist with self-administration of medications or administer medications for a resident, copies of the required medication records maintained	A 162		

AHCA Form 3020-0001
STATE FORM

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 162	Continued From page 12 licensed capacity of an assisted living facility, but who are not receiving any personal, limited nursing, or extended congregate care services, record keeping may be limited to the following at the discretion of the facility: 1. A log listing the names of residents participating in this arrangement, 2. The resident demographic data required in this paragraph, 3. The health assessment described in rule 59A-36.006, F.A.C., 4. The resident's contract described in rule 59A-36.018, F.A.C.; and, 5. A health care provider's order for a therapeutic diet if such diet is prescribed and the resident participates in the meal plan offered by the facility. (q) Except for resident contracts, which must be retained for 5 years, all resident records must be retained for 2 years following the departure of a resident from the facility unless it is required by contract to retain the records for a longer period of time. Upon request, residents must be provided with a copy of their records upon departure from the facility. (r) Additional resident records requirements for facilities holding a limited mental health, extended congregate care, or limited nursing services license are provided in rules 59A-36.020, 59A-36.021 and 59A-36.022, F.A.C., respectively. This Statute or Rule is not met as evidenced by: Based on observation, record review and interview the facility failed to have an updated health assessment for one of six sampled residents (Resident #1). Finding included: On at 9:30 AM, observed Resident #1	A 162		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 162	Continued From page 13 walking with assistance from staff and eating his breakfast, and going to the bathroom on his own with no assistance. A review of Resident #1's health assessment showed no documentation of what assistance the resident needed with activities of daily living. On at 1:10 PM the Administrator stated, "He can do most thing himself we give him assistance with walking and bathing only." Class III	A 162			
A 200 SS=D	59A-36.025 FAC Emergency Environmental Control 59A-36.025 Emergency Environmental Control for Assisted Living Facilities. (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the assisted living facility, to ensure that current licensees of assisted living facilities will be equipped to ensure air temperatures will be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 14 appropriate for resident care needs and life safety requirements. For planning purposes, no less than twenty (20) net square . . . per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed capacity as the number of residents to be used in the to determine the required square footage. This may include areas that are less than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving provider for evacuees when the conditions stated in section 408.821, F.S. and subsection 59A-36.019(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained. 2. The alternate power source and fuel supply shall be located in an area(s) in accordance with local zoning and the Florida Building Code. 3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly, this rule does not limit the types of systems or equipment that may be used to achieve temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 15 operate the systems and equipment. a. An assisted living facility in an evacuation zone pursuant to chapter 252, F, S. must maintain an alternative power source and fuel as required by this subsection at all times when the assisted living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if evacuation is necessary. b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly described in the emergency power plan. c. A multistory facility, whose comprehensive emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional equipment so it can safely operate in a location protected from flooding or storm surge damage. (b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the alternate power source to maintain temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours after the loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel storage. 1. Facilities must store minimum amounts of fuel onsite as follows: a. A facility with a licensed capacity of 16 beds or	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 16 less must store 48 hours of fuel onsite. b. A facility with a licensed capacity of 17 or more beds must store 72 hours of fuel onsite. 2. An assisted living facility located in an area in a declared state of emergency area pursuant to section 252.36, F.S. that may impact primary power delivery must secure ninety-six (96) hours of fuel. The assisted living facility may utilize portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency. 3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule. 4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living facility must develop a plan that includes maximum onsite fuel storage allowable by the ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a monoxide alarm. (2) SUBMISSION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall submit its plan to the local emergency management agency for review within 30 days of the effective date of this rule. Assisted living facility plans previously submitted and approved pursuant to emergency rule 58AER17-1 will require resubmission only if changes are made to the plan. (b) Each new assisted living facility shall submit	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 17 the plan required under this rule prior to obtaining a license. (c) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the local emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally authorized entity. If the plan is maintained in an electronic format, assisted living facility staff must be readily available to access and produce the plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within two (2) business days of the approval of the plan from the local emergency management agency, the assisted living facility shall submit in writing proof of the approval to the Agency for Health Care Administration. (c) The assisted living facility shall submit a consumer-friendly summary of the emergency power plan to the Agency. The Agency shall post the summary and notice of the approval and implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the local emergency management agency and update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN. (a) Each assisted living facility licensed prior to	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 18 the effective date of this rule shall , no later than , have implemented the plan required under this rule. (b) The Agency shall allow an extension up to to providers in compliance with paragraph (c) below and who can show delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes. Assisted living facilities shall notify the Agency that they will utilize the extension and keep the Agency apprised of progress on a quarterly basis to ensure there are no unnecessary delays. If an assisted living facility can show in its quarterly progress reports that unavoidable delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes will occur beyond the initial extension date, the assisted living facility may request a waiver pursuant to section 120.542, F.S. (c) During the extension period, an assisted living facility must make arrangements pending full implementation of its plan that provides the residents with an area or areas to congregate that meets the safe indoor air temperature requirements of subsection (1) (a) for a minimum of ninety-six (96) hours. 1. An assisted living facility not located in an evacuation zone must either have an alternative power source onsite or have a contract in place for delivery of an alternative power source and fuel when requested. Within twenty-four (24) hours of the issuance of a state of emergency for an event that may impact primary power delivery for the area of the assisted living facility, it must have the alternative power source and no less than ninety-six (96) hours of fuel stored onsite. 2. An assisted living facility located in an evacuation zone pursuant to chapter 252, F.S.	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 19 must either: a. Fully and safely evacuate its residents prior to the arrival of the event; or b. Have an alternative power source and no less than ninety-six (96) hours of fuel stored onsite, within twenty-four (24) hours of the issuance of a state of emergency for the area of the assisted living facility. (d) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (e) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan concurrent with any such additions, modifications, alterations, refurbishment, renovations or reconstruction. (f) The Agency for Health Care Administration may request cooperation from the State Fire Marshal to conduct inspections to ensure implementation of the plan in compliance with this rule. (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can effectively and immediately activate, operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in . . . air temperatures inside the facility. Procedures must address the care of residents occupying the facility during a declared state of emergency, specifically, a description of the methods to be used to mitigate the potential	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 20 for heat related injury including: 1. The use of cooling devices and equipment; 2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration; 3. Wellness checks by assisted living facility staff to monitor for signs of _____ and heat injury; and 4. A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy. (b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted living facility staff must be readily available to access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request. (c) The written policies and procedures must be readily available for inspection by each resident; each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by law. (6) REVOCATION OF LICENSE, FINES OR SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by chapter 429, part I, or chapter 408, part II, F.S., including, but not limited to, license revocation, license suspension, and the imposition of administrative fines. (7) COMPREHENSIVE EMERGENCY	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 21 MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION. (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon submission of the plan to the local emergency management agency that the plan has been submitted for review and approval; 2. Upon final implementation of the plan by the assisted living facility. (b) Each assisted living facility must maintain a copy of each notification set forth in paragraph (a) above in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the notifications, either in electronic or paper format, upon request. This Statute or Rule is not met as evidenced by: Based on observation and interview, the facility failed to maintain enough fuel needed to maintain room temperature at or below 81 degrees for at least 48 hours in the event of a loss of primary power. The facility also failed to keep a log which documented the maintenance of generator.	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967199	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 10/17/2019
NAME OF PROVIDER OR SUPPLIER CASA BONITA ALF LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 931 NE 17 TERRACE HOMESTEAD, FL 33033		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 22 Findings included: On at 9:20 AM observed a portable generator, two tanks of propane near it, one was filled. A shed with three five gallon of fuel containers, only two of which contained fuel totaling ten gallons of fuel. Review of the generator manual revealed that the generator would run for eight hours on 7 gallons of fuel. Therefore fuel onsite would last for less than 16 hours. On at 12:45 PM the Administrator stated, "the propane is for the dryer and the fuel we have is in the shed." Class III	A 200			