

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965589	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R 12/16/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SAVANNAH COURT OF ST CLOUD

**3791 OLD CANOE CREEK RD
SAINT CLOUD, FL 34769**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 000}	Initial Comments A Second revisit to the re-licensure survey was conducted at Savannah Ct of St Cloud on . Deficiencies were identified at the time of survey.	{A 000}		
{A 081} SS=D	58A-5.0191(. . .) FAC Training - Staff In-Service (2) STAFF PRESERVICE ORIENTATION. (a) Facilities must provide a preservice orientation of at least 2 hours to all new assisted living facility employees who have not previously completed core training as detailed in subsection (1). (b) New staff must complete the preservice orientation prior to interacting with residents. (c) Once complete, the employee and the facility administrator must sign a statement that the employee completed the preservice orientation which must be kept in the employee's personnel record. (d) In addition to topics that may be chosen by the facility administrator, the preservice orientation must cover: 1. Resident's rights; and, 2. The facility's license type and services offered by the facility. (3) STAFF IN-SERVICE TRAINING. Facility administrators or managers shall provide or arrange for the following in-service training to facility staff: (a) Staff who provide direct care to residents, other than nurses, certified nursing assistants, or home health aides trained in accordance with rule 59A-8.0095, F.A.C., must receive a minimum of 1 hour in-service training in control, including universal precautions and facility sanitation procedures, before providing personal care to residents. The facility must use its	{A 081}		

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965589	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R 12/16/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SAVANNAH COURT OF ST CLOUD

**3791 OLD CANOE CREEK RD
SAINT CLOUD, FL 34769**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 081}	Continued From page 1 control policies and procedures when offering this training. Documentation of compliance with the staff training requirements of 29 CFR 1910.1030, relating to borne may be used to meet this requirement. (b) Staff who provide direct care to residents must receive a minimum of 1 hour in-service training within 30 days of employment that covers the following subjects: 1. Reporting adverse incidents. 2. Facility emergency procedures including chain-of-command and staff roles relating to emergency evacuation. (c) Staff who provide direct care to residents, who have not taken the core training program, shall receive a minimum of 1 hour in-service training within 30 days of employment that covers the following subjects: 1. Resident rights in an assisted living facility. 2. Recognizing and reporting resident neglect, and The facility must use its prevention policies and procedures when offering this training. (d) Staff who provide direct care to residents, other than nurses, CNAs, or home health aides trained in accordance with rule 59A-8.0095, F.A.C., must receive 3 hours of in-service training within 30 days of employment that covers the following subjects: 1. Resident behavior and needs. 2. Providing assistance with the activities of daily living. (e) Staff who prepare or serve food, who have not taken the assisted living facility core training must receive a minimum of 1-hour-in-service training within 30 days of employment in safe food handling practices. (f) All facility staff shall receive in-service training	{A 081}		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965589	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R 12/16/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SAVANNAH COURT OF ST CLOUD

**3791 OLD CANOE CREEK RD
SAINT CLOUD, FL 34769**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 081}	Continued From page 2 regarding the facility's resident elopement response policies and procedures within thirty (30) days of employment. 1. All facility staff shall be provided with a copy of the facility's resident elopement response policies and procedures. 2. All facility staff shall demonstrate an understanding and competency in the implementation of the elopement response policies and procedures. This Statute or Rule is not met as evidenced by: DEFICIENCY REMAINED UNCORRECTED Based on record review and interview the facility failed to ensure 2 of 6 staff (H and J) who provided direct care to residents received all the mandated training. Findings: 1. Personnel record review for staff H, hired _____ and was a caregiver revealed a certificate dated _____ that indicated a 1-hour in-service training regarding: 1. Resident behavior and needs and 2. Providing assistance with the activities of daily living (ADLs). The continued review revealed a certificate dated _____ that indicated a 1-hour in-service training regarding managing _____ and elopements - self-study. There was no evidence to confirm the staff received 3 hours of in-service training regarding 1. Resident behavior and needs, and 2. Providing assistance with the activities of daily living. There was no evidence she attended an in-service training regarding the facility's elopement response policies and procedures.	{A 081}		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965589	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R 12/16/2019
NAME OF PROVIDER OR SUPPLIER SAVANNAH COURT OF ST CLOUD		STREET ADDRESS, CITY, STATE, ZIP CODE 3791 OLD CANOE CREEK RD SAINT CLOUD, FL 34769		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 081}	Continued From page 3 In an interview with the administrator on at 1:30 PM who said she provided personal care to the residents if it was necessary. 2. Personnel record review for the administrator hired on _____, who at times provided personal care to residents revealed a certificate dated _____ that indicated a 1-hour in-service training regarding 1. Resident behavior and needs and 2. Providing assistance with the activities of daily living. There was no evidence either staff was a nurse, Certified Nursing Assistant (CNA), or home health aide (HHA) and therefore exempt from the 3- hours of ADL training. Class III	{A 081}		
{A 082} SS=D	58A-5.0191(4) FAC Training - / . . . (4) _____ (/). Pursuant to section 381.0035, F.S., all facility employees, with the exception of employees subject to the requirements of section 456.033, F.S., must complete a one-time education course on and _____, including the topics prescribed in the section 381.0035, F.S. New facility staff must obtain the training within 30 days of employment. Documentation of compliance must be maintained in accordance with subsection (12), of this rule. This Statute or Rule is not met as evidenced by: DEFICIENCY REMAINED UNCORRECTED	{A 082}		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965589	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED R 12/16/2019
NAME OF PROVIDER OR SUPPLIER SAVANNAH COURT OF ST CLOUD			STREET ADDRESS, CITY, STATE, ZIP CODE 3791 OLD CANOE CREEK RD SAINT CLOUD, FL 34769		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
{A 082}	Continued From page 4 Based on records review and interview the facility failed to ensure 2 of 6 staff (H and J) a one-time education course on _____ and _____, including the topics prescribed in the section 381.0035, F.S. Findings: 1. Personnel record review for staff H, hired _____, and was a caregiver revealed a certificate dated _____ that indicated a 2-hour in-service training regarding "communicable _____". There was no evidence she attended a one-time education course on _____ and _____. In an interview with the administrator on _____ at 1:30 PM who said she provided personal care to the resident if it was necessary. 2. Personnel record review for the administrator hired on _____, who at times provided personal care to residents, revealed a certificate dated _____ that indicated a 2 in-service training regarding "communicable _____". There was no evidence she attended time education course on _____ and _____. The Business Office Manager said on _____ at 3 PM that the in-service _____ was provided by the former administrator and she thought it met the requirement. There was no evidence either staff was a nurse, and therefore exempt from this the 3- hours of ADL training. Class III	{A 082}			
{A 200} SS=G	58A-5.036 FAC Emergency Environmental Control	{A 200}			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965589	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R 12/16/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SAVANNAH COURT OF ST CLOUD

**3791 OLD CANOE CREEK RD
SAINT CLOUD, FL 34769**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 200}	Continued From page 5 (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the assisted living facility, to ensure that current licensees of assisted living facilities will be equipped to ensure air temperatures will be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is appropriate for resident care needs and life safety requirements. For planning purposes, no less than twenty (20) net square per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed capacity as the number of residents to be used in the to determine the required square footage. This may include areas that are less than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving provider for evacuees when the conditions stated in Section 408.821, F.S., and subsection	{A 200}		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965589	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED R 12/16/2019
NAME OF PROVIDER OR SUPPLIER SAVANNAH COURT OF ST CLOUD			STREET ADDRESS, CITY, STATE, ZIP CODE 3791 OLD CANOE CREEK RD SAINT CLOUD, FL 34769		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
{A 200}	Continued From page 6 58A-5.026(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained. 2. The alternate power source and fuel supply shall be located in an area(s) in accordance with local zoning and the Florida Building Code. 3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly, this rule does not limit the types of systems or equipment that may be used to achieve temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to operate the systems and equipment. a. An assisted living facility in an evacuation zone pursuant to Chapter 252, F.S., must maintain an alternative power source and fuel as required by this subsection at all times when the assisted living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if evacuation is necessary. b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly described in the emergency power plan. c. A multistory facility, whose comprehensive	{A 200}			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965589	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED R 12/16/2019
NAME OF PROVIDER OR SUPPLIER SAVANNAH COURT OF ST CLOUD			STREET ADDRESS, CITY, STATE, ZIP CODE 3791 OLD CANOE CREEK RD SAINT CLOUD, FL 34769		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
{A 200}	Continued From page 7 emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional equipment so it can safely operate in a location protected from flooding or storm surge damage. (b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the alternate power source to maintain temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours after the loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel storage. 1. Facilities must store minimum amounts of fuel onsite as follows: a. A facility with a licensed capacity of 16 beds or less must store 48 hours of fuel onsite. b. A facility with a licensed capacity of 17 or more beds must store 72 hours of fuel onsite. 2. An assisted living facility located in an area in a declared state of emergency area pursuant to Section 252.36, F.S., that may impact primary power delivery must secure ninety-six (96) hours of fuel. The assisted living facility may utilize portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency. 3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule. 4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living facility must develop a plan that includes maximum onsite fuel storage allowable by the	{A 200}			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965589	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED R 12/16/2019
NAME OF PROVIDER OR SUPPLIER SAVANNAH COURT OF ST CLOUD			STREET ADDRESS, CITY, STATE, ZIP CODE 3791 OLD CANOE CREEK RD SAINT CLOUD, FL 34769		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
{A 200}	Continued From page 8 ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a monoxide alarm. (2) SUBMISSION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall submit its plan to the local emergency management agency for review within 30 days of the effective date of this rule. Assisted living facility plans previously submitted and approved pursuant to Emergency Rule 58AER17-1, F.A.C., will require resubmission only if changes are made to the plan. (b) Each new assisted living facility shall submit the plan required under this rule prior to obtaining a license. (c) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the local emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally authorized entity. If the plan is maintained in an electronic format, assisted living facility staff must be readily available to access and produce the	{A 200}			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965589	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R 12/16/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SAVANNAH COURT OF ST CLOUD

**3791 OLD CANOE CREEK RD
SAINT CLOUD, FL 34769**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 200}	Continued From page 9 plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within two (2) business days of the approval of the plan from the local emergency management agency, the assisted living facility shall submit in writing proof of the approval to the Agency for Health Care Administration. (c) The assisted living facility shall submit a consumer-friendly summary of the emergency power plan to the Agency. The Agency shall post the summary and notice of the approval and implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the local emergency management agency and update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall, no later than _____, have implemented the plan required under this rule. (b) The Agency shall allow an extension up to _____ to providers in compliance with subsection (c), below, and who can show delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes. Assisted living facilities shall notify the Agency that they will utilize the extension and keep the Agency apprised of progress on a quarterly basis to ensure there are no unnecessary delays. If an assisted living facility can show in its quarterly progress reports that unavoidable delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes will occur beyond the initial extension date, the	{A 200}		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965589	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R 12/16/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SAVANNAH COURT OF ST CLOUD

**3791 OLD CANOE CREEK RD
SAINT CLOUD, FL 34769**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 200}	Continued From page 10 assisted living facility may request a waiver pursuant to Section 120.542, F.S. (c) During the extension period, an assisted living facility must make arrangements pending full implementation of its plan that provides the residents with an area or areas to congregate that meets the safe indoor air temperature requirements of paragraph (1)(a), for a minimum of ninety-six (96) hours. 1. An assisted living facility not located in an evacuation zone must either have an alternative power source onsite or have a contract in place for delivery of an alternative power source and fuel when requested. Within twenty-four (24) hours of the issuance of a state of emergency for an event that may impact primary power delivery for the area of the assisted living facility, it must have the alternative power source and no less than ninety-six (96) hours of fuel stored onsite. 2. An assisted living facility located in an evacuation zone pursuant to Chapter 252, F.S., must either: a. Fully and safely evacuate its residents prior to the arrival of the event, or b. Have an alternative power source and no less than ninety-six (96) hours of fuel stored onsite, within twenty-four (24) hours of the issuance of a state of emergency for the area of the assisted living facility. (d) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (e) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan concurrent with any such additions, modifications,	{A 200}		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965589	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R 12/16/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SAVANNAH COURT OF ST CLOUD

**3791 OLD CANOE CREEK RD
SAINT CLOUD, FL 34769**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 200}	Continued From page 11 alterations, refurbishment, renovations or reconstruction. (f) The Agency for Health Care Administration may request cooperation from the State Fire Marshal to conduct inspections to ensure implementation of the plan in compliance with this rule. (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can effectively and immediately activate, operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in air temperatures inside the facility. Procedures must address the care of residents occupying the facility during a declared state of emergency, specifically, a description of the methods to be used to mitigate the potential for heat related injury including: 1. The use of cooling devices and equipment; 2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration; 3. Wellness checks by assisted living facility staff to monitor for signs of . . . and heat injury; and, 4. A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy. (b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted living facility staff must be readily available to	{A 200}		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965589	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED R 12/16/2019
NAME OF PROVIDER OR SUPPLIER SAVANNAH COURT OF ST CLOUD			STREET ADDRESS, CITY, STATE, ZIP CODE 3791 OLD CANOE CREEK RD SAINT CLOUD, FL 34769		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
{A 200}	Continued From page 12 access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request. (c) The written policies and procedures must be readily available for inspection by each resident; each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by law. (6) REVOCATION OF LICENSE, FINES OR SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by Chapter 429, Part I, F.S., or Chapter 408, Part II, F.S., including, but not limited to, license revocation, license suspension, and the imposition of administrative fines. (7) COMPREHENSIVE EMERGENCY MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION. (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon submission of the plan to the local emergency management agency that the plan has been submitted for review and approval; 2. Upon final implementation of the plan by the	{A 200}			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965589	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R 12/16/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SAVANNAH COURT OF ST CLOUD

**3791 OLD CANOE CREEK RD
SAINT CLOUD, FL 34769**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 200}	Continued From page 13 assisted living facility. (b) Each assisted living facility must maintain a copy of each notification set forth in paragraph (a), above, in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the notifications, either in electronic or paper format, upon request. This Statute or Rule is not met as evidenced by: Based on facility records review and interview the facility failed to ensure the Environmental Control Plan policies and procedures addressed all the required components. Findings: Review of the facility's Environmental Control Plan policies and procedures dated _____ and amended on _____ revealed the policies indicated that additional medications would be ordered, that there would be hydration stations. The policies did not address: 1 The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration; 2. Wellness checks by assisted living facility staff to monitor for signs of _____ and heat injury; and, 4 A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy. In an interview with the administrator on at 3:30 PM who said she had spoken to her supervisor at the corporate office and she was	{A 200}		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965589	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED R 12/16/2019	
NAME OF PROVIDER OR SUPPLIER SAVANNAH COURT OF ST CLOUD		STREET ADDRESS, CITY, STATE, ZIP CODE 3791 OLD CANOE CREEK RD SAINT CLOUD, FL 34769		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{A 200}	Continued From page 14 unable to locate any additional documentation. Class II	{A 200}		