

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 11/30/2020
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

GENESIS ALF VALRICO

**1108 BLACK KNIGHT DR,
VALRICO, FL 33594**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 000	Initial Comments A biennial relicensure survey with limited mental health services (LMH) was conducted at Genesis ALF Valrico on . Deficiencies were identified at the time of the survey.	A 000		
A 077 SS=D	429.176 FS; 429.52(.),59A-36.01(1) FAC Staffing Standards - Administrators 429.176 Notice of change of administrator.-If, during the period for which a license is issued, the owner changes administrators, the owner must notify the agency of the change within 10 days and provide documentation within 90 days that the new administrator meets educational requirements and has completed the applicable core educational requirements under s. 429.52. A facility may not be operated for more than 120 consecutive days without an administrator who has completed the core educational requirements. 429.52 (4) A facility administrator must complete the required core training, including the competency test, within 90 days after the date of employment as an administrator. Failure to do so is a violation of this part and subjects the violator to an administrative fine as prescribed in s. 429.19. Administrators licensed in accordance with part II of chapter 468 are exempt from this requirement. Other licensed professionals may be exempted, as determined by the agency by rule. (5) Administrators are required to participate in continuing education for a minimum of 12 contact hours every 2 years. 59A-36.010 (1) ADMINISTRATORS. Every facility must be under the supervision of an administrator who is	A 077		

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 11/30/2020
NAME OF PROVIDER OR SUPPLIER GENESIS ALF VALRICO			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BLACK KNIGHT DR, VALRICO, FL 33594		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 077	Continued From page 1 responsible for the operation and maintenance of the facility including the management of all staff and the provision of appropriate care to all residents as required by chapters 408, part II, 429, part I, F.S., and rule chapter 59A-35, F.A.C., and this rule chapter. (a) An administrator must: 1. Be at least _____; 2. If employed on or after _____, have, at a minimum, a high school diploma or G.E.D.; 3. Be in compliance with Level 2 background screening requirements pursuant to sections 408.809 and 429.174, F.S.; 4. Complete the core training and core competency test requirements pursuant to rule 59A-36.011, F.A.C., no later than 90 days after becoming employed as a facility administrator. Administrators who attended core training prior to _____, are not required to take the competency test unless specified elsewhere in this rule; and, 5. Satisfy the continuing education requirements pursuant to rule 59A-36.011, F.A.C. Administrators who are not in compliance with these requirements must retake the core training and core competency test requirements in effect on the date the non-compliance is discovered by the agency or the department. (b) In the event of extenuating circumstances, such as the _____ of a facility administrator, the agency may permit an individual who otherwise has not satisfied the training requirements of subparagraph (1)(a)4. of this rule, to temporarily serve as the facility administrator for a period not to exceed 90 days. During the 90 day period, the individual temporarily serving as facility administrator must: 1. Complete the core training and core	A 077			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 11/30/2020
NAME OF PROVIDER OR SUPPLIER GENESIS ALF VALRICO		STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BLACK KNIGHT DR, VALRICO, FL 33594		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 077	Continued From page 2 competency test requirements pursuant to rule 59A-36.011, F.A.C.; and, 2. Complete all additional training requirements if the facility maintains licensure as an extended congregate care or limited mental health facility. (c) Administrators may supervise a maximum of either three assisted living facilities or a group of facilities on a single campus providing housing and health care Administrators who supervise more than one facility must appoint in writing a separate manager for each facility. However, an administrator supervising a maximum of three assisted living facilities, each licensed for 16 or fewer beds and all within a 15 mile of each other, is only required to appoint two managers to assist in the operation and maintenance of those facilities. (d) An individual serving as a manager must satisfy the same qualifications, background screening, core training and competency test requirements, and continuing education requirements as an administrator pursuant to paragraph (1)(a) of this rule. Managers who attended the core training program prior to , are not required to take the competency test unless specified elsewhere in this rule. In addition, a manager may not serve as a manager of more than a single facility, except as provided in paragraph (1)(c) of this rule, and may not , serve as an administrator of any other facility. (e) Pursuant to section 429.176, F.S., facility owners must notify the Agency Central Office within 10 days of a change in facility administrator on the Notification of Change of Administrator form, AHCA Form 3180-1006, , which is incorporated by reference and available online at: http://www.flrules.org/Gateway/reference.asp?No	A 077		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 11/30/2020
NAME OF PROVIDER OR SUPPLIER GENESIS ALF VALRICO		STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BLACK KNIGHT DR, VALRICO, FL 33594		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 077	Continued From page 3 =Ref-09393. This Statute or Rule is not met as evidenced by: Based on record review and interview, the facility failed to maintain documentation that verified completion of passing of the core competency test by the Administrator. Findings included: Record review conducted on _____ revealed there was no evidence that the Administrator had passed the competency exam in the record. Interview with the Assistant Administrator at 1:20pm on _____ provided no explanation why this document was not available for Agency inspection. Class III	A 077		
A 200 SS=D	59A-36.025 FAC Emergency Environmental Control 59A-36.025 Emergency Environmental Control for Assisted Living Facilities. (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the assisted living facility, to ensure that current licensees of assisted living facilities will be	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 11/30/2020
NAME OF PROVIDER OR SUPPLIER GENESIS ALF VALRICO			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BLACK KNIGHT DR, VALRICO, FL 33594		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 4 equipped to ensure air temperatures will be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is appropriate for resident care needs and life safety requirements. For planning purposes, no less than twenty (20) net square . . . per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed capacity as the number of residents to be used in the to determine the required square footage. This may include areas that are less than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving provider for evacuees when the conditions stated in section 408.821, F.S. and subsection 59A-36.019(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained. 2. The alternate power source and fuel supply shall be located in an area(s) in accordance with local zoning and the Florida Building Code. 3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly,	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 11/30/2020
NAME OF PROVIDER OR SUPPLIER GENESIS ALF VALRICO			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BLACK KNIGHT DR, VALRICO, FL 33594		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 5 this rule does not limit the types of systems or equipment that may be used to achieve temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to operate the systems and equipment. a. An assisted living facility in an evacuation zone pursuant to chapter 252, F, S. must maintain an alternative power source and fuel as required by this subsection at all times when the assisted living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if evacuation is necessary. b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly described in the emergency power plan. c. A multistory facility, whose comprehensive emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional equipment so it can safely operate in a location protected from flooding or storm surge damage. (b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the alternate power source to maintain temperatures at or below 81 degrees Fahrenheit	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 11/30/2020
NAME OF PROVIDER OR SUPPLIER GENESIS ALF VALRICO			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BLACK KNIGHT DR, VALRICO, FL 33594		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 6 for a minimum of ninety-six (96) hours after the loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel storage. 1. Facilities must store minimum amounts of fuel onsite as follows: a. A facility with a licensed capacity of 16 beds or less must store 48 hours of fuel onsite. b. A facility with a licensed capacity of 17 or more beds must store 72 hours of fuel onsite. 2. An assisted living facility located in an area in a declared state of emergency area pursuant to section 252.36, F.S. that may impact primary power delivery must secure ninety-six (96) hours of fuel. The assisted living facility may utilize portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency. 3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule. 4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living facility must develop a plan that includes maximum onsite fuel storage allowable by the ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a monoxide alarm. (2) SUBMISSION OF THE PLAN. (a) Each assisted living facility licensed prior to	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 11/30/2020
NAME OF PROVIDER OR SUPPLIER GENESIS ALF VALRICO			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BLACK KNIGHT DR, VALRICO, FL 33594		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 7 the effective date of this rule shall submit its plan to the local emergency management agency for review within 30 days of the effective date of this rule. Assisted living facility plans previously submitted and approved pursuant to emergency Rule 58AER17-1 will require resubmission only if changes are made to the plan. (b) Each new assisted living facility shall submit the plan required under this rule prior to obtaining a license. (c) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the local emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally authorized entity. If the plan is maintained in an electronic format, assisted living facility staff must be readily available to access and produce the plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within two (2) business days of the approval of the plan from the local emergency management agency, the assisted living facility shall submit in writing proof of the approval to the Agency for Health Care Administration. (c) The assisted living facility shall submit a consumer-friendly summary of the emergency power plan to the Agency. The Agency shall post the summary and notice of the approval and	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 11/30/2020
NAME OF PROVIDER OR SUPPLIER GENESIS ALF VALRICO			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BLACK KNIGHT DR, VALRICO, FL 33594		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 8 implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the local emergency management agency and update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall, no later than _____, have implemented the plan required under this rule. (b) The Agency shall allow an extension up to _____ to providers in compliance with paragraph (c) below and who can show delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes. Assisted living facilities shall notify the Agency that they will utilize the extension and keep the Agency apprised of progress on a quarterly basis to ensure there are no unnecessary delays. If an assisted living facility can show in its quarterly progress reports that unavoidable delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes will occur beyond the initial extension date, the assisted living facility may request a waiver pursuant to section 120.542, F.S. (c) During the extension period, an assisted living facility must make arrangements pending full implementation of its plan that provides the residents with an area or areas to congregate that meets the safe indoor air temperature requirements of subsection (1) (a) for a minimum of ninety-six (96) hours. 1. An assisted living facility not located in an evacuation zone must either have an alternative power source onsite or have a contract in place for delivery of an alternative power source and	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 11/30/2020
NAME OF PROVIDER OR SUPPLIER GENESIS ALF VALRICO			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BLACK KNIGHT DR, VALRICO, FL 33594		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 9 fuel when requested. Within twenty-four (24) hours of the issuance of a state of emergency for an event that may impact primary power delivery for the area of the assisted living facility, it must have the alternative power source and no less than ninety-six (96) hours of fuel stored onsite. 2. An assisted living facility located in an evacuation zone pursuant to chapter 252, F.S. must either: a. Fully and safely evacuate its residents prior to the arrival of the event; or b. Have an alternative power source and no less than ninety-six (96) hours of fuel stored onsite, within twenty-four (24) hours of the issuance of a state of emergency for the area of the assisted living facility. (d) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (e) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan concurrent with any such additions, modifications, alterations, refurbishment, renovations or reconstruction. (f) The Agency for Health Care Administration may request cooperation from the State Fire Marshal to conduct inspections to ensure implementation of the plan in compliance with this rule. (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can effectively and immediately activate, operate and maintain the alternate power source and any fuel	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 11/30/2020
NAME OF PROVIDER OR SUPPLIER GENESIS ALF VALRICO			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BLACK KNIGHT DR, VALRICO, FL 33594		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 10 required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in air temperatures inside the facility. Procedures must address the care of residents occupying the facility during a declared state of emergency, specifically, a description of the methods to be used to mitigate the potential for heat related injury including: 1. The use of cooling devices and equipment; 2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration; 3. Wellness checks by assisted living facility staff to monitor for signs of ... and heat injury; and 4. A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy. (b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted living facility staff must be readily available to access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request. (c) The written policies and procedures must be readily available for inspection by each resident; each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by law. (6) REVOCATION OF LICENSE, FINES OR	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 11/30/2020
NAME OF PROVIDER OR SUPPLIER GENESIS ALF VALRICO			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BLACK KNIGHT DR, VALRICO, FL 33594		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 11 SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by chapter 429, part I, or chapter 408, part II, F.S., including, but not limited to, license revocation, license suspension, and the imposition of administrative fines. (7) COMPREHENSIVE EMERGENCY MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION. (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon submission of the plan to the local emergency management agency that the plan has been submitted for review and approval; 2. Upon final implementation of the plan by the assisted living facility. (b) Each assisted living facility must maintain a copy of each notification set forth in paragraph (a) above in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the notifications, either in electronic or paper format, upon request.	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 11/30/2020
NAME OF PROVIDER OR SUPPLIER GENESIS ALF VALRICO			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BLACK KNIGHT DR, VALRICO, FL 33594		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 12 This Statute or Rule is not met as evidenced by: Based on observation and interview, the facility failed to maintain its generator and fuel tank in a safe distance from the facility. Additionally, the facility did not have a _____ monoxide detector. Findings included: During a tour of the facility at approximately 4:25pm on _____, the facility's portable generator was observed to be inside the facility, located in the storage area in front of the Administrator's office area. In addition, the facility's fuel tank was noted to be outside and less than 6 inches from the side of the facility, almost leaning up against it. Finally, there were no _____ monoxide detectors were observed in the facility. Interview with the Assistant Administrator at 4:40pm on _____ indicated that they had no _____ monoxide alarm on the premises, and that he was unaware of this requirement. Class III	A 200			
AL241 SS=D	429.075(_____); 59A-36.020(2) FAC LMH - Records 429.075 (3) A facility that has a limited mental health license must: (a) Have a copy of each mental health resident's community living support plan and the _____ agreement with the mental health care services provider or provide written evidence that a request for the community living support plan and the _____ agreement was sent to the Medicaid managed care plan or managing	AL241			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 11/30/2020
NAME OF PROVIDER OR SUPPLIER GENESIS ALF VALRICO			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BLACK KNIGHT DR, VALRICO, FL 33594		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
AL241	Continued From page 13 entity under contract with the Department of Children and Families within 72 hours after admission. The support plan and the agreement may be combined. (b) Have documentation provided by the department that each mental health resident has been assessed and determined to be able to live in the community in an assisted living facility that has a limited mental health license or provide written evidence that a request for documentation was sent to the department within 72 hours after admission. (c) Make the community living support plan available for inspection by the resident, the resident's legal guardian or health care surrogate, and other individuals who have a lawful basis for reviewing this document. (d) Assist the mental health resident in carrying out the activities identified in the resident's community living support plan. (4) A facility that has a limited mental health license may enter into a _____ agreement with a private mental health provider. For purposes of the limited mental health license, the private mental health provider may act as the case manager. 59A-36.020 (2) RECORDS. (a) A facility with a limited mental health license must maintain an up-to-date admission and discharge log containing the names and dates of admission and discharge for all mental health residents. The admission and discharge log required in rule 59A-36.015, F.A.C., satisfies this condition provided that all mental health residents are clearly identified. (b) Staff records must contain documentation that designated staff have completed limited mental	AL241			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 11/30/2020
NAME OF PROVIDER OR SUPPLIER GENESIS ALF VALRICO			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BLACK KNIGHT DR, VALRICO, FL 33594		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
AL241	Continued From page 14 health training as required by rule 59A-36.011, F.A.C. (c) Resident records must include: 1. Documentation, provided by a mental health care provider within 30 days of the resident's admission to the facility, that the resident is a mental health resident as defined in section 394.4574, F.S., and that the resident is receiving social security _____, or supplemental security income and _____ as follows: a. An affirmative statement on the Alternate Care Certification for _____ () form, CF-ES 1006, _____, which is hereby incorporated by reference and available for review at: http://www.flrules.org/Gateway/reference.asp?No=Ref-03988, that the resident is receiving SSI or SSDI due to a mental _____. b. Written verification provided by the Social Security Administration that the resident is receiving SSI or SSDI for a mental _____. Such verification may be acquired from the Social Security Administration upon obtaining a release from the resident permitting the Social Security Administration to provide such information, or c. A written statement from the resident's case manager or other mental health care provider that the resident is an adult with severe and persistent mental _____. The case manager or other mental health care provider must consider the following minimum criteria in making that determination: (i) The resident is eligible for, is receiving, or has received mental health services within the last 5 years, or (ii) The resident has been diagnosed as having a severe or persistent mental _____. 2. An appropriate placement assessment	AL241			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 11/30/2020
NAME OF PROVIDER OR SUPPLIER GENESIS ALF VALRICO			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BLACK KNIGHT DR, VALRICO, FL 33594		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
AL241	Continued From page 15 provided by the resident's mental health care provider within 30 days of admission to the facility that the resident has been assessed and found appropriate for residence in an assisted living facility. Such assessment must be conducted by a psychiatrist, clinical psychologist, clinical social worker, _____ nurse, or an individual supervised by one of these professionals. a. Any of the following documentation that contains the name of the resident and the name, signature, date, and license number, if applicable, of the person making the assessment, meets this requirement: (I) Completed Alternate Care Certification for _____ (_____) form, CF-ES Form 1006, (II) Discharge Statement from a state mental hospital completed no more than 90 days before admission to the assisted living facility provided it contains a statement that the individual is appropriate to live in an assisted living facility, or (III) Other signed statement that the resident has been assessed and found appropriate for residency in an assisted living facility. b. A mental health resident returning to a facility from treatment in a hospital or crisis stabilization unit will not be considered a new admission and will not require a new assessment. However, a break in a resident's residency that requires the facility to execute a new resident contract or admission agreement will be considered a new admission and the resident's mental health care provider must provide a new assessment. 3. A Community Living Support Plan. Each mental health resident and the resident's mental health case manager must, in consultation with the facility administrator, prepare a plan within 30 days of the resident's admission to the facility or within 30 days after receiving the appropriate	AL241			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 11/30/2020
NAME OF PROVIDER OR SUPPLIER GENESIS ALF VALRICO			STREET ADDRESS, CITY, STATE, ZIP CODE 1108 BLACK KNIGHT DR, VALRICO, FL 33594		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
AL241	Continued From page 16 placement assessment in paragraph (2)(c), whichever is later, that: a. Includes the specific needs of the resident that must be met in order to enable the resident to live in the assisted living facility and the community, b. Includes the clinical mental health services to be provided by the mental health care provider to help meet the resident's needs, and the frequency and duration of such services, c. Includes any other services and activities to be provided by or arranged for by the mental health care provider or mental health case manager to meet the resident's needs, and the frequency and duration of such services and activities, d. Includes the _____ of the facility to facilitate and assist the resident in attending _____ and arranging transportation to _____ for the services and activities identified in the plan that have been provided or arranged for by the resident's mental health care provider or case manager, e. Includes a description of other services to be provided or arranged by the facility, f. Includes a list of factors pertinent to the care, safety, and welfare of the mental health resident and a description of the signs and symptoms _____ to the resident that indicate the immediate need for professional mental health services, g. Is in writing and signed by the mental health resident, the resident's mental health case manager, and the assisted living facility administrator or manager and a copy placed in the resident's file. If the resident refuses to sign the plan, the resident's mental health case manager must add a statement that the resident was asked but refused to sign the plan, h. Is updated at least annually or if there is a significant change in the resident's behavioral	AL241			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 11/30/2020
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

GENESIS ALF VALRICO

**1108 BLACK KNIGHT DR,
VALRICO, FL 33594**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
AL241	Continued From page 17 health, i. , include the , Agreement described in subparagraph (2)(c)4. If included, the mental health care provider must also sign the plan; and, j. Must be available for inspection to those who have legal authority to review the document. 4. , Agreement. The mental health care provider for each mental health resident and the facility administrator or designee must prepare a written statement, within 30 days of the resident's admission to the facility or receipt of the resident's appropriate placement assessment, whichever is later. The statement: a. Provides procedures and directions for accessing emergency and after-hours care for the mental health resident. The provider must furnish the resident and the facility with the provider's 24-hour emergency crisis telephone number; b. Must be signed by the administrator or designee and the mental health care provider, or by a designated representative of a Medicaid prepaid health plan if the resident is on a plan and the plan provides behavioral health services in section 409.912, F.S.; c. , cover all mental health residents of the facility who are clients of the same provider; and, d. , be included in the Community Living Support Plan described in subparagraph (2)(c)3. 5. Missing documentation will not be the basis for administrative action against a facility if the facility can demonstrate that it has made a good faith effort to obtain the required documentation from the appropriate party. A documented request for such missing documentation made by the facility administrator within 72 hours of the resident's admission will be considered a good faith effort. The documented request must include the name,	AL241		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968909	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 11/30/2020
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

GENESIS ALF VALRICO

**1108 BLACK KNIGHT DR,
VALRICO, FL 33594**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
AL241	Continued From page 18 title, and phone number of the person to whom the request was made and must be kept in the resident's file. This Statute or Rule is not met as evidenced by: Based on record review and interview, the facility failed to obtain the community living support plan and _____ agreement for one of one limited mental health (LMH) resident sampled (#1). In addition, the facility failed to obtain documentation provided by the Department of Children & Families (DCF) that this resident had been assessed and determined to be able to live in the community in an assisted living facility that has a LMH license or provide evidence that a request for said documentation was sent to the Dept. within 72 hours after admission. Findings included: Resident record review conducted _____ revealed that Resident #1, admitted early _____, was an LMH resident per an _____ certification. However, further review of the file found no documentation furnished from DCF indicating that she had been determined to be able to live in the community in an assisted living facility. In addition, there was no _____ agreement or community living support plan available for inspection for Resident #1. In an interview with the Assistant Administrator conducted on _____ at 11am, these omissions were verified. Class III	AL241		