

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	
A 000	Initial Comments A re-licensure survey was conducted at South Miami Senior Care on 07/12/2022. The provider had deficiencies identified at the time of the survey.		A 000		
A 031 SS=D	59A-36.007(6) FAC Resident Care - Third Party Services (6) THIRD PARTY SERVICES. (a) Nothing in this rule chapter is intended to prohibit a resident or the resident's representative from independently arranging, _____, and paying for services provided by a third party of the resident's choice, including a licensed home health agency or private nurse, or receiving services through an out-patient clinic, provided the resident meets the criteria for admission and continued residency and the resident complies with the facility's policy relating to the delivery of services in the facility by third parties. The facility's policies must require the third party to coordinate with the facility regarding the resident's condition and the services being provided. (b) When residents require or arrange for services from a third party provider, the facility administrator or designee must allow for the receipt of those services, provided that the resident meets the criteria for admission and continued residency. The facility, when requested by residents or representatives, must coordinate with the provider to facilitate the receipt of care and services provided to meet the resident's needs. (c) The administrator or designee must ensure that: 1. Care coordination includes documented communications about the resident's condition and response to treatment or services ordered by		A 031		

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X8) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 031	Continued From page 1 the physician which may impact the resident's appropriateness for continued residency in the facility; 2. Communications occur at least once every 30 days and whenever there is a significant change in the resident's condition; and 3. If physician ordered treatments or services occur less often than once a month, communications must be conducted according to the ordered treatment or service schedule and whenever there is a significant change in the resident's condition. 4. When communication with the third party provider is unsuccessful, at least two attempts at communication on two separate days must be documented. Documentation must include the name of the person from the third party provider with whom contact was attempted, the method of communication, and the date and time of the attempts. This documentation must be included in the resident's record in accordance with the timeframes in subparagraphs 59A-36.007(6)(c)2. and 3. (d) If residents accept assistance from the facility in arranging and coordinating third party services, the facility's assistance does not represent a guarantee that third party services will be received. If the facility's efforts to make arrangements for third party services are unsuccessful or declined by residents, the facility must include documentation in the residents' record explaining why its efforts were unsuccessful. This documentation will serve to demonstrate its compliance with this subsection. This Statute or Rule is not met as evidenced by: Based on record review and interview the facility failed to ensure that a third party that provides hospice services to one out of five sampled residents (# 2), kept the initial plan of care and	A 031			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 031	Continued From page 2 the most updated care plan at the facility. Findings included: A review of Resident # 2's record revealed that she was receiving hospice services since _____, revealed that there was no initial care plan and no care plan review. On _____ at 12:50 PM the Administrator stated, "I kept telling the nurse to bring it, that I was waiting for AHCA." Class III	A 031			
A 077 SS=D	429.176 FS; 429.52() .59A-36.01(1) FAC Staffing Standards - Administrators 429.176 Notice of change of administrator.-If, during the period for which a license is issued, the owner changes administrators, the owner must notify the agency of the change within 10 days and provide documentation within 90 days that the new administrator meets educational requirements and has completed the applicable core educational requirements under s. 429.52. A facility may not be operated for more than 120 consecutive days without an administrator who has completed the core educational requirements. 429.52 (4) A facility administrator must complete the required core training, including the competency test, within 90 days after the date of employment as an administrator. Failure to do so is a violation of this part and subjects the violator to an administrative fine as prescribed in s. 429.19. Administrators licensed in accordance with part II	A 077			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 077	Continued From page 3 of chapter 468 are exempt from this requirement. Other licensed professionals may be exempted, as determined by the agency by rule. (5) Administrators are required to participate in continuing education for a minimum of 12 contact hours every 2 years. 59A-36.010 (1) ADMINISTRATORS. Every facility must be under the supervision of an administrator who is responsible for the operation and maintenance of the facility including the management of all staff and the provision of appropriate care to all residents as required by chapters 408, part II, 429, part I, F.S., and rule chapter 59A-35, F.A.C., and this rule chapter. (a) An administrator must: 1. Be at least _____; 2. If employed on or after _____, have, at a minimum, a high school diploma or G.E.D.; 3. Be in compliance with Level 2 background screening requirements pursuant to sections 408.809 and 429.174, F.S.; 4. Complete the core training and core competency test requirements pursuant to rule 59A-36.011, F.A.C., no later than 90 days after becoming employed as a facility administrator. Administrators who attended core training prior to _____, are not required to take the competency test unless specified elsewhere in this rule; and, 5. Satisfy the continuing education requirements pursuant to rule 59A-36.011, F.A.C. Administrators who are not in compliance with these requirements must retake the core training and core competency test requirements in effect on the date the non-compliance is discovered by the agency or the department.	A 077			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 077	Continued From page 4 (b) In the event of extenuating circumstances, such as the _____ of a facility administrator, the agency may permit an individual who otherwise has not satisfied the training requirements of subparagraph (1)(a)4. of this rule, to temporarily serve as the facility administrator for a period not to exceed 90 days. During the 90 day period, the individual temporarily serving as facility administrator must: 1. Complete the core training and core competency test requirements pursuant to rule 59A-36.011, F.A.C.; and, 2. Complete all additional training requirements if the facility maintains licensure as an extended congregate care or limited mental health facility. (c) Administrators may supervise a maximum of either three assisted living facilities or a group of facilities on a single campus providing housing and health care Administrators who supervise more than one facility must appoint in writing a separate manager for each facility. However, an administrator supervising a maximum of three assisted living facilities, each licensed for 16 or fewer beds and all within a 15 mile _____ of each other, is only required to appoint two managers to assist in the operation and maintenance of those facilities. (d) An individual serving as a manager must satisfy the same qualifications, background screening, core training and competency test requirements, and continuing education requirements as an administrator pursuant to paragraph (1)(a) of this rule. Managers who attended the core training program prior to _____, _____, are not required to take the competency test unless specified elsewhere in this rule. In addition, a manager may not serve as a manager of more than a single facility, except as provided in paragraph (1)(c) of this rule, and	A 077			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 077	Continued From page 5 may not serve as an administrator of any other facility. (e) Pursuant to section 429.176, F.S., facility owners must notify the Agency Central Office within 10 days of a change in facility administrator on the Notification of Change of Administrator form, AHCA Form 3180-1006,, which is incorporated by reference and available online at: http://www.flrules.org/Gateway/reference.asp?No=Ref-09393. This Statute or Rule is not met as evidenced by: Based on record review and interview the facility failed to ensure the facility manager have at a minimum, a high school diploma or G.E.D. on file. Findings included: A review of employee records revealed that the manager had been hired on There was no copy of the high school diploma, G.E.D or higher degree in file. On at 10:45 AM, regarding the manager's high school diploma, the Administrator stated, " I do not know why it is not there." Class III	A 077			
A 081 SS=D	429.52(1 & 7) FS; 59A-36.011() FAC Training - Staff In-Service 429.52(1) (1) Each new assisted living facility employee who has not previously completed core training must attend a preservice orientation provided by	A 081			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 081	Continued From page 6 the facility before interacting with residents. The preservice orientation must be at least 2 hours in duration and cover topics that help the employee provide responsible care and respond to the needs of facility residents. Upon completion, the employee and the administrator of the facility must sign a statement that the employee completed the required preservice orientation. The facility must keep the signed statement in the employee's personnel record. (7) Facility staff shall participate in inservice training relevant to their job duties as specified by agency rule. Topics covered during the preservice orientation are not required to be repeated during inservice training. A single certificate of completion that covers all required inservice training topics may be issued to a participating staff member if the training is provided in a single training course. 59A-36.011 (2) STAFF PRESERVICE ORIENTATION. (a) Facilities must provide a preservice orientation of at least 2 hours to all new assisted living facility employees who have not previously completed core training as detailed in subsection (1). (b) New staff must complete the preservice orientation prior to interacting with residents. (c) Once complete, the employee and the facility administrator must sign a statement that the employee completed the preservice orientation which must be kept in the employee's personnel record. (d) In addition to topics that may be chosen by the facility administrator, the preservice orientation must cover: 1. Resident's rights; and,	A 081			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 07/12/2022
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SOUTH MIAMI SENIOR CARE

**15592 SW 183 LANE
MIAMI, FL 33185**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 081	Continued From page 7 2. The facility's license type and services offered by the facility. (3) STAFF IN-SERVICE TRAINING. Facility administrators or managers shall provide or arrange for the following in-service training to facility staff: (a) Staff who provide direct care to residents, other than nurses, certified nursing assistants, or home health aides trained in accordance with rule 59A-8.0095, F.A.C., must receive a minimum of 1 hour in-service training in _____ control, including universal precautions and facility sanitation procedures, before providing personal care to residents. The facility must use its _____ control policies and procedures when offering this training. Documentation of compliance with the staff training requirements of 29 CFR 1910.1030, relating to _____ borne _____, may be used to meet this requirement. (b) Staff who provide direct care to residents must receive a minimum of 1 hour in-service training within 30 days of employment that covers the following subjects: 1. Reporting adverse incidents. 2. Facility emergency procedures including chain-of-command and staff roles relating to emergency evacuation. (c) Staff who provide direct care to residents, who have not taken the core training program, shall receive a minimum of 1 hour in-service training within 30 days of employment that covers the following subjects: 1. Resident rights in an assisted living facility. 2. Recognizing and reporting resident _____, neglect, and _____. The facility must use its _____ prevention policies and procedures when offering this training. (d) Staff who provide direct care to residents,	A 081		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 081	Continued From page 8 other than nurses, CNAs, or home health aides trained in accordance with rule 59A-8.0095, F.A.C., must receive 3 hours of in-service training within 30 days of employment that covers the following subjects: 1. Resident behavior and needs. 2. Providing assistance with the activities of daily living. (e) Staff who prepare or serve food, who have not taken the assisted living facility core training must receive a minimum of 1-hour-in-service training within 30 days of employment in safe food handling practices. (f) All facility staff shall receive in-service training regarding the facility's resident elopement response policies and procedures within thirty (30) days of employment. 1. All facility staff shall be provided with a copy of the facility's resident elopement response policies and procedures. 2. All facility staff shall demonstrate an understanding and competency in the implementation of the elopement response policies and procedures. This Statute or Rule is not met as evidenced by: Based on record review and interview the facility failed to provide evidence that one out of three sampled staff (Manager) had received in-service training regarding the facility's resident elopement response policies and procedures within thirty (30) days of employment. Findings included: A review of the employee records revealed that the Manager had been hired on There	A 081			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 081	Continued From page 9 was no documentation staff had completed the elopement response policies and procedures training in file. On at 10:50 AM the Administrator stated, "She should have those training's, the consultant recently reviewed those records." Class III		A 081		
A 090 SS=D	59A-36.011(11) FAC Training - (11) TRAINING. (a) Currently employed facility administrators, managers, direct care staff and staff involved in resident admissions must receive at least one hour of training in the facility's policies and procedures regarding (b) Newly hired facility administrators, managers, direct care staff and staff involved in resident admissions must receive at least one hour of training in the facility's policy and procedures regarding . . . within 30 days after employment. (c) Training shall consist of the information included in rule 59A-36.009, F.A.C. This Statute or Rule is not met as evidenced by: Based on record review and interview the facility failed failed to ensure that one out of three sampled staff (Manager) received at least one hour of training on the facility's policies and procedures regarding Findings included: A review of the employee records revealed that		A 090		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 090	Continued From page 10 the Manager had been hired on There was no documentation the manager had completed the one hour training on the facility's policies and procedures regarding On at 10:51 AM the Administrator stated, "She is studying to be a nurse, probably she took it." Class III	A 090			
A 200 SS=D	59A-36.025 FAC Emergency Environmental Control 59A-36.025 Emergency Environmental Control for Assisted Living Facilities. (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the assisted living facility, to ensure that current licensees of assisted living facilities will be equipped to ensure air temperatures will be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is appropriate for resident care needs and life safety requirements. For planning purposes, no less	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 07/12/2022
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SOUTH MIAMI SENIOR CARE

**15592 SW 183 LANE
MIAMI, FL 33185**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 11 than twenty (20) net square . . . per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed capacity as the number of residents to be used in the to determine the required square footage. This may include areas that are less than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving provider for evacuees when the conditions stated in section 408.821, F.S. and subsection 59A-36.019(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained. 2. The alternate power source and fuel supply shall be located in an area(s) in accordance with local zoning and the Florida Building Code. 3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly, this rule does not limit the types of systems or equipment that may be used to achieve temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to operate the systems and equipment. a. An assisted living facility in an evacuation zone	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 12 pursuant to chapter 252, F. S. must maintain an alternative power source and fuel as required by this subsection at all times when the assisted living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if evacuation is necessary. b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly described in the emergency power plan. c. A multistory facility, whose comprehensive emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional equipment so it can safely operate in a location protected from flooding or storm surge damage. (b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the alternate power source to maintain temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours after the loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel storage. 1. Facilities must store minimum amounts of fuel onsite as follows: a. A facility with a licensed capacity of 16 beds or less must store 48 hours of fuel onsite. b. A facility with a licensed capacity of 17 or more	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 13 beds must store 72 hours of fuel onsite. 2. An assisted living facility located in an area in a declared state of emergency area pursuant to section 252.36, F.S. that may impact primary power delivery must secure ninety-six (96) hours of fuel. The assisted living facility may utilize portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency. 3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule. 4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living facility must develop a plan that includes maximum onsite fuel storage allowable by the ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a monoxide alarm. (2) SUBMISSION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall submit its plan to the local emergency management agency for review within 30 days of the effective date of this rule. Assisted living facility plans previously submitted and approved pursuant to emergency Rule 58AER17-1 will require resubmission only if changes are made to the plan. (b) Each new assisted living facility shall submit the plan required under this rule prior to obtaining a license.	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 14 (c) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the local emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally authorized entity. If the plan is maintained in an electronic format, assisted living facility staff must be readily available to access and produce the plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within two (2) business days of the approval of the plan from the local emergency management agency, the assisted living facility shall submit in writing proof of the approval to the Agency for Health Care Administration. (c) The assisted living facility shall submit a consumer-friendly summary of the emergency power plan to the Agency. The Agency shall post the summary and notice of the approval and implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the local emergency management agency and update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall, no later than _____, have implemented the plan	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 15 required under this rule. (b) The Agency shall allow an extension to _____ to providers in compliance with paragraph (c) below and who can show delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes. Assisted living facilities shall notify the Agency that they will utilize the extension and keep the Agency apprised of progress on a quarterly basis to ensure there are no unnecessary delays. If an assisted living facility can show in its quarterly progress reports that unavoidable delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes will occur beyond the initial extension date, the assisted living facility may request a waiver pursuant to section 120.542, F.S. (c) During the extension period, an assisted living facility must make arrangements pending full implementation of its plan that provides the residents with an area or areas to congregate that meets the safe indoor air temperature requirements of subsection (1) (a) for a minimum of ninety-six (96) hours. 1. An assisted living facility not located in an evacuation zone must either have an alternative power source onsite or have a contract in place for delivery of an alternative power source and fuel when requested. Within twenty-four (24) hours of the issuance of a state of emergency for an event that may impact primary power delivery for the area of the assisted living facility, it must have the alternative power source and no less than ninety-six (96) hours of fuel stored onsite. 2. An assisted living facility located in an evacuation zone pursuant to chapter 252, F.S. must either: a. Fully and safely evacuate its residents prior to	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 16 the arrival of the event; or b. Have an alternative power source and no less than ninety-six (96) hours of fuel stored onsite, within twenty-four (24) hours of the issuance of a state of emergency for the area of the assisted living facility. (d) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (e) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan concurrent with any such additions, modifications, alterations, refurbishment, renovations or reconstruction. (f) The Agency for Health Care Administration may request cooperation from the State Fire Marshal to conduct inspections to ensure implementation of the plan in compliance with this rule. (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can effectively and immediately activate, operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in air temperatures inside the facility. Procedures must address the care of residents occupying the facility during a declared state of emergency, specifically, a description of the methods to be used to mitigate the potential for heat related injury including: 1. The use of cooling devices and equipment;	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 17 2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration; 3. Wellness checks by assisted living facility staff to monitor for signs of _____ and heat injury; and 4. A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy. (b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted living facility staff must be readily available to access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request. (c) The written policies and procedures must be readily available for inspection by each resident; each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by law. (6) REVOCATION OF LICENSE, FINES OR SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by chapter 429, part I, or chapter 408, part II, F.S., including, but not limited to, license revocation, license suspension, and the imposition of administrative fines. (7) COMPREHENSIVE EMERGENCY MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 18 emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION. (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon submission of the plan to the local emergency management agency that the plan has been submitted for review and approval; 2. Upon final implementation of the plan by the assisted living facility. (b) Each assisted living facility must maintain a copy of each notification set forth in paragraph (a) above in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the notifications, either in electronic or paper format, upon request. This Statute or Rule is not met as evidenced by: Based on record review and interview the facility failed to ensure residents or their legal representatives were notify in writing of the approval of the comprehensive emergency management plan for one out of five sampled residents (# 4) . Findings included:	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967136	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/12/2022
NAME OF PROVIDER OR SUPPLIER SOUTH MIAMI SENIOR CARE		STREET ADDRESS, CITY, STATE, ZIP CODE 15592 SW 183 LANE MIAMI, FL 33185			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 19 A review of the residents' records revealed that there was no proof that Resident # 4 or her legal representative had been notified in writing of the approval of the comprehensive emergency management plan. On at 10:55 AM the Administrator stated that she [resident #4] was a new resident. Class III	A 200			