

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/13/2022
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SILVER PALM ALF CORP

**11271 SW 229 TERRACE
MIAMI, FL 33170**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 000	Initial Comments A biennial survey was conducted at Silver Palm ALF, Corp on 09/13/2022. The provider had deficiencies identified at the time of the visit.	A 000		
A 054 SS=D	59A-36.008(5) FAC Medication - Records (5) MEDICATION RECORDS. (a) For residents who use a pill organizer managed in subsection (2), the facility must keep either the original labeled medication container; or a medication listing with the prescription number, the name and address of the issuing pharmacy, the health care provider's name, the resident's name, the date dispensed, the name and strength of the drug, and the directions for use. (b) The facility must maintain a daily medication observation record for each resident who receives assistance with self-administration of medications or medication administration. A medication observation record must be immediately updated each time the medication is offered or administered and include: 1. The name of the resident and any known _____ the resident may have; 2. The name of the resident's health care provider and the health care provider's telephone number; 3. The name, strength, and directions for use of each medication; and, 4. A chart for recording each time the medication is taken, any missed dosages, refusals to take medication as prescribed, or medication errors. (c) For medications that serve as chemical _____, the facility must, pursuant to Section 429.41, F.S., maintain a record of the prescribing physician's annual evaluation of the use of the medication.	A 054		

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 054	Continued From page 1 This Statute or Rule is not met as evidenced by: Based on observation, record review and interview the facility failed to maintain an accurate daily medication observation record (MOR) for each resident who receives assistance with self-administration of medications or medication administration that included each time the medications were offered or administered and any known the resident may have for three out of five sampled residents (Resident #1, Resident #2 and Resident #4). Findings included: 1) On at 1:00 PM, observation showed during medication pass that Staff B (caregiver) assisted Resident #4 with the self-administration of medication. Further observation showed that Staff B signed the MOR before she gave the medications to the resident and prior the resident had taken the medications. 2) Review of Resident #1's MOR showed the resident had been identified as with "No Known Drug" Review of Resident # 1's health assessment completed revealed that Resident #1 had to and Sulfa Review of Resident #2's MOR showed that Resident #2 had been identified as with "No Known Drug" Further review of Resident # 2's health assessment completed revealed that Resident #2 had to radiographic dye and On at 2:20 PM, Staff B acknowledged that she signed the MOR in advance and that the	A 054			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP		STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 054	Continued From page 2 MOR did not include the residents' _____ Class III	A 054		
A 081 SS=D	429.52(1 & 7) FS; 59A-36.011() FAC Training - Staff In-Service 429.52(1) (1) Each new assisted living facility employee who has not previously completed core training must attend a preservice orientation provided by the facility before interacting with residents. The preservice orientation must be at least 2 hours in duration and cover topics that help the employee provide responsible care and respond to the needs of facility residents. Upon completion, the employee and the administrator of the facility must sign a statement that the employee completed the required preservice orientation. The facility must keep the signed statement in the employee's personnel record. (7) Facility staff shall participate in inservice training relevant to their job duties as specified by agency rule. Topics covered during the preservice orientation are not required to be repeated during inservice training. A single certificate of completion that covers all required inservice training topics may be issued to a participating staff member if the training is provided in a single training course. 59A-36.011 (2) STAFF PRESERVICE ORIENTATION. (a) Facilities must provide a preservice orientation of at least 2 hours to all new assisted living facility employees who have not previously completed core training as detailed in subsection (1).	A 081		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/13/2022
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SILVER PALM ALF CORP

**11271 SW 229 TERRACE
MIAMI, FL 33170**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 081	Continued From page 3 (b) New staff must complete the preservice orientation prior to interacting with residents. (c) Once complete, the employee and the facility administrator must sign a statement that the employee completed the preservice orientation which must be kept in the employee's personnel record. (d) In addition to topics that may be chosen by the facility administrator, the preservice orientation must cover: 1. Resident's rights; and, 2. The facility's license type and services offered by the facility. (3) STAFF IN-SERVICE TRAINING. Facility administrators or managers shall provide or arrange for the following in-service training to facility staff: (a) Staff who provide direct care to residents, other than nurses, certified nursing assistants, or home health aides trained in accordance with rule 59A-8.0095, F.A.C., must receive a minimum of 1 hour in-service training in control, including universal precautions and facility sanitation procedures, before providing personal care to residents. The facility must use its control policies and procedures when offering this training. Documentation of compliance with the staff training requirements of 29 CFR 1910.1030, relating to blood borne pathogens, may be used to meet this requirement. (b) Staff who provide direct care to residents must receive a minimum of 1 hour in-service training within 30 days of employment that covers the following subjects: 1. Reporting adverse incidents. 2. Facility emergency procedures including chain-of-command and staff roles relating to emergency evacuation.	A 081		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/13/2022
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SILVER PALM ALF CORP

**11271 SW 229 TERRACE
MIAMI, FL 33170**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 081	Continued From page 4 (c) Staff who provide direct care to residents, who have not taken the core training program, shall receive a minimum of 1 hour in-service training within 30 days of employment that covers the following subjects: 1. Resident rights in an assisted living facility. 2. Recognizing and reporting resident _____, neglect, and _____. The facility must use its _____ prevention policies and procedures when offering this training. (d) Staff who provide direct care to residents, other than nurses, CNAs, or home health aides trained in accordance with rule 59A-8.0095, F.A.C., must receive 3 hours of in-service training within 30 days of employment that covers the following subjects: 1. Resident behavior and needs. 2. Providing assistance with the activities of daily living. (e) Staff who prepare or serve food, who have not taken the assisted living facility core training must receive a minimum of 1-hour-in-service training within 30 days of employment in safe food handling practices. (f) All facility staff shall receive in-service training regarding the facility's resident elopement response policies and procedures within thirty (30) days of employment. 1. All facility staff shall be provided with a copy of the facility's resident elopement response policies and procedures. 2. All facility staff shall demonstrate an understanding and competency in the implementation of the elopement response policies and procedures. This Statute or Rule is not met as evidenced by:	A 081		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 081	Continued From page 5 Based on record review and interview, the facility failed to ensure one out of four sampled staff had documentation of the required in-service training (Staff D). Findings included: Review of personnel record for Staff D showed no documentation of the employee having received all the pre-service trainings prior to interacting with residents. There was no documentation of one hour of in-service training in control within 30 days of employment. Staff D's hire date was On at 2:20 PM, Staff B (caregiver) acknowledged that Staff D had not completed all the required staff in-service trainings within 30 days of employment. Class III	A 081			
A 161 SS=D	429.275(2) FS; 59A-36.015(2) FAC Records - Staff 429.275 (2) The administrator or owner of a facility shall maintain personnel records for each staff member which contain, at a minimum, documentation of background screening, if applicable, documentation of compliance with all training requirements of this part or applicable rule, and a copy of all licenses or certification held by each staff who performs services for which licensure or certification is required under this part or rule. 59A-36.015 (2) STAFF RECORDS.	A 161			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP		STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 161	Continued From page 6 (a) Personnel records for each staff member must contain, at a minimum, a copy of the employment application, with references furnished, and documentation verifying freedom from signs or symptoms of communicable . In addition, records must contain the following, as applicable: 1. Documentation of compliance with all staff training and continuing education required by rule 59A-36.011, F.A.C., 2. Copies of all licenses or certifications for all staff providing services that require licensing or certification, 3. Documentation of compliance with level 2 background screening for all staff subject to screening requirements as specified in section 429.174, F.S., and rule 59A-36.010, F.A.C., 4. For facilities with a licensed capacity of 17 or more residents, a copy of the job description given to each staff member pursuant to rule 59A-36.010, F.A.C., 5. Documentation verifying direct care staff and administrator participation in resident elopement drills pursuant to paragraph 59A-36.007(8)(c), F.A.C. (b) The facility is not required to maintain personnel records for staff provided by a licensed staffing agency or staff employed by an entity to provide direct or indirect services to residents and the facility. However, the facility must maintain a copy of the contract between the facility and the staffing agency or contractor as described in rule 59A-36.010, F.A.C. (c) The facility must maintain the written work schedules and staff time sheets for the most current 6 months as required by rule 59A-36.010, F.A.C. This Statute or Rule is not met as evidenced by:	A 161			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/13/2022
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SILVER PALM ALF CORP

**11271 SW 229 TERRACE
MIAMI, FL 33170**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 161	Continued From page 7 Based on record review and interview, the facility failed to maintain a copy of an employment application with references for one out of four sampled staff (Staff D). Findings included: Personnel records review for Staff D showed no documentation of an employment application including references. Staff D's hire date was _____. On _____ at 2:20 PM, Staff B (caregiver) acknowledged there was no employment application in Staff D's file. Class III	A 161		
A 200 SS=G	59A-36.025 FAC Emergency Environmental Control 59A-36.025 Emergency Environmental Control for Assisted Living Facilities. (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the assisted living facility, to ensure that current licensees of assisted living facilities will be equipped to ensure _____ air temperatures will be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power.	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 8 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is appropriate for resident care needs and life safety requirements. For planning purposes, no less than twenty (20) net square feet per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed capacity as the number of residents to be used in the facility to determine the required square footage. This may include areas that are less than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving provider for evacuees when the conditions stated in section 408.821, F.S. and subsection 59A-36.019(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained. 2. The alternate power source and fuel supply shall be located in an area(s) in accordance with local zoning and the Florida Building Code. 3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly, this rule does not limit the types of systems or equipment that may be used to achieve temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/13/2022
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SILVER PALM ALF CORP

**11271 SW 229 TERRACE
MIAMI, FL 33170**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 9 event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to operate the systems and equipment. a. An assisted living facility in an evacuation zone pursuant to chapter 252, F, S. must maintain an alternative power source and fuel as required by this subsection at all times when the assisted living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if evacuation is necessary. b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly described in the emergency power plan. c. A multistory facility, whose comprehensive emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional equipment so it can safely operate in a location protected from flooding or storm surge damage. (b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the alternate power source to maintain temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours after the loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 10 storage. 1. Facilities must store minimum amounts of fuel onsite as follows: a. A facility with a licensed capacity of 16 beds or less must store 48 hours of fuel onsite. b. A facility with a licensed capacity of 17 or more beds must store 72 hours of fuel onsite. 2. An assisted living facility located in an area in a declared state of emergency area pursuant to section 252.36, F.S. that may impact primary power delivery must secure ninety-six (96) hours of fuel. The assisted living facility may utilize portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency. 3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule. 4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living facility must develop a plan that includes maximum onsite fuel storage allowable by the ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a monoxide alarm. (2) SUBMISSION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall submit its plan to the local emergency management agency for review within 30 days of the effective date of this rule. Assisted living facility plans previously	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 11 submitted and approved pursuant to emergency Rule 58AER17-1 will require resubmission only if changes are made to the plan. (b) Each new assisted living facility shall submit the plan required under this rule prior to obtaining a license. (c) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the local emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally authorized entity. If the plan is maintained in an electronic format, assisted living facility staff must be readily available to access and produce the plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within two (2) business days of the approval of the plan from the local emergency management agency, the assisted living facility shall submit in writing proof of the approval to the Agency for Health Care Administration. (c) The assisted living facility shall submit a consumer-friendly summary of the emergency power plan to the Agency. The Agency shall post the summary and notice of the approval and implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the local emergency management agency and	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 12 update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall, no later than , have implemented the plan required under this rule. (b) The Agency shall allow an extension up to to providers in compliance with paragraph (c) below and who can show delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes. Assisted living facilities shall notify the Agency that they will utilize the extension and keep the Agency apprised of progress on a quarterly basis to ensure there are no unnecessary delays. If an assisted living facility can show in its quarterly progress reports that unavoidable delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes will occur beyond the initial extension date, the assisted living facility may request a waiver pursuant to section 120.542, F.S. (c) During the extension period, an assisted living facility must make arrangements pending full implementation of its plan that provides the residents with an area or areas to congregate that meets the safe indoor air temperature requirements of subsection (1) (a) for a minimum of ninety-six (96) hours. 1. An assisted living facility not located in an evacuation zone must either have an alternative power source onsite or have a contract in place for delivery of an alternative power source and fuel when requested. Within twenty-four (24) hours of the issuance of a state of emergency for an event that may impact primary power delivery for the area of the assisted living facility, it must	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 13 have the alternative power source and no less than ninety-six (96) hours of fuel stored onsite. 2. An assisted living facility located in an evacuation zone pursuant to chapter 252, F.S. must either: a. Fully and safely evacuate its residents prior to the arrival of the event; or b. Have an alternative power source and no less than ninety-six (96) hours of fuel stored onsite, within twenty-four (24) hours of the issuance of a state of emergency for the area of the assisted living facility. (d) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (e) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan concurrent with any such additions, modifications, alterations, refurbishment, renovations or reconstruction. (f) The Agency for Health Care Administration may request cooperation from the State Fire Marshal to conduct inspections to ensure implementation of the plan in compliance with this rule. (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can effectively and immediately activate, operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in air temperatures inside	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 14 the facility. Procedures must address the care of residents occupying the facility during a declared state of emergency, specifically, a description of the methods to be used to mitigate the potential for heat related injury including: 1. The use of cooling devices and equipment; 2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration; 3. Wellness checks by assisted living facility staff to monitor for signs of _____ and heat injury; and 4. A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy. (b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted living facility staff must be readily available to access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request. (c) The written policies and procedures must be readily available for inspection by each resident; each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by law. (6) REVOCATION OF LICENSE, FINES OR SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by chapter 429, part I, or chapter 408, part II, F.S., including, but	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP		STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 15 not limited to, license revocation, license suspension, and the imposition of administrative fines. (7) COMPREHENSIVE EMERGENCY MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION. (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon submission of the plan to the local emergency management agency that the plan has been submitted for review and approval; 2. Upon final implementation of the plan by the assisted living facility. (b) Each assisted living facility must maintain a copy of each notification set forth in paragraph (a) above in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the notifications, either in electronic or paper format, upon request. This Statute or Rule is not met as evidenced by: Based on observation, record review and interview, the facility failed to have the required fuel onsite for the operation of the alternate power	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/13/2022
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SILVER PALM ALF CORP

**11271 SW 229 TERRACE
MIAMI, FL 33170**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 16 source for at least 48 hours to maintain room temperature at or below 81 degrees in the event of a loss of primary power. Findings included: On at 9:40 AM, observation showed in the facility's backyard a dual fuel portable generator Champion 9000/7000 Watts and tanks filled with propane. A review of the generator 's manual revealed that the generator will run for 5.5 hours at 50% load when using a 20-, propane tank. The facility had of propane that would last approximately 16.5 hours. On at 2:23 PM, Staff B (caregiver) stated that she believed that had enough propane to run the generator for 48 hours and she would ask the Owner to obtain the additional fuel within the next day. Class II	A 200		
AL243 SS=D	429.075(1) FS; 59A-36.011(9) FAC LMH - Training 429.075 (1) To obtain a limited mental health license , a facility must hold a standard license as an assisted living facility, must not have any current uncorrected violations, and must ensure that, within 6 months after receiving a limited mental health license, the facility administrator and the staff of the facility who are in direct contact with mental health residents must complete training of no less than 6 hours related to their duties. This	AL243		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
AL243	Continued From page 17 designation may be made at the time of initial licensure or relicensure or upon request in writing by a licensee under this part and part II of chapter 408. Notification of approval or denial of such request shall be made in accordance with this part, part II of chapter 408, and applicable rules. This training must be provided by or approved by the Department of Children and Families. 59A-36.011 (9) LIMITED MENTAL HEALTH TRAINING. (a) Pursuant to section 429.075, F.S., the administrator, managers and staff, who have direct contact with mental health residents in a licensed limited mental health facility, must receive the following training: 1. A minimum of 6 hours of specialized training in working with individuals with mental health diagnoses. a. The training must be provided or approved by the Department of Children and Families and must be taken within 6 months of the facility's receiving a limited mental health license or within 6 months of employment in a limited mental health facility. b. Training received under this subparagraph may count once for 6 of the 12 hours of continuing education required for administrators and managers pursuant to section 429.52(5), F.S., and subsection (1) of this rule. 2. A minimum of 3 hours of continuing education, which may be provided by the ALF administrator, online, or through distance learning, biennially thereafter in subjects dealing with one or more of the following topics: a. Mental health diagnoses; and, b. Mental health treatment such as: (i) Mental health needs, services, behaviors and appropriate interventions;	AL243			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
AL243	Continued From page 18 (II) Resident progress in achieving treatment goals; (III) How to recognize changes in the resident's status or condition that may affect other services received or may require intervention; and, () Crisis services and the procedures. 3. For administrators and managers, the continuing education requirement under this subsection will satisfy 3 of the 12 hours of continuing education required biennially pursuant to section 429.52(5), F.S., and subsection (1) of this rule. 4. Administrators, managers and direct contact staff affected by the continuing education requirement under this subsection shall have up to 6 months after the effective date of this rule to meet the training requirement. (b) Administrators, managers and staff do not have to repeat the initial training should they change employers provided they present a copy of their training certificate to the current employer for retention in the facility's personnel files. They must also ensure that copies of the continuing education training certificates, pursuant to subparagraph (a)2. of this subsection, are retained in their personnel files. This Statute or Rule is not met as evidenced by: Based on record review and interview, the facility failed to ensure a minimum of 6 hours of specialized training in working with individuals with mental health diagnoses within 6 months of employment for two out of four sampled staff (the Administrator and Staff D). Findings included: Review of Florida Health Finder database	AL243			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/13/2022
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SILVER PALM ALF CORP

**11271 SW 229 TERRACE
MIAMI, FL 33170**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
AL243	Continued From page 19 revealed that the facility had a license with a limited mental health specialty component. Personnel records review for the Administrator showed no documentation that he had completed a minimum of 6 hours of specialized training in working with individuals with mental health diagnoses. The Administrator's hire date was Personnel records review for Staff D showed no documentation that the employee had completed a minimum of 6 hours of specialized training in working with individuals with mental health diagnoses. Staff D's hire date was On at 2:10 PM, Staff B (caregiver) stated that the Administrator had taken the course, but she did not know where the certificate was, however Staff D had not taken it yet. Class III	AL243		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 000	Initial Comments A biennial survey was conducted at Silver Palm ALF, Corp on . The provider had deficiencies identified at the time of the visit.	A 000			
A 054 SS=D	59A-36.008(5) FAC Medication - Records (5) MEDICATION RECORDS. (a) For residents who use a pill organizer managed in subsection (2), the facility must keep either the original labeled medication container; or a medication listing with the prescription number, the name and address of the issuing pharmacy, the health care provider's name, the resident's name, the date dispensed, the name and strength of the drug, and the directions for use. (b) The facility must maintain a daily medication observation record for each resident who receives assistance with self-administration of medications or medication administration. A medication observation record must be immediately updated each time the medication is offered or administered and include: 1. The name of the resident and any known the resident may have; 2. The name of the resident's health care provider and the health care provider's telephone number; 3. The name, strength, and directions for use of each medication; and, 4. A chart for recording each time the medication is taken, any missed dosages, refusals to take medication as prescribed, or medication errors. (c) For medications that serve as chemical , the facility must, pursuant to Section 429.41, F.S., maintain a record of the prescribing physician's annual evaluation of the use of the medication.	A 054			

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X8) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 054	Continued From page 1 This Statute or Rule is not met as evidenced by: Based on observation, record review and interview the facility failed to maintain an accurate daily medication observation record (MOR) for each resident who receives assistance with self-administration of medications or medication administration that included each time the medications were offered or administered and any known _____ the resident may have for three out of five sampled residents (Resident #1, Resident #2 and Resident #4). Findings included: 1) On _____ at 1:00 PM, observation showed during medication pass that Staff B (caregiver) assisted Resident #4 with the self-administration of medication. Further observation showed that Staff B signed the MOR before she gave the medications to the resident and prior the resident had taken the medications. 2) Review of Resident #1's MOR showed the resident had been identified as with "No Known Drug _____." Review of Resident # 1's health assessment completed _____ revealed that Resident #1 had _____ to _____ and Sulfa _____. Review of Resident #2's MOR showed that Resident #2 had been identified as with "No Known Drug _____." Further review of Resident # 2's health assessment completed _____ revealed that Resident #2 had _____ to radiographic dye and _____. On _____ at 2:20 PM, Staff B acknowledged that she signed the MOR in advance and that the	A 054			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 054	Continued From page 2 MOR did not include the residents' _____ Class III	A 054			
A 081 SS=D	429.52(1 & 7) FS; 59A-36.011() FAC Training - Staff In-Service 429.52(1) (1) Each new assisted living facility employee who has not previously completed core training must attend a preservice orientation provided by the facility before interacting with residents. The preservice orientation must be at least 2 hours in duration and cover topics that help the employee provide responsible care and respond to the needs of facility residents. Upon completion, the employee and the administrator of the facility must sign a statement that the employee completed the required preservice orientation. The facility must keep the signed statement in the employee's personnel record. (7) Facility staff shall participate in inservice training relevant to their job duties as specified by agency rule. Topics covered during the preservice orientation are not required to be repeated during inservice training. A single certificate of completion that covers all required inservice training topics may be issued to a participating staff member if the training is provided in a single training course. 59A-36.011 (2) STAFF PRESERVICE ORIENTATION. (a) Facilities must provide a preservice orientation of at least 2 hours to all new assisted living facility employees who have not previously completed core training as detailed in subsection (1).	A 081			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 081	Continued From page 3 (b) New staff must complete the preservice orientation prior to interacting with residents. (c) Once complete, the employee and the facility administrator must sign a statement that the employee completed the preservice orientation which must be kept in the employee's personnel record. (d) In addition to topics that may be chosen by the facility administrator, the preservice orientation must cover: 1. Resident's rights; and, 2. The facility's license type and services offered by the facility. (3) STAFF IN-SERVICE TRAINING. Facility administrators or managers shall provide or arrange for the following in-service training to facility staff: (a) Staff who provide direct care to residents, other than nurses, certified nursing assistants, or home health aides trained in accordance with rule 59A-8.0095, F.A.C., must receive a minimum of 1 hour in-service training in control, including universal precautions and facility sanitation procedures, before providing personal care to residents. The facility must use its control policies and procedures when offering this training. Documentation of compliance with the staff training requirements of 29 CFR 1910.1030, relating to borne , , may be used to meet this requirement. (b) Staff who provide direct care to residents must receive a minimum of 1 hour in-service training within 30 days of employment that covers the following subjects: 1. Reporting adverse incidents. 2. Facility emergency procedures including chain-of-command and staff roles relating to emergency evacuation.	A 081			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 081	Continued From page 4 (c) Staff who provide direct care to residents, who have not taken the core training program, shall receive a minimum of 1 hour in-service training within 30 days of employment that covers the following subjects: 1. Resident rights in an assisted living facility. 2. Recognizing and reporting resident neglect, and . The facility must use its prevention policies and procedures when offering this training. (d) Staff who provide direct care to residents, other than nurses, CNAs, or home health aides trained in accordance with rule 59A-8.0095, F.A.C., must receive 3 hours of in-service training within 30 days of employment that covers the following subjects: 1. Resident behavior and needs. 2. Providing assistance with the activities of daily living. (e) Staff who prepare or serve food, who have not taken the assisted living facility core training must receive a minimum of 1-hour-in-service training within 30 days of employment in safe food handling practices. (f) All facility staff shall receive in-service training regarding the facility's resident elopement response policies and procedures within thirty (30) days of employment. 1. All facility staff shall be provided with a copy of the facility's resident elopement response policies and procedures. 2. All facility staff shall demonstrate an understanding and competency in the implementation of the elopement response policies and procedures. This Statute or Rule is not met as evidenced by:	A 081			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 081	Continued From page 5 Based on record review and interview, the facility failed to ensure one out of four sampled staff had documentation of the required in-service training (Staff D). Findings included: Review of personnel record for Staff D showed no documentation of the employee having received all the pre-service trainings prior to interacting with residents. There was no documentation of one hour of in-service training in _____ control within 30 days of employment. Staff D's hire date was _____. On _____ at 2:20 PM, Staff B (caregiver) acknowledged that Staff D had not completed all the required staff in-service trainings within 30 days of employment. Class III	A 081			
A 161 SS=D	429.275(2) FS; 59A-36.015(2) FAC Records - Staff 429.275 (2) The administrator or owner of a facility shall maintain personnel records for each staff member which contain, at a minimum, documentation of background screening, if applicable, documentation of compliance with all training requirements of this part or applicable rule, and a copy of all licenses or certification held by each staff who performs services for which licensure or certification is required under this part or rule. 59A-36.015 (2) STAFF RECORDS.	A 161			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP		STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 161	Continued From page 6 (a) Personnel records for each staff member must contain, at a minimum, a copy of the employment application, with references furnished, and documentation verifying freedom from signs or symptoms of communicable . In addition, records must contain the following, as applicable: 1. Documentation of compliance with all staff training and continuing education required by rule 59A-36.011, F.A.C., 2. Copies of all licenses or certifications for all staff providing services that require licensing or certification, 3. Documentation of compliance with level 2 background screening for all staff subject to screening requirements as specified in section 429.174, F.S., and rule 59A-36.010, F.A.C., 4. For facilities with a licensed capacity of 17 or more residents, a copy of the job description given to each staff member pursuant to rule 59A-36.010, F.A.C., 5. Documentation verifying direct care staff and administrator participation in resident elopement drills pursuant to paragraph 59A-36.007(8)(c), F.A.C. (b) The facility is not required to maintain personnel records for staff provided by a licensed staffing agency or staff employed by an entity to provide direct or indirect services to residents and the facility. However, the facility must maintain a copy of the contract between the facility and the staffing agency or contractor as described in rule 59A-36.010, F.A.C. (c) The facility must maintain the written work schedules and staff time sheets for the most current 6 months as required by rule 59A-36.010, F.A.C. This Statute or Rule is not met as evidenced by:	A 161		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 161	Continued From page 7 Based on record review and interview, the facility failed to maintain a copy of an employment application with references for one out of four sampled staff (Staff D). Findings included: Personnel records review for Staff D showed no documentation of an employment application including references. Staff D's hire date was On _____ at 2:20 PM, Staff B (caregiver) acknowledged there was no employment application in Staff D's file. Class III	A 161			
A 200 SS=G	59A-36.025 FAC Emergency Environmental Control 59A-36.025 Emergency Environmental Control for Assisted Living Facilities. (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the assisted living facility, to ensure that current licensees of assisted living facilities will be equipped to ensure _____ air temperatures will be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power.	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 8 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is appropriate for resident care needs and life safety requirements. For planning purposes, no less than twenty (20) net square per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed capacity as the number of residents to be used in the to determine the required square footage. This may include areas that are less than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving provider for evacuees when the conditions stated in section 408.821, F.S. and subsection 59A-36.019(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained. 2. The alternate power source and fuel supply shall be located in an area(s) in accordance with local zoning and the Florida Building Code. 3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly, this rule does not limit the types of systems or equipment that may be used to achieve temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 9 event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to operate the systems and equipment. a. An assisted living facility in an evacuation zone pursuant to chapter 252, F. S. must maintain an alternative power source and fuel as required by this subsection at all times when the assisted living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if evacuation is necessary. b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly described in the emergency power plan. c. A multistory facility, whose comprehensive emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional equipment so it can safely operate in a location protected from flooding or storm surge damage. (b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the alternate power source to maintain temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours after the loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 10 storage. 1. Facilities must store minimum amounts of fuel onsite as follows: a. A facility with a licensed capacity of 16 beds or less must store 48 hours of fuel onsite. b. A facility with a licensed capacity of 17 or more beds must store 72 hours of fuel onsite. 2. An assisted living facility located in an area in a declared state of emergency area pursuant to section 252.36, F.S. that may impact primary power delivery must secure ninety-six (96) hours of fuel. The assisted living facility may utilize portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency. 3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule. 4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living facility must develop a plan that includes maximum onsite fuel storage allowable by the ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a monoxide alarm. (2) SUBMISSION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall submit its plan to the local emergency management agency for review within 30 days of the effective date of this rule. Assisted living facility plans previously	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 11 submitted and approved pursuant to emergency Rule 58AER17-1 will require resubmission only if changes are made to the plan. (b) Each new assisted living facility shall submit the plan required under this rule prior to obtaining a license. (c) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the local emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally authorized entity. If the plan is maintained in an electronic format, assisted living facility staff must be readily available to access and produce the plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within two (2) business days of the approval of the plan from the local emergency management agency, the assisted living facility shall submit in writing proof of the approval to the Agency for Health Care Administration. (c) The assisted living facility shall submit a consumer-friendly summary of the emergency power plan to the Agency. The Agency shall post the summary and notice of the approval and implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the local emergency management agency and	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 12 update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall, no later than , have implemented the plan required under this rule. (b) The Agency shall allow an extension up to to providers in compliance with paragraph (c) below and who can show delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes. Assisted living facilities shall notify the Agency that they will utilize the extension and keep the Agency apprised of progress on a quarterly basis to ensure there are no unnecessary delays. If an assisted living facility can show in its quarterly progress reports that unavoidable delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes will occur beyond the initial extension date, the assisted living facility may request a waiver pursuant to section 120.542, F.S. (c) During the extension period, an assisted living facility must make arrangements pending full implementation of its plan that provides the residents with an area or areas to congregate that meets the safe indoor air temperature requirements of subsection (1) (a) for a minimum of ninety-six (96) hours. 1. An assisted living facility not located in an evacuation zone must either have an alternative power source onsite or have a contract in place for delivery of an alternative power source and fuel when requested. Within twenty-four (24) hours of the issuance of a state of emergency for an event that may impact primary power delivery for the area of the assisted living facility, it must	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 13 have the alternative power source and no less than ninety-six (96) hours of fuel stored onsite. 2. An assisted living facility located in an evacuation zone pursuant to chapter 252, F.S. must either: a. Fully and safely evacuate its residents prior to the arrival of the event; or b. Have an alternative power source and no less than ninety-six (96) hours of fuel stored onsite, within twenty-four (24) hours of the issuance of a state of emergency for the area of the assisted living facility. (d) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (e) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan concurrent with any such additions, modifications, alterations, refurbishment, renovations or reconstruction. (f) The Agency for Health Care Administration may request cooperation from the State Fire Marshal to conduct inspections to ensure implementation of the plan in compliance with this rule. (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can effectively and immediately activate, operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in . . . air temperatures inside	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 14 the facility. Procedures must address the care of residents occupying the facility during a declared state of emergency, specifically, a description of the methods to be used to mitigate the potential for heat related injury including: 1. The use of cooling devices and equipment; 2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration; 3. Wellness checks by assisted living facility staff to monitor for signs of _____ and heat injury; and 4. A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy. (b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted living facility staff must be readily available to access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request. (c) The written policies and procedures must be readily available for inspection by each resident; each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by law. (6) REVOCATION OF LICENSE, FINES OR SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by chapter 429, part I, or chapter 408, part II, F.S., including, but	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 15 not limited to, license revocation, license suspension, and the imposition of administrative fines. (7) COMPREHENSIVE EMERGENCY MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION. (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon submission of the plan to the local emergency management agency that the plan has been submitted for review and approval; 2. Upon final implementation of the plan by the assisted living facility. (b) Each assisted living facility must maintain a copy of each notification set forth in paragraph (a) above in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the notifications, either in electronic or paper format, upon request. This Statute or Rule is not met as evidenced by: Based on observation, record review and interview, the facility failed to have the required fuel onsite for the operation of the alternate power	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 16 source for at least 48 hours to maintain room temperature at or below 81 degrees in the event of a loss of primary power. Findings included: On at 9:40 AM, observation showed in the facility's backyard a dual fuel portable generator Champion 9000/7000 Watts and , tanks filled with propane. A review of the generator 's manual revealed that the generator will run for 5.5 hours at 50% load when using a 20-, propane tank. The facility had of propane that would last approximately 16.5 hours. On at 2:23 PM, Staff B (caregiver) stated that she believed that had enough propane to run the generator for 48 hours and she would ask the Owner to obtain the additional fuel within the next day. Class II	A 200			
AL243 SS=D	429.075(1) FS; 59A-36.011(9) FAC LMH - Training 429.075 (1) To obtain a limited mental health license, a facility must hold a standard license as an assisted living facility, must not have any current uncorrected violations, and must ensure that, within 6 months after receiving a limited mental health license, the facility administrator and the staff of the facility who are in direct contact with mental health residents must complete training of no less than 6 hours related to their duties. This	AL243			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
AL243	Continued From page 17 designation may be made at the time of initial licensure or relicensure or upon request in writing by a licensee under this part and part II of chapter 408. Notification of approval or denial of such request shall be made in accordance with this part, part II of chapter 408, and applicable rules. This training must be provided by or approved by the Department of Children and Families. 59A-36.011 (9) LIMITED MENTAL HEALTH TRAINING. (a) Pursuant to section 429.075, F.S., the administrator, managers and staff, who have direct contact with mental health residents in a licensed limited mental health facility, must receive the following training: 1. A minimum of 6 hours of specialized training in working with individuals with mental health diagnoses. a. The training must be provided or approved by the Department of Children and Families and must be taken within 6 months of the facility's receiving a limited mental health license or within 6 months of employment in a limited mental health facility. b. Training received under this subparagraph may count once for 6 of the 12 hours of continuing education required for administrators and managers pursuant to section 429.52(5), F.S., and subsection (1) of this rule. 2. A minimum of 3 hours of continuing education, which may be provided by the ALF administrator, online, or through distance learning, biennially thereafter in subjects dealing with one or more of the following topics: a. Mental health diagnoses; and, b. Mental health treatment such as: (I) Mental health needs, services, behaviors and appropriate interventions;	AL243			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
AL243	Continued From page 18 (II) Resident progress in achieving treatment goals; (III) How to recognize changes in the resident's status or condition that may affect other services received or may require intervention; and, () Crisis services and the procedures. 3. For administrators and managers, the continuing education requirement under this subsection will satisfy 3 of the 12 hours of continuing education required biennially pursuant to section 429.52(5), F.S., and subsection (1) of this rule. 4. Administrators, managers and direct contact staff affected by the continuing education requirement under this subsection shall have up to 6 months after the effective date of this rule to meet the training requirement. (b) Administrators, managers and staff do not have to repeat the initial training should they change employers provided they present a copy of their training certificate to the current employer for retention in the facility's personnel files. They must also ensure that copies of the continuing education training certificates, pursuant to subparagraph (a)2. of this subsection, are retained in their personnel files. This Statute or Rule is not met as evidenced by: Based on record review and interview, the facility failed to ensure a minimum of 6 hours of specialized training in working with individuals with mental health diagnoses within 6 months of employment for two out of four sampled staff (the Administrator and Staff D). Findings included: Review of Florida Health Finder database	AL243			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966977	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 09/13/2022
NAME OF PROVIDER OR SUPPLIER SILVER PALM ALF CORP			STREET ADDRESS, CITY, STATE, ZIP CODE 11271 SW 229 TERRACE MIAMI, FL 33170		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
AL243	Continued From page 19 revealed that the facility had a license with a limited mental health specialty component. Personnel records review for the Administrator showed no documentation that he had completed a minimum of 6 hours of specialized training in working with individuals with mental health diagnoses. The Administrator's hire date was Personnel records review for Staff D showed no documentation that the employee had completed a minimum of 6 hours of specialized training in working with individuals with mental health diagnoses. Staff D's hire date was On at 2:10 PM, Staff B (caregiver) stated that the Administrator had taken the course, but she did not know where the certificate was, however Staff D had not taken it yet. Class III	AL243			