

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967824	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/26/2022
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

ALFONSO'S ALF INC

**17010 SW 100 AVENUE
MIAMI, FL 33157**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 000	Initial Comments A Generator monitoring was conducted at Alfonso's ALF Inc. on 09/26/2022. A deficiency was identified at the time of survey.	A 000		
A 182 SS=I	59A-36.019(3) FAC Emergency Mgmt - Plan Implementation (3) PLAN IMPLEMENTATION. (a) All staff must be trained in their duties and are responsible for implementing the emergency management plan. (b) If telephone service is not available during an emergency, the facility must request assistance from local law enforcement or emergency management personnel in maintaining communication. This Statute or Rule is not met as evidenced by: Based on interview and observation the facility was unable to implement the emergency management plan. Findings as follow: On 09/26/2022 at 9:30 AM when Staff present in facility was requested to start the generator she stated "The generator is not working, a technician make some work on it but it didn't start, the Administrator stated was going to buy a new one". On 09/26/2022 at 9:32 AM the Administrator stated "the technician was in the facility a week earlier for maintenance and generator did not start so I decided to buy a new one today". On 09/26/2022 at 9:35 AM, observed in a storage room in the patio secured with a chain and a lock, a portable generator Predator 3200 running	A 182		

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967824	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/26/2022
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

ALFONSO'S ALF INC

**17010 SW 100 AVENUE
MIAMI, FL 33157**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 182	Continued From page 1 watts/4000 peak watts. Class II	A 182		