

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 01/11/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SENIORS RESIDENCE ACLF

**11334 SW 2 STREET
MIAMI, FL 33174**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
CZ816	408.809(2) 435.05(2) 59A-35.090(2d-3b) Background Screening-Compliance Attestation 408.809 Background screening; prohibited offenses.- (2) Every 5 years following his or her licensure, employment, or entry into a contract in a capacity that under subsection (1) would require level 2 background screening under chapter 435, each such person must submit to level 2 background rescreening as a condition of retaining such license or continuing in such employment or contractual status. For any such rescreening, the agency shall request the Department of Law Enforcement to forward the person's _____ to the Federal Bureau of Investigation for a national criminal history record check unless the person's _____ are enrolled in the Federal Bureau of Investigation's national retained print _____ notification program. If the _____ of such a person are not retained by the Department of Law Enforcement under s. 943.05(2)(g) and (h), the person must submit _____ electronically to the Department of Law Enforcement for state processing, and the Department of Law Enforcement shall forward the _____ to the Federal Bureau of Investigation for a national criminal history record check. The _____ shall be retained by the Department of Law Enforcement under s. 943.05(2)(g) and (h) and enrolled in the national retained print _____ notification program when the Department of Law Enforcement begins participation in the program. The cost of the state and national criminal history records checks required by level 2 screening may be borne by the licensee or the person _____. The agency may accept as satisfying the requirements of this section proof of compliance with level 2 screening standards submitted within the previous 5 years to meet any provider or	CZ816		

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 01/11/2023
NAME OF PROVIDER OR SUPPLIER SENIORS RESIDENCE ACLF			STREET ADDRESS, CITY, STATE, ZIP CODE 11334 SW 2 STREET MIAMI, FL 33174		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
CZ816	Continued From page 1 professional licensure requirements of the Department of Financial Services for an applicant for a certificate of authority or provisional certificate of authority to operate a continuing care retirement community under chapter 651, provided that: (a) The screening standards and disqualifying offenses for the prior screening are equivalent to those specified in s. 435.04 and this section; (b) The person subject to screening has not had a break in service from a position that requires level 2 screening for more than 90 days; and (c) Such proof is accompanied, under penalty of perjury, by an attestation of compliance with chapter 435 and this section using forms provided by the agency. 435.05 Requirements for covered employees and employers.-Except as otherwise provided by law, the following requirements apply to covered employees and employers: (2) Every employee must attest, subject to penalty of perjury, to meeting the requirements for qualifying for employment pursuant to this chapter and agreeing to inform the employer immediately if _____ for any of the disqualifying offenses while employed by the employer. 59A-35.090 Background Screening. (2) Processing Screening Requests, Required Documents and Fees. (d) An Attestation of Compliance with Background Screening Requirements, AHCA Form 3100-0008, _____, herein incorporated by reference, available at http://www.flrules.org/Gateway/reference.asp?No=Ref-09106, and available from the Agency for Health Care Administration at: http://ahca.myflorida.com/MCHQ/Central_Service	CZ816			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 01/11/2023
NAME OF PROVIDER OR SUPPLIER SENIORS RESIDENCE ACLF			STREET ADDRESS, CITY, STATE, ZIP CODE 11334 SW 2 STREET MIAMI, FL 33174		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
CZ816	Continued From page 2 s/Background_Screening/Regulations_Forms.sht ml. This form must be completed by the individual and retained by the provider upon hire to attest that they meet the requirements for qualifying for employment, they have not been unemployed for more than 90 days from a position that requires Level 2 screening, and they agree to inform the employer immediately if _____ for any disqualifying offense. (e) An administrator or chief financial officer must be screened and qualified prior to _____ to the position. (3) Results of Screening and Notification. (a) Final results of background screening requests will be provided through the Agency's secure website that may be accessed by all health care providers applying for or actively licensed through the Agency that are registered with the Care Provider Background Screening Clearinghouse. The secure website is located at: apps.ahca.myflorida.com/SingleSignOnPortal. (b) If a Level 2 criminal history is incomplete, a certified letter will be sent to the individual being screened requesting the _____ report and court disposition information. If the letter is returned unclaimed, a copy of the letter will be sent by regular mail. Pursuant to Section 435.05(1)(d), F.S., the missing information must be filed with the Agency within 30 days of the Agency's request or the individual is subject to disqualification in accordance with Section 435.06(3), F.S. This Statute or Rule is not met as evidenced by: Based on record review and interview the facility failed to ensure staff had a signed Attestation of Compliance form for one of five (Staff B) sampled staff.	CZ816			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 01/11/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SENIORS RESIDENCE ACLF

**11334 SW 2 STREET
MIAMI, FL 33174**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
CZ816	Continued From page 3 Findings Included: A review of Staff B's record showed a hired date for . There was no signed Attestation of Compliance document in file. In an interview with the Administrator on at 2:51 pm, he stated, "I thought the staff attestation form was in file . Class III	CZ816		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 01/11/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SENIORS RESIDENCE ACLF

**11334 SW 2 STREET
MIAMI, FL 33174**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 000	Initial Comments A relicensure survey was conducted at Seniors Residences ACLF on Deficiencies were identified at the time of the visit.	A 000		
A 079 SS=E	59A-36.010(3) FAC Staffing Standards - Levels (3) STAFFING STANDARDS. (a) Minimum staffing: 1. Facilities must maintain the following minimum staff hours per week: Number of Residents, Day Care Participants, and Respite Care Residents Staff Hours/Week 0-5 168 212 16-25 253 26-35 294 36-45 335 46-55 375 56-65 416 66-75 457 76-85 498 86-95 539 For every 20 total combined residents, day care participants, and respite care residents over 95 add 42 staff hours per week. 2. Independent living residents, as referenced in subsection 59A-36.015(3), F.A.C., who occupy beds included within the licensed capacity of an assisted living facility but do not receive personal, limited nursing, or extended congregate care services, are not counted as residents for purposes of computing minimum staff hours. 3. At least one staff member who has access to facility and resident records in case of an emergency must be in the facility at all times when residents are in the facility. Residents	A 079		

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 01/11/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SENIORS RESIDENCE ACLF

**11334 SW 2 STREET
MIAMI, FL 33174**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 079	Continued From page 1 serving as paid or volunteer staff may not be left solely in charge of other residents while the facility administrator, manager or other staff are absent from the facility. 4. In facilities with 17 or more residents, there must be at least one staff member awake at all hours of the day and night. 5. A staff member who has completed courses in First Aid and _____ () and holds a currently valid card documenting completion of such courses must be in the facility at all times. a. Documentation of attendance at First Aid or courses pursuant to subsection 59A-36.011(5), F.A.C., satisfies this requirement. b. A nurse is considered as having met the course requirements for First Aid. An emergency medical technician or paramedic currently certified under chapter 401, part III, F.S., is considered as having met the course requirements for both First Aid and _____. 6. During periods of temporary absence of the administrator or manager of more than 48 hours when residents are on the premises, a staff member who is at least _____ must be physically present and designated in writing to be in charge of the facility. No staff member shall be in charge of a facility for a consecutive period of 21 days or more, or for a total of 60 days within a calendar year, without being an administrator or manager. 7. Staff whose duties are exclusively building or grounds maintenance, clerical, or food preparation do not count towards meeting the minimum staffing hours requirement. 8. The administrator or manager's time may be counted for the purpose of meeting the required staffing hours, provided the administrator or manager is actively involved in the day-to-day	A 079		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 01/11/2023
NAME OF PROVIDER OR SUPPLIER SENIORS RESIDENCE ACLF			STREET ADDRESS, CITY, STATE, ZIP CODE 11334 SW 2 STREET MIAMI, FL 33174		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 079	Continued From page 2 operation of the facility, including making decisions and providing supervision for all aspects of resident care, and is listed on the facility's staffing schedule. 9. Only on-the-job staff may be counted in meeting the minimum staffing hours. Vacant positions or absent staff may not be counted. (b) Notwithstanding the minimum staffing requirements specified in paragraph (a), all facilities, including those composed of apartments, must have enough qualified staff to provide resident supervision, and to provide or arrange for resident services in accordance with the residents' scheduled and unscheduled service needs, resident contracts, and resident care standards as described in rule 59A-36.007, F.A.C. (c) The facility must maintain a written work schedule that reflects its 24-hour staffing pattern for a given time period. Upon request, the facility must make the daily work schedules of direct care staff available to residents or their representatives. (d) The facility must provide staff immediately when the agency determines that the requirements of paragraph (a) are not met. The facility must immediately increase staff above the minimum levels established in paragraph (a), if the agency determines that adequate supervision and care are not being provided to residents, resident care standards described in rule 59A-36.007, F.A.C., are not being met, or that the facility is failing to meet the terms of residents' contracts. The agency will consult with the facility administrator and residents regarding any determination that additional staff is required. Based on the recommendations of the local fire safety authority, the agency may require additional staff when the facility fails to meet the	A 079			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 01/11/2023
NAME OF PROVIDER OR SUPPLIER SENIORS RESIDENCE ACLF			STREET ADDRESS, CITY, STATE, ZIP CODE 11334 SW 2 STREET MIAMI, FL 33174		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 079	Continued From page 3 fire safety standards described in rule chapter 69A-40, F.A.C., until such time as the local fire safety authority informs the agency that fire safety requirements are being met. 1. When additional staff is required above the minimum, the agency will require the submission of a corrective action plan within the time specified in the notification indicating how the increased staffing is to be achieved to meet resident service needs. The plan will be reviewed by the agency to determine if it sufficiently increases the staffing levels to meet resident needs. 2. When the facility can demonstrate to the agency that resident needs are being met, or that resident needs can be met without increased staffing, the agency may modify staffing requirements for the facility and the facility will no longer be required to maintain a plan with the agency. (e) Facilities that are co-located with a nursing home may use shared staffing provided that staff hours are only counted once for the purpose of meeting either assisted living facility or nursing home minimum staffing ratios. (f) Facilities holding a limited mental health, extended congregate care, or limited nursing services license must also comply with the staffing requirements of rules 59A-36.020, 59A-36.021 or 59A-36.022, F.A.C., respectively. This Statute or Rule is not met as evidenced by: Based on observation, record review, and interview, the facility failed to maintain a written work schedule that reflects its 24 hour staffing pattern for a given period. Findings Included:	A 079			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 01/11/2023
NAME OF PROVIDER OR SUPPLIER SENIORS RESIDENCE ACLF			STREET ADDRESS, CITY, STATE, ZIP CODE 11334 SW 2 STREET MIAMI, FL 33174		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 079	Continued From page 4 On at 10:42 am, observed Staff D working alone with eight residents. Staff D stated she and the Administrator were scheduled to work and the Administrator left to go grocery shopping and would return shortly. On at 11:19 am, observed the Administrator arrived at the facility. The Administrator stated he was scheduled to work but he went to the grocery store to pick up some items. A review of the facility's staffing schedule dated for showed Staff C, Staff D, and Staff E was scheduled to work from 7 am-7 pm. In an interview with Staff D on at 10:55 am, she stated Staff E was out of the country at the time of the visit, and Staff B and Staff C were out sick. Class III	A 079			
A 081 SS=E	429.52(1 & 7) FS; 59A-36.011() FAC Training - Staff In-Service 429.52(1) (1) Each new assisted living facility employee who has not previously completed core training must attend a preservice orientation provided by the facility before interacting with residents. The preservice orientation must be at least 2 hours in duration and cover topics that help the employee provide responsible care and respond to the needs of facility residents. Upon completion, the employee and the administrator of the facility must sign a statement that the employee completed the required preservice orientation. The facility must keep the signed statement in the	A 081			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 01/11/2023
NAME OF PROVIDER OR SUPPLIER SENIORS RESIDENCE ACLF			STREET ADDRESS, CITY, STATE, ZIP CODE 11334 SW 2 STREET MIAMI, FL 33174		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 081	Continued From page 5 employee's personnel record. (7) Facility staff shall participate in inservice training relevant to their job duties as specified by agency rule. Topics covered during the preservice orientation are not required to be repeated during inservice training. A single certificate of completion that covers all required inservice training topics may be issued to a participating staff member if the training is provided in a single training course. 59A-36.011 (2) STAFF PRESERVICE ORIENTATION. (a) Facilities must provide a preservice orientation of at least 2 hours to all new assisted living facility employees who have not previously completed core training as detailed in subsection (1). (b) New staff must complete the preservice orientation prior to interacting with residents. (c) Once complete, the employee and the facility administrator must sign a statement that the employee completed the preservice orientation which must be kept in the employee's personnel record. (d) In addition to topics that may be chosen by the facility administrator, the preservice orientation must cover: 1. Resident's rights; and, 2. The facility's license type and services offered by the facility. (3) STAFF IN-SERVICE TRAINING. Facility administrators or managers shall provide or arrange for the following in-service training to facility staff: (a) Staff who provide direct care to residents, other than nurses, certified nursing assistants, or home health aides trained in accordance with rule	A 081			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 01/11/2023
NAME OF PROVIDER OR SUPPLIER SENIORS RESIDENCE ACLF			STREET ADDRESS, CITY, STATE, ZIP CODE 11334 SW 2 STREET MIAMI, FL 33174		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 081	Continued From page 6 59A-8.0095, F.A.C., must receive a minimum of 1 hour in-service training in control, including universal precautions and facility sanitation procedures, before providing personal care to residents. The facility must use its control policies and procedures when offering this training. Documentation of compliance with the staff training requirements of 29 CFR 1910.1030, relating to blood borne pathogens, may be used to meet this requirement. (b) Staff who provide direct care to residents must receive a minimum of 1 hour in-service training within 30 days of employment that covers the following subjects: 1. Reporting adverse incidents. 2. Facility emergency procedures including chain-of-command and staff roles relating to emergency evacuation. (c) Staff who provide direct care to residents, who have not taken the core training program, shall receive a minimum of 1 hour in-service training within 30 days of employment that covers the following subjects: 1. Resident rights in an assisted living facility. 2. Recognizing and reporting resident neglect, and abuse. The facility must use its prevention policies and procedures when offering this training. (d) Staff who provide direct care to residents, other than nurses, CNAs, or home health aides trained in accordance with rule 59A-8.0095, F.A.C., must receive 3 hours of in-service training within 30 days of employment that covers the following subjects: 1. Resident behavior and needs. 2. Providing assistance with the activities of daily living. (e) Staff who prepare or serve food, who have not	A 081			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 01/11/2023
NAME OF PROVIDER OR SUPPLIER SENIORS RESIDENCE ACLF			STREET ADDRESS, CITY, STATE, ZIP CODE 11334 SW 2 STREET MIAMI, FL 33174		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 081	Continued From page 7 taken the assisted living facility core training must receive a minimum of 1-hour-in-service training within 30 days of employment in safe food handling practices. (f) All facility staff shall receive in-service training regarding the facility's resident elopement response policies and procedures within thirty (30) days of employment. 1. All facility staff shall be provided with a copy of the facility's resident elopement response policies and procedures. 2. All facility staff shall demonstrate an understanding and competency in the implementation of the elopement response policies and procedures. This Statute or Rule is not met as evidenced by: Based on observation, record review, and interview, the facility failed to ensure that two out of four sampled Staff (Staff C and Staff D) had at least 2 hours of preservice orientation prior to interacting with residents. Findings Included: On at 10:42 am, observed Staff D working alone with eight residents. A review of Staff C's record showed Staff C was hired on There was no documentation of 2 hours of pre-service orientation training prior to interacting with the residents in file. A review of Staff D's record showed Staff D was hired on There was no documentation of 2 hours of pre-service	A 081			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 01/11/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SENIORS RESIDENCE ACLF

**11334 SW 2 STREET
MIAMI, FL 33174**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 081	Continued From page 8 orientation training prior to interacting with the residents in file. In an interview with the Administrator on _____ at 2:55 pm, he stated he thought the staff members' pre-service training was in the file. Class III	A 081		
A 200 SS=G	59A-36.025 FAC Emergency Environmental Control 59A-36.025 Emergency Environmental Control for Assisted Living Facilities. (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the assisted living facility, to ensure that current licensees of assisted living facilities will be equipped to ensure _____ air temperatures will be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is appropriate for resident care needs and life safety requirements. For planning purposes, no less than twenty (20) net square _____ per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 01/11/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SENIORS RESIDENCE ACLF

**11334 SW 2 STREET
MIAMI, FL 33174**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 9 capacity as the number of residents to be used in the _____ to determine the required square footage. This may include areas that are less than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving provider for evacuees when the conditions stated in section 408.821, F.S. and subsection 59A-36.019(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained. 2. The alternate power source and fuel supply shall be located in an area(s) in accordance with local zoning and the Florida Building Code. 3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly, this rule does not limit the types of systems or equipment that may be used to achieve temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to operate the systems and equipment. a. An assisted living facility in an evacuation zone pursuant to chapter 252, F. S. must maintain an alternative power source and fuel as required by this subsection at all times when the assisted	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 01/11/2023
NAME OF PROVIDER OR SUPPLIER SENIORS RESIDENCE ACLF			STREET ADDRESS, CITY, STATE, ZIP CODE 11334 SW 2 STREET MIAMI, FL 33174		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 10 living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if evacuation is necessary. b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly described in the emergency power plan. c. A multistory facility, whose comprehensive emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional equipment so it can safely operate in a location protected from flooding or storm surge damage. (b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the alternate power source to maintain temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours after the loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel storage. 1. Facilities must store minimum amounts of fuel onsite as follows: a. A facility with a licensed capacity of 16 beds or less must store 48 hours of fuel onsite. b. A facility with a licensed capacity of 17 or more beds must store 72 hours of fuel onsite. 2. An assisted living facility located in an area in a declared state of emergency area pursuant to	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 01/11/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SENIORS RESIDENCE ACLF

**11334 SW 2 STREET
MIAMI, FL 33174**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 11 section 252.36, F.S. that may impact primary power delivery must secure ninety-six (96) hours of fuel. The assisted living facility may utilize portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency. 3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule. 4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living facility must develop a plan that includes maximum onsite fuel storage allowable by the ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a monoxide alarm. (2) SUBMISSION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall submit its plan to the local emergency management agency for review within 30 days of the effective date of this rule. Assisted living facility plans previously submitted and approved pursuant to emergency Rule 58AER17-1 will require resubmission only if changes are made to the plan. (b) Each new assisted living facility shall submit the plan required under this rule prior to obtaining a license. (c) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 01/11/2023
NAME OF PROVIDER OR SUPPLIER SENIORS RESIDENCE ACLF			STREET ADDRESS, CITY, STATE, ZIP CODE 11334 SW 2 STREET MIAMI, FL 33174		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 12 reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the local emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally authorized entity. If the plan is maintained in an electronic format, assisted living facility staff must be readily available to access and produce the plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within two (2) business days of the approval of the plan from the local emergency management agency, the assisted living facility shall submit in writing proof of the approval to the Agency for Health Care Administration. (c) The assisted living facility shall submit a consumer-friendly summary of the emergency power plan to the Agency. The Agency shall post the summary and notice of the approval and implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the local emergency management agency and update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall, no later than _____, have implemented the plan required under this rule. (b) The Agency shall allow an extension up to _____ to providers in compliance with	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 01/11/2023
NAME OF PROVIDER OR SUPPLIER SENIORS RESIDENCE ACLF			STREET ADDRESS, CITY, STATE, ZIP CODE 11334 SW 2 STREET MIAMI, FL 33174		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 13 paragraph (c) below and who can show delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes. Assisted living facilities shall notify the Agency that they will utilize the extension and keep the Agency apprised of progress on a quarterly basis to ensure there are no unnecessary delays. If an assisted living facility can show in its quarterly progress reports that unavoidable delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes will occur beyond the initial extension date, the assisted living facility may request a waiver pursuant to section 120.542, F.S. (c) During the extension period, an assisted living facility must make arrangements pending full implementation of its plan that provides the residents with an area or areas to congregate that meets the safe indoor air temperature requirements of subsection (1) (a) for a minimum of ninety-six (96) hours. 1. An assisted living facility not located in an evacuation zone must either have an alternative power source onsite or have a contract in place for delivery of an alternative power source and fuel when requested. Within twenty-four (24) hours of the issuance of a state of emergency for an event that may impact primary power delivery for the area of the assisted living facility, it must have the alternative power source and no less than ninety-six (96) hours of fuel stored onsite. 2. An assisted living facility located in an evacuation zone pursuant to chapter 252, F.S. must either: a. Fully and safely evacuate its residents prior to the arrival of the event; or b. Have an alternative power source and no less than ninety-six (96) hours of fuel stored onsite,	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 01/11/2023
NAME OF PROVIDER OR SUPPLIER SENIORS RESIDENCE ACLF			STREET ADDRESS, CITY, STATE, ZIP CODE 11334 SW 2 STREET MIAMI, FL 33174		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 14 within twenty-four (24) hours of the issuance of a state of emergency for the area of the assisted living facility. (d) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (e) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan concurrent with any such additions, modifications, alterations, refurbishment, renovations or reconstruction. (f) The Agency for Health Care Administration may request cooperation from the State Fire Marshal to conduct inspections to ensure implementation of the plan in compliance with this rule. (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can effectively and immediately activate, operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in air temperatures inside the facility. Procedures must address the care of residents occupying the facility during a declared state of emergency, specifically, a description of the methods to be used to mitigate the potential for heat related injury including: 1. The use of cooling devices and equipment; 2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration;	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 01/11/2023
NAME OF PROVIDER OR SUPPLIER SENIORS RESIDENCE ACLF			STREET ADDRESS, CITY, STATE, ZIP CODE 11334 SW 2 STREET MIAMI, FL 33174		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 15 3. Wellness checks by assisted living facility staff to monitor for signs of _____ and heat injury; and 4. A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy. (b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted living facility staff must be readily available to access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request. (c) The written policies and procedures must be readily available for inspection by each resident; each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by law. (6) REVOCATION OF LICENSE, FINES OR SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by chapter 429, part I, or chapter 408, part II, F.S., including, but not limited to, license revocation, license suspension, and the imposition of administrative fines. (7) COMPREHENSIVE EMERGENCY MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 01/11/2023
NAME OF PROVIDER OR SUPPLIER SENIORS RESIDENCE ACLF			STREET ADDRESS, CITY, STATE, ZIP CODE 11334 SW 2 STREET MIAMI, FL 33174		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 16 shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION. (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon submission of the plan to the local emergency management agency that the plan has been submitted for review and approval; 2. Upon final implementation of the plan by the assisted living facility. (b) Each assisted living facility must maintain a copy of each notification set forth in paragraph (a) above in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the notifications, either in electronic or paper format, upon request. This Statute or Rule is not met as evidenced by: Based on observation, record review, and interview, the facility failed to store the minimum amounts of fuel onsite to ensure that in the event of the loss of primary electrical power, there is sufficient fuel available for the alternate power source to maintain temperatures at or below 81 degrees Fahrenheit. The facility is license for 14 beds and require 48 hours of fuel to be stored onsite. Findings Included:	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11942885	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 01/11/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

SENIORS RESIDENCE ACLF

**11334 SW 2 STREET
MIAMI, FL 33174**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 17 On 01/11/2023 at 2:40 pm, observed a portable generator (Duramax EXP 1000EH) in the backyard. Observed (1) 5 gallon of fuel and three empty 5- gallon fuel containers in the backyard. A review of the portable generator (Duramax EXP Hybrid)'s manual showed the portable generator used 8 gallons of gas to power the generator for 10 hours. The facility had enough gas to fill the generator for approximately 7 hours. The facility needed 36 gallons of gas to power the generator for 48 hours. In an interview with the Administrator on 01/11/2023 at 2:45 pm, he stated, " the fire department doesn't want us to have a lot of gas stored around the facility because gas is flammable." Review of the facility records showed there was no documentation that the fire department informed the facility of how much fuel is allowed to be stored at the facility. Class II	A 200		