

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969833	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 02/16/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

NINA'S HOUSE ALF

**2312 W POWHATAN AVE
TAMPA, FL 33603**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
CZ841 SS=D	408.823() FS In-person Visitation (1) This section applies to _____ centers as defined in s. 393.063, hospitals licensed under chapter 395, nursing home facilities licensed under part II of chapter 400, hospice facilities licensed under part _____ of chapter 400, intermediate care facilities for the _____ licensed and certified under part VIII of chapter 400, and assisted living facilities licensed under part I of chapter 429. (2)(a) No later than 30 days after the effective date of this act, each provider shall establish visitation policies and procedures. The policies and procedures must, at a minimum, include _____ control and education policies for visitors; screening, personal protective equipment, and other _____ control protocols for visitors; permissible length of visits and numbers of visitors, which must meet or exceed the standards in ss. 400.022(1)(b) and 429.28(1)(d), as applicable; and designation of a person responsible for ensuring that staff adhere to the policies and procedures. Safety-related policies and procedures may not be more stringent than those established for the provider's staff and may not require visitors to submit proof of any _____ or immunization. The policies and procedures must allow consensual physical contact between a resident, client, or patient and the visitor. (b) A resident, client, or patient may designate a visitor who is a family member, friend, guardian, or other individual as an essential caregiver. The provider must allow in-person visitation by the essential caregiver for at least 2 hours daily in addition to any other visitation authorized by the provider. This section does not require an essential caregiver to provide necessary care to a resident, client, or patient of a provider, and	CZ841		

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969833	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 02/16/2023
NAME OF PROVIDER OR SUPPLIER NINA'S HOUSE ALF			STREET ADDRESS, CITY, STATE, ZIP CODE 2312 W POWHATAN AVE TAMPA, FL 33603		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
CZ841	Continued From page 1 providers may not require an essential caregiver to provide such care. (c) The visitation policies and procedures required by this section must allow in-person visitation in all of the following circumstances, unless the resident, client, or patient objects: 1. End-of-life situations. 2. A resident, client, or patient who was living with family before being admitted to the provider's care is struggling with the change in environment and lack of in-person family support. 3. The resident, client, or patient is making one or more major medical decisions. 4. A resident, client, or patient is experiencing emotional distress or grieving the loss of a friend or family member who recently . 5. A resident, client, or patient needs cueing or encouragement to eat or drink which was previously provided by a family member or caregiver. 6. A resident, client, or patient who used to talk and interact with others is seldom speaking. 7. For hospitals, childbirth, including labor and delivery. 8. patients. (d) The policies and procedures may require a visitor to agree in writing to follow the provider's policies and procedures. A provider may suspend in-person visitation of a specific visitor if the visitor violates the provider's policies and procedures. (e) The providers shall provide their visitation policies and procedures to the agency when applying for initial licensure, licensure renewal, or change of ownership. The provider must make the visitation policies and procedures available to the agency for review at any time, upon request. (f) Within 24 hours after establishing the policies and procedures required under this section,	CZ841			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969833	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 02/16/2023
NAME OF PROVIDER OR SUPPLIER NINA'S HOUSE ALF			STREET ADDRESS, CITY, STATE, ZIP CODE 2312 W POWHATAN AVE TAMPA, FL 33603		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
CZ841	Continued From page 2 providers must make such policies and procedures easily accessible from the homepage of their websites. This Statute or Rule is not met as evidenced by: Based on record review and interview, the facility did not establish visitation policies and procedures that would address control measures and allow in-person visitation. Findings Included: A record review of the facility's visitation policy and procedures conducted on revealed the policy did not the new requirements. In an interview with the Owner conducted at 11:35pm on , she stated she was not aware of the new visitation policy and procedures requirements that came out in . Class III	CZ841			
A 000	Initial Comments A re-licensure survey was conducted at the Nina's House ALF on . Deficiencies were identified at the time of the survey.	A 000			
A 078 SS=D	59A-36.010(2) FAC Staffing Standards - Staff (2) STAFF. (a) Within 30 days after beginning employment, newly hired staff must submit a written statement from a health care provider documenting that the individual does not have any signs or symptoms of communicable . The examination performed by the health care provider must have	A 078			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969833	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 02/16/2023
NAME OF PROVIDER OR SUPPLIER NINA'S HOUSE ALF			STREET ADDRESS, CITY, STATE, ZIP CODE 2312 W POWHATAN AVE TAMPA, FL 33603		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 078	Continued From page 3 been conducted no earlier than 6 months before submission of the statement. Newly hired staff does not include an employee transferring without a break in service from one facility to another when the facility is under the same management or ownership. 1. Evidence of a negative examination must be documented on an annual basis. Documentation provided by the Florida Department of Health or a licensed health care provider certifying that there is a shortage of testing materials satisfies the annual examination requirement. An individual with a positive test must submit a health care provider's statement that the individual does not constitute a risk of 2. If any staff member has, or is suspected of having, a communicable , such individual must be immediately removed from duties until a written statement is submitted from a health care provider indicating that the individual does not constitute a risk of transmitting a communicable (b) Staff must be qualified to perform their assigned duties consistent with their level of education, training, preparation, and experience. Staff providing services requiring licensing or certification must be appropriately licensed or certified. All staff must exercise their responsibilities, consistent with their qualifications, to observe residents, to document observations on the appropriate resident's record, and to report the observations to the resident's health care provider in accordance with this rule chapter. (c) All staff must comply with the training requirements of rule 59A-36.011, F.A.C. (d) An assisted living facility to	A 078			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969833	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 02/16/2023
NAME OF PROVIDER OR SUPPLIER NINA'S HOUSE ALF		STREET ADDRESS, CITY, STATE, ZIP CODE 2312 W POWHATAN AVE TAMPA, FL 33603		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 078	Continued From page 4 provide services to residents must ensure that individuals providing services are qualified to perform their assigned duties in accordance with this rule chapter. The contract between the facility and the staffing agency or contractor must specifically describe the services the staffing agency or contractor will provide to residents. (e) For facilities with a licensed capacity of 17 or more residents, the facility must: 1. Develop a written job description for each staff position and provide a copy of the job description to each staff member; and, 2. Maintain time sheets for all staff. (f) Level 2 background screening must be conducted for staff, including staff _____ by the facility to provide services to residents, pursuant to sections 408.809 and 429.174, F.S. This Statute or Rule is not met as evidenced by: Based on record review and interview, the facility failed to ensure that all staff provided documented evidence of a negative examination, on an annual basis, for 1 (Owner) of 1 staff member whose records were reviewed. Findings Included: A review of the Owner's record conducted on _____, revealed the latest _____ screening was dated _____. In an interview with the Owner, conducted at 11:10am on _____, she stated she needed to go to doctor to get the _____ statement. Class III	A 078		
A 180 SS=D	59A-36.019(1) FAC Emergency Management	A 180		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969833	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 02/16/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

NINA'S HOUSE ALF

**2312 W POWHATAN AVE
TAMPA, FL 33603**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 180	Continued From page 5 (1) EMERGENCY PLAN COMPONENTS. Pursuant to Section 429.41, F.S., each facility must prepare a written comprehensive emergency management plan in accordance with the "Emergency Management Criteria for Assisted Living Facilities," dated _____, which is incorporated by reference and available at http://www.flrules.org/Gateway/reference.asp?No=Ref-04010 . This document is available from the local emergency management agency. The emergency management plan must, at a minimum, address the following: (a) Provision for all hazards; (b) Provision for the care of residents remaining in the facility during an emergency, including pre-disaster or emergency preparation; protecting the facility; supplies; emergency power; food and water; staffing; and emergency equipment; (c) Provision for the care of residents who must be evacuated from the facility during an emergency including identification of such residents and transfer of resident records; evacuation transportation; sheltering arrangements; supplies; staffing; emergency equipment; and medications; (d) Provision for the care of additional residents who may be evacuated to the facility during an emergency including the identification of such residents, staffing, and supplies; (e) Identification of residents with _____'s _____ or related _____, and residents with mobility limitations who may need specialized assistance either at the facility or in case of evacuation; (f) Identification of and coordination with the local emergency management agency; (g) Arrangement for post-disaster activities including responding to family inquiries, obtaining	A 180		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969833	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 02/16/2023
NAME OF PROVIDER OR SUPPLIER NINA'S HOUSE ALF		STREET ADDRESS, CITY, STATE, ZIP CODE 2312 W POWHATAN AVE TAMPA, FL 33603			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 180	Continued From page 6 medical intervention for residents, transportation, and reporting to the local emergency management agency the number of residents who have been relocated, and the place of relocation; and, (h) The identification of staff responsible for implementing each part of the plan. This Statute or Rule is not met as evidenced by: Based on record review and interview, the facility failed to prepare a written comprehensive emergency management plan. Findings Included: An attempted record review of the facility's comprehensive emergency management plan, on ..., revealed that the facility did not have a written emergency management plan. In an interview with the Owner, conducted at 10:15am on ..., she stated that the facility had not yet completed the writing of the emergency management plan. Class III	A 180			
A 200 SS=D	59A-36.025 FAC Emergency Environmental Control 59A-36.025 Emergency Environmental Control for Assisted Living Facilities. (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969833	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 02/16/2023
NAME OF PROVIDER OR SUPPLIER NINA'S HOUSE ALF			STREET ADDRESS, CITY, STATE, ZIP CODE 2312 W POWHATAN AVE TAMPA, FL 33603		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 7 primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the assisted living facility, to ensure that current licensees of assisted living facilities will be equipped to ensure air temperatures will be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is appropriate for resident care needs and life safety requirements. For planning purposes, no less than twenty (20) net square . . . per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed capacity as the number of residents to be used in the to determine the required square footage. This may include areas that are less than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving provider for evacuees when the conditions stated in section 408.821, F.S. and subsection 59A-36.019(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained. 2. The alternate power source and fuel supply shall be located in an area(s) in accordance with	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969833	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 02/16/2023
NAME OF PROVIDER OR SUPPLIER NINA'S HOUSE ALF			STREET ADDRESS, CITY, STATE, ZIP CODE 2312 W POWHATAN AVE TAMPA, FL 33603		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 8 local zoning and the Florida Building Code. 3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly, this rule does not limit the types of systems or equipment that may be used to achieve temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to operate the systems and equipment. a. An assisted living facility in an evacuation zone pursuant to chapter 252, F. S. must maintain an alternative power source and fuel as required by this subsection at all times when the assisted living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if evacuation is necessary. b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly described in the emergency power plan. c. A multistory facility, whose comprehensive emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional protection so it can safely operate in a location protected from flooding or storm surge damage.	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969833	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 02/16/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

NINA'S HOUSE ALF

**2312 W POWHATAN AVE
TAMPA, FL 33603**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 9 (b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the alternate power source to maintain temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours after the loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel storage. 1. Facilities must store minimum amounts of fuel onsite as follows: a. A facility with a licensed capacity of 16 beds or less must store 48 hours of fuel onsite. b. A facility with a licensed capacity of 17 or more beds must store 72 hours of fuel onsite. 2. An assisted living facility located in an area in a declared state of emergency area pursuant to section 252.36, F.S. that may impact primary power delivery must secure ninety-six (96) hours of fuel. The assisted living facility may utilize portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency. 3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule. 4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living facility must develop a plan that includes maximum onsite fuel storage allowable by the ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969833	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 02/16/2023
NAME OF PROVIDER OR SUPPLIER NINA'S HOUSE ALF		STREET ADDRESS, CITY, STATE, ZIP CODE 2312 W POWHATAN AVE TAMPA, FL 33603			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 10 alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a monoxide alarm. (2) SUBMISSION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall submit its plan to the local emergency management agency for review within 30 days of the effective date of this rule. Assisted living facility plans previously submitted and approved pursuant to emergency Rule 58AER17-1 will require resubmission only if changes are made to the plan. (b) Each new assisted living facility shall submit the plan required under this rule prior to obtaining a license. (c) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the local emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally authorized entity. If the plan is maintained in an electronic format, assisted living facility staff must be readily available to access and produce the plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within two (2) business days of the approval of the plan from the local emergency management agency, the assisted living facility	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969833	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 02/16/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

NINA'S HOUSE ALF

**2312 W POWHATAN AVE
TAMPA, FL 33603**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 11 shall submit in writing proof of the approval to the Agency for Health Care Administration. (c) The assisted living facility shall submit a consumer-friendly summary of the emergency power plan to the Agency. The Agency shall post the summary and notice of the approval and implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the local emergency management agency and update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall, no later than _____, have implemented the plan required under this rule. (b) The Agency shall allow an extension up to _____ to providers in compliance with paragraph (c) below and who can show delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes. Assisted living facilities shall notify the Agency that they will utilize the extension and keep the Agency apprised of progress on a quarterly basis to ensure there are no unnecessary delays. If an assisted living facility can show in its quarterly progress reports that unavoidable delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes will occur beyond the initial extension date, the assisted living facility may request a waiver pursuant to section 120.542, F.S. (c) During the extension period, an assisted living facility must make arrangements pending full implementation of its plan that provides the residents with an area or areas to congregate that meets the safe indoor air temperature	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969833	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 02/16/2023
NAME OF PROVIDER OR SUPPLIER NINA'S HOUSE ALF		STREET ADDRESS, CITY, STATE, ZIP CODE 2312 W POWHATAN AVE TAMPA, FL 33603			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 12 requirements of subsection (1) (a) for a minimum of ninety-six (96) hours. 1. An assisted living facility not located in an evacuation zone must either have an alternative power source onsite or have a contract in place for delivery of an alternative power source and fuel when requested. Within twenty-four (24) hours of the issuance of a state of emergency for an event that may impact primary power delivery for the area of the assisted living facility, it must have the alternative power source and no less than ninety-six (96) hours of fuel stored onsite. 2. An assisted living facility located in an evacuation zone pursuant to chapter 252, F.S. must either: a. Fully and safely evacuate its residents prior to the arrival of the event; or b. Have an alternative power source and no less than ninety-six (96) hours of fuel stored onsite, within twenty-four (24) hours of the issuance of a state of emergency for the area of the assisted living facility. (d) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (e) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan concurrent with any such additions, modifications, alterations, refurbishment, renovations or reconstruction. (f) The Agency for Health Care Administration may request cooperation from the State Fire Marshal to conduct inspections to ensure implementation of the plan in compliance with this rule.	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969833	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 02/16/2023
NAME OF PROVIDER OR SUPPLIER NINA'S HOUSE ALF			STREET ADDRESS, CITY, STATE, ZIP CODE 2312 W POWHATAN AVE TAMPA, FL 33603		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 13 (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can effectively and immediately activate, operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in air temperatures inside the facility. Procedures must address the care of residents occupying the facility during a declared state of emergency, specifically, a description of the methods to be used to mitigate the potential for heat related injury including: 1. The use of cooling devices and equipment; 2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration; 3. Wellness checks by assisted living facility staff to monitor for signs of _____ and heat injury; and 4. A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy. (b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted living facility staff must be readily available to access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request. (c) The written policies and procedures must be readily available for inspection by each resident;	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969833	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 02/16/2023
NAME OF PROVIDER OR SUPPLIER NINA'S HOUSE ALF			STREET ADDRESS, CITY, STATE, ZIP CODE 2312 W POWHATAN AVE TAMPA, FL 33603		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 14 each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by law. (6) REVOCATION OF LICENSE, FINES OR SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by chapter 429, part I, or chapter 408, part II, F.S., including, but not limited to, license revocation, license suspension, and the imposition of administrative fines. (7) COMPREHENSIVE EMERGENCY MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION. (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon submission of the plan to the local emergency management agency that the plan has been submitted for review and approval; 2. Upon final implementation of the plan by the assisted living facility. (b) Each assisted living facility must maintain a copy of each notification set forth in paragraph (a) above in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969833	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 02/16/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

NINA'S HOUSE ALF

**2312 W POWHATAN AVE
TAMPA, FL 33603**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 15 format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the notifications, either in electronic or paper format, upon request. This Statute or Rule is not met as evidenced by: Based on observation and interview, the facility failed to store enough fuel onsite to ensure that, in the event of the loss of primary electrical power, the alternate power source would run for at least 48 hours. Findings Included: An observation of the facility's alternate power source, a dual-fuel portable generator, conducted at 9:55am on _____, revealed that there was no gasoline or propane fuel (either of which the generator required) stored onsite. An empty 1 gallon gasoline container was also observed. In an interview with the Owner at 9:55am on _____, she stated that they had not yet purchased any additional fuel to run the generator. Class III	A 200		