

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 07/24/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

VISTA ALEGRE

**6800 SW 130 AVE 1
MIAMI, FL 33183**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 000	Initial Comments An abbreviated re-licensure survey was conducted at Vista Alegre ALF Inc. Deficiencies were identified at the time of the survey.	A 000		
A 081 SS=E	429.52(1 & 7) FS; 59A-36.011() FAC Training - Staff In-Service 429.52(1) (1) Each new assisted living facility employee who has not previously completed core training must attend a preservice orientation provided by the facility before interacting with residents. The preservice orientation must be at least 2 hours in duration and cover topics that help the employee provide responsible care and respond to the needs of facility residents. Upon completion, the employee and the administrator of the facility must sign a statement that the employee completed the required preservice orientation. The facility must keep the signed statement in the employee's personnel record. (7) Facility staff shall participate in inservice training relevant to their job duties as specified by agency rule. Topics covered during the preservice orientation are not required to be repeated during inservice training. A single certificate of completion that covers all required inservice training topics may be issued to a participating staff member if the training is provided in a single training course. 59A-36.011 (2) STAFF PRESERVICE ORIENTATION. (a) Facilities must provide a preservice orientation of at least 2 hours to all new assisted living facility employees who have not previously completed core training as detailed in subsection (1).	A 081		

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE		STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 081	Continued From page 1 (b) New staff must complete the preservice orientation prior to interacting with residents. (c) Once complete, the employee and the facility administrator must sign a statement that the employee completed the preservice orientation which must be kept in the employee's personnel record. (d) In addition to topics that may be chosen by the facility administrator, the preservice orientation must cover: 1. Resident's rights; and, 2. The facility's license type and services offered by the facility. (3) STAFF IN-SERVICE TRAINING. Facility administrators or managers shall provide or arrange for the following in-service training to facility staff: (a) Staff who provide direct care to residents, other than nurses, certified nursing assistants, or home health aides trained in accordance with rule 59A-8.0095, F.A.C., must receive a minimum of 1 hour in-service training in control, including universal precautions and facility sanitation procedures, before providing personal care to residents. The facility must use its control policies and procedures when offering this training. Documentation of compliance with the staff training requirements of 29 CFR 1910.1030, relating to blood borne pathogens, may be used to meet this requirement. (b) Staff who provide direct care to residents must receive a minimum of 1 hour in-service training within 30 days of employment that covers the following subjects: 1. Reporting adverse incidents. 2. Facility emergency procedures including chain-of-command and staff roles relating to emergency evacuation.	A 081			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE		STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 081	Continued From page 2 (c) Staff who provide direct care to residents, who have not taken the core training program, shall receive a minimum of 1 hour in-service training within 30 days of employment that covers the following subjects: 1. Resident rights in an assisted living facility. 2. Recognizing and reporting resident _____, neglect, and _____. The facility must use its _____ prevention policies and procedures when offering this training. (d) Staff who provide direct care to residents, other than nurses, CNAs, or home health aides trained in accordance with rule 59A-8.0095, F.A.C., must receive 3 hours of in-service training within 30 days of employment that covers the following subjects: 1. Resident behavior and needs. 2. Providing assistance with the activities of daily living. (e) Staff who prepare or serve food, who have not taken the assisted living facility core training must receive a minimum of 1-hour-in-service training within 30 days of employment in safe food handling practices. (f) All facility staff shall receive in-service training regarding the facility's resident elopement response policies and procedures within thirty (30) days of employment. 1. All facility staff shall be provided with a copy of the facility's resident elopement response policies and procedures. 2. All facility staff shall demonstrate an understanding and competency in the implementation of the elopement response policies and procedures. This Statute or Rule is not met as evidenced by:	A 081			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE			STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 081	Continued From page 3 Based on observation, record review, and interview, the facility failed to ensure staff received 2 hours preservice orientation prior to interacting with residents for two out of three sampled staff (Staff B and C). Findings Included: On at 10:50 am, observed Staff B and Staff C working at the facility with a census of four residents. A review of Staff B personnel file showed a hired date for There was no documentation staff received 2 hours preservice orientation prior to interacting with residents on file. A review of Staff C personnel file showed a hired date for There was no documentation staff received 2 hours preservice orientation prior to interacting with residents on file. In an interview with the Administrator on at 2:51 pm, concerning staff preservice orientation, she stated she believed she had 30 days for staff to complete the training. Class III	A 081			
A 083 SS=D	59A-36.011(5) FAC Training - First Aid and (5) FIRST AID AND (.....). A staff member who has completed courses in First Aid and and holds a currently valid card documenting completion of such courses must be in the facility at all times.	A 083			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE			STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 083	Continued From page 4 (a) Documentation that the staff member possess current certification that requires the student to demonstrate, in person, that he or she is able to perform and which is issued by an instructor or training provider that is approved to provide training by the American Red Cross, the American ... Association, the National Safety Council, or an organization whose training is accredited by the Commission on Accreditation for Pre-Hospital Continuing Education satisfies this requirement. (b) A nurse shall be considered as having met the training requirement for First Aid. An emergency medical technician or paramedic currently certified under chapter 401, Part III, F.S., shall be considered as having met the training requirements for both First Aid and C.P.R. This Statute or Rule is not met as evidenced by: Based on observation, record review, and interview, the facility failed to ensure that a staff member who had completed a course in First Aid and ... () and held a currently valid card documenting completion of such course was at the facility all times for one out of three sampled staff (Staff D). Findings Included: A review of the facility's staffing schedule for ... showed Staff D (caretaker) was scheduled to work the overnight shift during the week, alone. A review of Staff D's file showed a hired date of ... Further review of the record showed a ... certificate with expiration date for ... In an interview with the Administrator on ... at 2:59 pm, she stated she will have Staff D complete the ... training.	A 083			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE		STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 083	Continued From page 5 Class III	A 083			
A 084 SS=E	59A-36.011(6) FAC 429.52(6), FS Training - Assis Self-Admin Meds & Med Mgmt 59A-36.011 (6) ASSISTANCE WITH THE SELF-ADMINISTRATION OF MEDICATION AND MEDICATION MANAGEMENT. Unlicensed persons who will be providing assistance with the self-administration of medications as described in rule 59A-36.008, F.A.C., must meet the training requirements pursuant to section 429.52(6), F.S., prior to assuming this responsibility. Courses provided in fulfillment of this requirement must meet the following criteria: (a) Training must cover state law and rule requirements with respect to the supervision, assistance, administration, and management of medications in assisted living facilities; procedures and techniques for assisting the resident with self-administration of medication including how to read a prescription label; providing the right medications to the right resident; common medications; the importance of taking medications as prescribed; recognition of side effects and adverse reactions and procedures to follow when residents appear to be experiencing side effects and adverse reactions; documentation and record keeping; and medication storage and disposal. Training shall include demonstrations of proper techniques, including techniques for control, and ensure unlicensed staff have adequately demonstrated that they have acquired the skills necessary to provide such assistance. (b) The training must be provided by a registered nurse or licensed pharmacist who shall issue a	A 084			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 07/24/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

VISTA ALEGRE

**6800 SW 130 AVE 1
MIAMI, FL 33183**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 084	Continued From page 6 training certificate to a trainee who demonstrates, in person and both physically and verbally, the ability to: 1. Read and understand a prescription label; 2. Provide assistance with self-administration in accordance with section 429.256, F.S., and rule 59A-36.008, F.A.C., including: a. Assist with oral dosage forms, _____ dosage forms, and _____ and _____ dosage forms; b. Measure liquid medications, break scored tablets, and crush tablets in accordance with prescription directions; c. Recognize the need to obtain clarification of an "as needed" prescription order; d. Recognize a medication order which requires judgment or discretion, and to advise the resident, resident's health care provider or facility employer of inability to assist in the administration of such orders; e. Complete a medication observation record; f. Retrieve and store medication; g. Recognize the general signs of adverse reactions to medications and report such reactions; h. Assist residents with _____ syringes that are prefilled with the proper dosage by a pharmacist and _____ that are prefilled by the manufacturer by taking the medication, in its previously dispensed, properly labeled container, from where it is stored, and bringing it to the resident for self-injection; i. Assist with _____; j. Use a _____ to perform _____ testing; k. Assist residents with _____ and continuous positive airway pressure (CPAP) devices, excluding the titration of the _____ levels;	A 084		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 07/24/2023
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

VISTA ALEGRE

**6800 SW 130 AVE 1
MIAMI, FL 33183**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 084	Continued From page 7 l. Apply and remove _____ stockings and hosiery; m. Placement and removal of _____ bags, excluding the removal of the _____ or manipulation of the _____ site; and, n. Measurement of _____ rate, temperature, and _____ rate. (c) Unlicensed persons, as defined in section 429.256(1)(b), F.S., who provide assistance with self-administered medications and have successfully completed the initial 6 hour training, must obtain, annually, a minimum of 2 hours of continuing education training on providing assistance with self-administered medications and safe medication practices in an assisted living facility. The 2 hours of continuing education training may be provided online. (d) Trained unlicensed staff who, prior to the effective date of this rule, assist with the self-administration of medication and have successfully completed 4 hours of assistance with self-administration of medication training must complete an additional 2 hours of training that focuses on the topics listed in sub-subparagraphs (6)(b)2.h.-n. of this section, before assisting with the self-administration of medication procedures listed in sub-subparagraphs (6)(b)2.h.-n. 429.52 (6) Staff assisting with the self-administration of medications under s. 429.256 must complete a minimum of 6 additional hours of training provided by a registered nurse or a licensed pharmacist before providing assistance. Two hours of continuing education are required annually thereafter. The agency shall establish by rule the minimum requirements of this training	A 084		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE			STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 084	Continued From page 8 This Statute or Rule is not met as evidenced by: Based on record review and interview, the facility failed to ensure unlicensed staff who provide assistance with self-administered medications and have successfully completed the initial 6 hour training for one out of two sampled staff (Staff B). Findings Included: A review of Staff B's file showed a hired date on . There was no documentation that staff completed the initial 6-hour self-administered medications training file. A review of Staff C's file showed a hired date on . There was no documentation that staff completed the initial 6-hour self-administered medications training on file. In an interview with the Administrator on at 2:40 pm she stated she wasn't aware staff needed an initial 6 hours training and thought the four training would be adequate. Class III	A 084			
A 161 SS=E	429.275(2) FS; 59A-36.015(2) FAC Records - Staff 429.275 (2) The administrator or owner of a facility shall maintain personnel records for each staff member which contain, at a minimum, documentation of background screening, if applicable, documentation of compliance with all training requirements of this part or applicable rule, and a copy of all licenses or certification held by each staff who performs services for which	A 161			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE		STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 161	Continued From page 9 licensure or certification is required under this part or rule. 59A-36.015 (2) STAFF RECORDS. (a) Personnel records for each staff member must contain, at a minimum, a copy of the employment application, with references furnished, and documentation verifying freedom from signs or symptoms of communicable In addition, records must contain the following, as applicable: 1. Documentation of compliance with all staff training and continuing education required by Rule 59A-36.011, F.A.C., 2. Copies of all licenses or certifications for all staff providing services that require licensing or certification, 3. Documentation of compliance with level 2 background screening for all staff subject to screening requirements as specified in Section 429.174, F.S., and Rule 59A-36.010, F.A.C., 4. For facilities with a licensed capacity of 17 or more residents, a copy of the job description given to each staff member pursuant to Rule 59A-36.010, F.A.C., 5. Documentation verifying direct care staff and administrator participation in resident elopement drills pursuant to paragraph 59A-36.007(8)(c), F.A.C. (b) The facility is not required to maintain personnel records for staff provided by a licensed staffing agency or staff employed by an entity . . . to provide direct or indirect services to residents and the facility. However, the facility must maintain a copy of the contract between the facility and the staffing agency or contractor as described in Rule 59A-36.010, F.A.C. (c) The facility must maintain the written work	A 161			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE		STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 161	Continued From page 10 schedules and staff time sheets for the most current 6 months as required by Rule 59A-36.010, F.A.C. This Statute or Rule is not met as evidenced by: Based on record review and interview, the facility failed to ensure staff have a completed employment application, including references and copies of signed attestations on file for two out of eight sampled staff (Staff B and C). Findings Included: On _____ at 10:50 am, observed Staff B and C working with four residents. A review of Staff B's file showed a hired date on _____. There was no documentation of an employment application with references and no background screening signed attestation on file. A review of Staff C's file showed a hired date on _____. There was no documentation of an employment application with references and no background screening signed attestation on file. In an interview with the Administrator on _____ at 2:38 pm, concerning employee application and signed attestation, she stated she will have staff complete the forms. Class III	A 161			
A 200 SS=I	59A-36.025 FAC Emergency Environmental Control	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE			STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 11 59A-36.025 Emergency Environmental Control for Assisted Living Facilities. (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the assisted living facility, to ensure that current licensees of assisted living facilities will be equipped to ensure _____ air temperatures will be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is appropriate for resident care needs and life safety requirements. For planning purposes, no less than twenty (20) net square _____ per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed capacity as the number of residents to be used in the _____ to determine the required square footage. This may include areas that are less than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE			STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 12 provider for evacuees when the conditions stated in section 408.821, F.S. and subsection 59A-36.019(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained. 2. The alternate power source and fuel supply shall be located in an area(s) in accordance with local zoning and the Florida Building Code. 3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly, this rule does not limit the types of systems or equipment that may be used to achieve temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to operate the systems and equipment. a. An assisted living facility in an evacuation zone pursuant to chapter 252, F. S. must maintain an alternative power source and fuel as required by this subsection at all times when the assisted living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if evacuation is necessary. b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE			STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 13 described in the emergency power plan. c. A multistory facility, whose comprehensive emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional equipment so it can safely operate in a location protected from flooding or storm surge damage. (b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the alternate power source to maintain temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours after the loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel storage. 1. Facilities must store minimum amounts of fuel onsite as follows: a. A facility with a licensed capacity of 16 beds or less must store 48 hours of fuel onsite. b. A facility with a licensed capacity of 17 or more beds must store 72 hours of fuel onsite. 2. An assisted living facility located in an area in a declared state of emergency area pursuant to section 252.36, F.S. that may impact primary power delivery must secure ninety-six (96) hours of fuel. The assisted living facility may utilize portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency. 3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule. 4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE			STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 14 facility must develop a plan that includes maximum onsite fuel storage allowable by the ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a monoxide alarm. (2) SUBMISSION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall submit its plan to the local emergency management agency for review within 30 days of the effective date of this rule. Assisted living facility plans previously submitted and approved pursuant to emergency Rule 58AER17-1 will require resubmission only if changes are made to the plan. (b) Each new assisted living facility shall submit the plan required under this rule prior to obtaining a license. (c) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the local emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally authorized entity. If the plan is maintained in an electronic format, assisted living facility staff must	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE			STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 15 be readily available to access and produce the plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within two (2) business days of the approval of the plan from the local emergency management agency, the assisted living facility shall submit in writing proof of the approval to the Agency for Health Care Administration. (c) The assisted living facility shall submit a consumer-friendly summary of the emergency power plan to the Agency. The Agency shall post the summary and notice of the approval and implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the local emergency management agency and update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall, no later than _____, have implemented the plan required under this rule. (b) The Agency shall allow an extension up to _____ to providers in compliance with paragraph (c) below and who can show delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes. Assisted living facilities shall notify the Agency that they will utilize the extension and keep the Agency apprised of progress on a quarterly basis to ensure there are no unnecessary delays. If an assisted living facility can show in its quarterly progress reports that unavoidable delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes will	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE			STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 16 occur beyond the initial extension date, the assisted living facility may request a waiver pursuant to section 120.542, F.S. (c) During the extension period, an assisted living facility must make arrangements pending full implementation of its plan that provides the residents with an area or areas to congregate that meets the safe indoor air temperature requirements of subsection (1) (a) for a minimum of ninety-six (96) hours. 1. An assisted living facility not located in an evacuation zone must either have an alternative power source onsite or have a contract in place for delivery of an alternative power source and fuel when requested. Within twenty-four (24) hours of the issuance of a state of emergency for an event that may impact primary power delivery for the area of the assisted living facility, it must have the alternative power source and no less than ninety-six (96) hours of fuel stored onsite. 2. An assisted living facility located in an evacuation zone pursuant to chapter 252, F.S. must either: a. Fully and safely evacuate its residents prior to the arrival of the event; or b. Have an alternative power source and no less than ninety-six (96) hours of fuel stored onsite, within twenty-four (24) hours of the issuance of a state of emergency for the area of the assisted living facility. (d) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (e) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE			STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 17 concurrent with any such additions, modifications, alterations, refurbishment, renovations or reconstruction. (f) The Agency for Health Care Administration may request cooperation from the State Fire Marshal to conduct inspections to ensure implementation of the plan in compliance with this rule. (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can effectively and immediately activate, operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in air temperatures inside the facility. Procedures must address the care of residents occupying the facility during a declared state of emergency, specifically, a description of the methods to be used to mitigate the potential for heat related injury including: 1. The use of cooling devices and equipment; 2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration; 3. Wellness checks by assisted living facility staff to monitor for signs of _____ and heat injury; and 4. A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy. (b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE			STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 18 living facility staff must be readily available to access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request. (c) The written policies and procedures must be readily available for inspection by each resident; each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by law. (6) REVOCATION OF LICENSE, FINES OR SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by chapter 429, part I, or chapter 408, part II, F.S., including, but not limited to, license revocation, license suspension, and the imposition of administrative fines. (7) COMPREHENSIVE EMERGENCY MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION. (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon submission of the plan to the local emergency management agency that the plan has been submitted for review and approval;	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE			STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 19 2. Upon final implementation of the plan by the assisted living facility. (b) Each assisted living facility must maintain a copy of each notification set forth in paragraph (a) above in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the notifications, either in electronic or paper format, upon request. This Statute or Rule is not met as evidenced by: Based on observation, record review, and interview, the facility failed to have the required fuel for the operation of the alternate power source to maintain room temperatures at or below 81 degrees in the event of the loss of primary power for a minimum of 48 hours. Findings Included: On At 2:19 pm, observed a portable generator (Predator 900 Watts) in the backyard. Also, observed a storage unit in the backyard, that had (5) 5- gallons of fuel containers; two of the containers were half full and three containers were empty. Observed (1) 6- gallon container to be half full. The facility had approximately 6 gallons of fuel onsite. A review of the generator's manual showed the facility portable generator would operate for 13 hours with 6 gallons of fuel. In an interview with the Administrator on at 3:05 pm, she stated, "The gas may	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968015	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 07/24/2023
NAME OF PROVIDER OR SUPPLIER VISTA ALEGRE		STREET ADDRESS, CITY, STATE, ZIP CODE 6800 SW 130 AVE 1 MIAMI, FL 33183			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 20 have evaporated or was destroyed. I will refill the gas containers. Class II	A 200			