

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 03/20/2024
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

RIVERS EDGE ASSISTED LIVING LLC

**1315 ROCKLEDGE DR
ROCKLEDGE, FL 32955**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 000	Initial Comments A re-licensure survey was conducted on _____ at Rivers Edge Assisted Living LLC, Rockledge. Deficiencies were found at the time of the visit.	A 000		
A 078 SS=D	59A-36.010(2) FAC Staffing Standards - Staff (2) STAFF. (a) Within 30 days after beginning employment, newly hired staff must submit a written statement from a health care provider documenting that the individual does not have any signs or symptoms of communicable _____. The examination performed by the health care provider must have been conducted no earlier than 6 months before submission of the statement. Newly hired staff does not include an employee transferring without a break in service from one facility to another when the facility is under the same management or ownership. 1. Evidence of a negative examination must be documented on an annual basis. Documentation provided by the Florida Department of Health or a licensed health care provider certifying that there is a shortage of _____ testing materials satisfies the annual _____ examination requirement. An individual with a positive _____ test must submit a health care provider's statement that the individual does not constitute a risk of _____. 2. If any staff member has, or is suspected of having, a communicable _____, such individual must be immediately removed from duties until a written statement is submitted from a health care provider indicating that the individual does not constitute a risk of transmitting a communicable _____. (b) Staff must be qualified to perform their _____	A 078		

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 03/20/2024
NAME OF PROVIDER OR SUPPLIER RIVERS EDGE ASSISTED LIVING LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 1315 ROCKLEDGE DR ROCKLEDGE, FL 32955		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 078	Continued From page 1 assigned duties consistent with their level of education, training, preparation, and experience. Staff providing services requiring licensing or certification must be appropriately licensed or certified. All staff must exercise their responsibilities, consistent with their qualifications, to observe residents, to document observations on the appropriate resident's record, and to report the observations to the resident's health care provider in accordance with this rule chapter. (c) All staff must comply with the training requirements of rule 59A-36.011, F.A.C. (d) An assisted living facility to provide services to residents must ensure that individuals providing services are qualified to perform their assigned duties in accordance with this rule chapter. The contract between the facility and the staffing agency or contractor must specifically describe the services the staffing agency or contractor will provide to residents. (e) For facilities with a licensed capacity of 17 or more residents, the facility must: 1. Develop a written job description for each staff position and provide a copy of the job description to each staff member; and, 2. Maintain time sheets for all staff. (f) Level 2 background screening must be conducted for staff, including staff by the facility to provide services to residents, pursuant to sections 408.809 and 429.174, F.S. This Statute or Rule is not met as evidenced by: Based on record review and interview the facility failed to ensure 1 of 2 sampled staff (A) completed a required an annual () examination and a completed health care provider's statement that the staff does not constitute a risk of communicating . . .	A 078		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 03/20/2024
NAME OF PROVIDER OR SUPPLIER RIVERS EDGE ASSISTED LIVING LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 1315 ROCKLEDGE DR ROCKLEDGE, FL 32955		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 078	Continued From page 2 Findings: In a personnel record review of staff A, it revealed a hire date of _____. There was no documented evidence of a negative annual _____ examination or a health care provider's statement that the staff does not constitute a risk of communicating _____ as required. In an interview on _____ at 1pm with the administrator, she confirmed the findings. Class III	A 078			
A 083 SS=D	59A-36.011(5) FAC Training - First Aid and _____ (5) FIRST AID AND _____. A staff member who has completed courses in First Aid and _____ and holds a currently valid card documenting completion of such courses must be in the facility at all times. (a) Documentation that the staff member possess current _____ certification that requires the student to demonstrate, in person, that he or she is able to perform _____ and which is issued by an instructor or training provider that is approved to provide _____ training by the American Red Cross, the American _____ Association, the National Safety Council, or an organization whose training is accredited by the Commission on Accreditation for Pre-Hospital Continuing Education satisfies this requirement. (b) A nurse shall be considered as having met the training requirement for First Aid. An emergency medical technician or paramedic currently certified under chapter 401, Part III, F.S., shall be considered as having met the training requirements for both First Aid and C.P.R.	A 083			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 03/20/2024
NAME OF PROVIDER OR SUPPLIER RIVERS EDGE ASSISTED LIVING LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 1315 ROCKLEDGE DR ROCKLEDGE, FL 32955		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 083	Continued From page 3 This Statute or Rule is not met as evidenced by: Based on record review and interview, the facility failed to ensure that a staff member (A) completed First Aid and _____ () courses, which at least one staff is required on all shifts. Findings: In a personnel record of staff A, it revealed a hire date of _____ as a direct care giver. In review of the facility's schedule, it revealed staff A works alone on her shift. There was no evidence staff A completed the required First Aid/ _____ course. In a interview on _____ at 1pm, with the administrator, she confirmed the findings. Class III	A 083			
A 086 SS=D	59A-36.011(10) FAC Training - ADRD (10) _____ AND RELATED _____ ("ADRD") TRAINING REQUIREMENTS. Facilities which advertise that they provide special care for persons with ADRD, or who maintain secured areas as described in Chapter 4, Section 464.4.6 of the Florida Building Code, as adopted in rule 61G20-1.001, F.A.C., Florida Building Code Adopted, must ensure that facility staff receive the following training. (a) Facility staff who interact on a daily basis with residents with ADRD but do not provide direct care to such residents and staff who provide direct care to residents with ADRD, shall obtain 4 hours of initial training within 3 months of employment. Completion of the core training program between _____ and _____	A 086			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL1169598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 03/20/2024
NAME OF PROVIDER OR SUPPLIER RIVERS EDGE ASSISTED LIVING LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 1315 ROCKLEDGE DR ROCKLEDGE, FL 32955		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 086	Continued From page 4 shall satisfy this requirement. Facility staff who meet the requirements for ADRD training providers under paragraph (g) of this subsection, will be considered as having met this requirement. Initial training, entitled " _____ and Related _____ Level I Training," must address the following subject areas: - Understanding _____'s _____ and related _____; - Characteristics of _____; - Communicating with residents with _____'s _____; - Family issues; - Resident environment; and, - Ethical issues. (b) Staff who have successfully completed both the initial one hour and continuing three hours of ADRD training pursuant to sections 400.1755, 429.917 and 400.6045(1), F.S., shall be considered to have met the initial assisted living facility _____ and Related _____ Level I Training. (c) Facility staff who provide direct care to residents with ADRD must obtain an additional 4 hours of training, entitled " _____ and Related _____ Level II Training," within 9 months of employment. Facility staff who meet the requirements for ADRD training providers under paragraph (g) of this subsection, will be considered as having met this requirement. _____ and Related _____ Level II Training must address the following subject areas as they apply to these _____: - Behavior management, - Assistance with ADLs, - Activities for residents, - Stress management for the care giver; and, - Medical information. (d) A detailed description of the subject areas that	A 086			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 03/20/2024
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

RIVERS EDGE ASSISTED LIVING LLC

**1315 ROCKLEDGE DR
ROCKLEDGE, FL 32955**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 086	Continued From page 5 must be included in an ADRD curriculum which meets the requirements of paragraphs (a) and (b) of this subsection, can be found in the document "Training Guidelines for the Special Care of Persons with _____'s _____ and Related _____," dated _____, incorporated by reference, available from the Department of Elder Affairs, 4040 Esplanade Way, Tallahassee, Florida 32399-7000. (e) Direct care staff shall participate in 4 hours of continuing education annually as required under section 429.178, F.S. Continuing education received under this paragraph may be used to meet 3 of the 12 hours of continuing education required by section 429.52, F.S., and subsection (1) of this rule, or 3 of the 6 hours of continuing education for extended congregate care required by subsection (7) of this rule. (f) Facility staff who have only incidental contact with residents with ADRD must receive general written information provided by the facility on interacting with such residents, as required under section 429.178, F.S., within three (3) months of employment. "Incidental contact" means all staff who neither provide direct care nor are in regular contact with such residents. (g) Persons who seek to provide ADRD training in accordance with this subsection must provide the department or its designee with documentation that they hold a Bachelor's degree from an accredited college or university or hold a license as a registered nurse, and: 1. Have 1 year teaching experience as an educator of caregivers for persons with _____ or related _____, or 2. Three years of practical experience in a program providing care to persons with _____ or related _____, or 3. Completed a specialized training program in	A 086		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 03/20/2024
NAME OF PROVIDER OR SUPPLIER RIVERS EDGE ASSISTED LIVING LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 1315 ROCKLEDGE DR ROCKLEDGE, FL 32955		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 086	Continued From page 6 the subject matter of this program and have a minimum of two years of practical experience in a program providing care to persons with or related (h) With reference to requirements in paragraph (g), a Master's degree from an accredited college or university in a subject related to the content of this training program can substitute for the teaching experience. Years of teaching experience related to the subject matter of this training program may substitute on a year-by-year basis for the required Bachelor's degree referenced in paragraph (g). This Statute or Rule is not met as evidenced by: Based on record review and interview the facility failed to ensure 1 of sampled 2 staff (A) completed the required 4-hour annual continuing education in _____'s _____ and related _____ (ADRD). Findings: Personnel record review revealed staff A was hired on _____ as a direct care giver. Further review confirmed staff A completed the ADRD I and II on _____ from another facility. There was no documentation of any annual updates in 2023 or 2024. In an interview on _____ at 1pm, the administrator confirmed the findings. Class III	A 086			
A 152 SS=D	59A-36.014(3) FAC Physical Plant - Safe Living Environ/Other (3) OTHER REQUIREMENTS.	A 152			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 03/20/2024
NAME OF PROVIDER OR SUPPLIER RIVERS EDGE ASSISTED LIVING LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 1315 ROCKLEDGE DR ROCKLEDGE, FL 32955		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 152	Continued From page 7 (a) All facilities must: 1. Provide a safe living environment pursuant to section 429.28(1)(a), F.S.; 2. Be maintained free of hazards; and, 3. Ensure that all existing architectural, mechanical, electrical and structural systems, and appurtenances are maintained in good working order. (b) Pursuant to section 429.27, F.S., residents must be given the option of using their own belongings as space permits. When the facility supplies the furnishings, each resident bedroom or sleeping area must have at least the following furnishings: 1. A clean, comfortable bed with a mattress no less than 36 inches wide and 72 inches long, with the top surface of the mattress at a comfortable height to ensure easy access by the resident, 2. A closet or wardrobe space for hanging clothes, 3. A dresser, chest of drawers, or other furniture designed for storage of clothing or personal effects, 4. A table or nightstand, bedside lamp or floor lamp, and waste basket; and, 5. A comfortable chair, if requested. (c) The facility must maintain master or duplicate keys to resident bedrooms to be used in the event of an emergency. (d) Residents who use portable bedside commodes must be provided with privacy during use. (e) Facilities must make available linens and personal laundry services for residents who require such services. Linens provided by a facility must be free of tears, stains and must not be soiled. This Statute or Rule is not met as evidenced by: Based on observation and interview, the facility failed to maintain a safe living environment by	A 152			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 03/20/2024
NAME OF PROVIDER OR SUPPLIER RIVERS EDGE ASSISTED LIVING LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 1315 ROCKLEDGE DR ROCKLEDGE, FL 32955		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 152	Continued From page 8 maintaining appurtenances are in good working order. Findings: In an observation on _____ at 11am, of the facility's resident bathroom, the lid on the toilet (in between residents' bedrooms off the kitchen) was not the correct toilet lid for that toilet. The lid was larger than the toilet tank and was placed lopsided on top of the toilet tank. In addition, the door cabinet under the sink, in the same bathroom, was missing. In an interview on _____ at 1pm with the administrator, she confirmed the findings. Photographic evidence obtained. Class III	A 152			
A 200 SS=D	59A-36.025 FAC Emergency Environmental Control 59A-36.025 Emergency Environmental Control for Assisted Living Facilities. (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the assisted living facility, to ensure that current licensees of assisted living facilities will be	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 03/20/2024
NAME OF PROVIDER OR SUPPLIER RIVERS EDGE ASSISTED LIVING LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 1315 ROCKLEDGE DR ROCKLEDGE, FL 32955		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 9 equipped to ensure air temperatures will be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is appropriate for resident care needs and life safety requirements. For planning purposes, no less than twenty (20) net square . . . per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed capacity as the number of residents to be used in the to determine the required square footage. This may include areas that are less than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving provider for evacuees when the conditions stated in Section 408.821, F.S. and subsection 59A-36.019(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained. 2. The alternate power source and fuel supply shall be located in an area(s) in accordance with local zoning and the Florida Building Code. 3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly,	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 03/20/2024
NAME OF PROVIDER OR SUPPLIER RIVERS EDGE ASSISTED LIVING LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 1315 ROCKLEDGE DR ROCKLEDGE, FL 32955		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 10 this rule does not limit the types of systems or equipment that may be used to achieve temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to operate the systems and equipment. a. An assisted living facility in an evacuation zone pursuant to Chapter 252, F, S. must maintain an alternative power source and fuel as required by this subsection at all times when the assisted living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if evacuation is necessary. b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly described in the emergency power plan. c. A multistory facility, whose comprehensive emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional equipment so it can safely operate in a location protected from flooding or storm surge damage. (b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the alternate power source to maintain temperatures at or below 81 degrees Fahrenheit	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 03/20/2024
NAME OF PROVIDER OR SUPPLIER RIVERS EDGE ASSISTED LIVING LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 1315 ROCKLEDGE DR ROCKLEDGE, FL 32955		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 11 for a minimum of ninety-six (96) hours after the loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel storage. 1. Facilities must store minimum amounts of fuel onsite as follows: a. A facility with a licensed capacity of 16 beds or less must store 48 hours of fuel onsite. b. A facility with a licensed capacity of 17 or more beds must store 72 hours of fuel onsite. 2. An assisted living facility located in an area in a declared state of emergency area pursuant to Section 252.36, F.S. that may impact primary power delivery must secure ninety-six (96) hours of fuel. The assisted living facility may utilize portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency. 3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule. 4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living facility must develop a plan that includes maximum onsite fuel storage allowable by the ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a monoxide alarm. (2) SUBMISSION OF THE PLAN. (a) Each new assisted living facility shall submit	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 03/20/2024
NAME OF PROVIDER OR SUPPLIER RIVERS EDGE ASSISTED LIVING LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 1315 ROCKLEDGE DR ROCKLEDGE, FL 32955		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 12 the plan required under this rule prior to obtaining a license. (b) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the county emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally authorized entity. If the plan is maintained in an electronic format, assisted living facility staff must be readily available to access and produce the plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within 30 days of the approval of the plan from the county emergency management agency, the assisted living facility shall submit in writing proof of the approval to the Agency for Health Care Administration to assistedliving@ahca.myflorida.com . (c) The assisted living facility shall submit a consumer-friendly summary of the emergency power plan to the Agency. The Agency shall post the summary and notice of the approval and implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the county emergency management agency and update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN.	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 03/20/2024
NAME OF PROVIDER OR SUPPLIER RIVERS EDGE ASSISTED LIVING LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 1315 ROCKLEDGE DR ROCKLEDGE, FL 32955		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 13 (a) Each assisted living facility licensed prior to the effective date of this rule shall, no later than _____, have implemented the plan required under this rule. (b) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (c) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan concurrent with any such additions, modifications, alterations, refurbishment, renovations or reconstruction. (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can effectively and immediately activate, operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in _____ air temperatures inside the facility. Procedures must address the care of residents occupying the facility during a declared state of emergency, specifically, a description of the methods to be used to mitigate the potential for heat related injury including: 1. The use of cooling devices and equipment; 2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration; 3. Wellness checks by assisted living facility staff to monitor for signs of _____ and heat injury; and 4. A provision for obtaining medical intervention	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 03/20/2024
NAME OF PROVIDER OR SUPPLIER RIVERS EDGE ASSISTED LIVING LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 1315 ROCKLEDGE DR ROCKLEDGE, FL 32955		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 14 from emergency services for residents whose life safety is in jeopardy. (b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted living facility staff must be readily available to access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request. (c) The written policies and procedures must be readily available for inspection by each resident; each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by law. (6) REVOCATION OF LICENSE, FINES OR SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by Chapter 429, Part I, or Chapter 408, Part II, F.S., including, but not limited to, license revocation, license suspension, and the imposition of administrative fines. (7) COMPREHENSIVE EMERGENCY MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION.	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 03/20/2024
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

RIVERS EDGE ASSISTED LIVING LLC

**1315 ROCKLEDGE DR
ROCKLEDGE, FL 32955**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 15 (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon the initial submission of the plan to the county emergency management agency that the plan has been submitted for review and approval; 2. Upon final implementation of the plan by the assisted living facility. 3. Annual submissions and approvals of the plan do not require notification to residents or their legal representatives unless a significant modification as defined in Rule 59A-36.019, F.A.C., has been made to the plan. (b) Each assisted living facility must maintain a copy of each notification set forth in paragraph (a) above in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the notifications, either in electronic or paper format, upon request. This Statute or Rule is not met as evidenced by: Based on observation and interview, the facility failed to maintain an alternate power source (generator) in working order. Findings: In an interview on _____ at 1pm with the administrator, she stated she has 2 portable generators, one for each side of the home. In an observation on _____ of the facility's	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11969598	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 03/20/2024
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

RIVERS EDGE ASSISTED LIVING LLC

**1315 ROCKLEDGE DR
ROCKLEDGE, FL 32955**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 16 alternate power source, a request was made for the administrator to start both generators to observe that they were in good working order. One of the generators started the other generator continued to backfire and did not start up. The administrator was able to start the second portable generator. In an interview with the administrator at 1pm, she stated the generator that would not start was older and she needed to replace it. Photo taken Class III	A 200		