

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910267	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 10/07/2025
NAME OF PROVIDER OR SUPPLIER BROOKDALE CHAMBREL PINECASTLE			STREET ADDRESS, CITY, STATE, ZIP CODE 1801 SE 24TH ROAD OCALA, FL 34471		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 000	Initial Comments An unannounced re-licensure survey with Emergency Power Plan and Limited Nursing Services monitoring and a complaint investigation (complaint #2025014228) were conducted at Brookdale Chambrel Pinecastle on October 6, 2025 through October 7, 2025. Deficiencies were identified at the time of the survey.	A 000			
A 052	429.256(3-5); 59A-36.008(3) Medication - Assistance with Self-Admin 429.256 (3) Assistance with self-administration of medication includes: (a) Taking the medication, in its previously dispensed, properly labeled container, from where it is stored, and bringing it to the resident. For purposes of this paragraph, an insulin syringe that is prefilled with the proper dosage by a pharmacist and an insulin pen that is prefilled by the manufacturer are considered medications in previously dispensed, properly labeled containers. (b) In the presence of the resident, confirming that the medication is intended for that resident, orally advising the resident of the medication name and dosage, opening the container, removing a prescribed amount of medication from the container, and closing the container. The resident may sign a written waiver to opt out of being orally advised of the medication name and dosage. The waiver must identify all of the medications intended for the resident, including names and dosages of such medications, and must immediately be updated each time the resident's medications or dosages change. (c) Placing an oral dosage in the resident's hand or placing the dosage in another container and helping the resident by lifting the container to his or her mouth.	A 052			

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X8) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910267	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 10/07/2025
NAME OF PROVIDER OR SUPPLIER BROOKDALE CHAMBREL PINECASTLE			STREET ADDRESS, CITY, STATE, ZIP CODE 1801 SE 24TH ROAD OCALA, FL 34471		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 052	Continued From page 1 (d) Applying topical medications. (e) Returning the medication container to proper storage. (f) Keeping a record of when a resident receives assistance with self-administration under this section. (g) Assisting with the use of a nebulizer, including removing the cap of a nebulizer, opening the unit dose of nebulizer solution, and pouring the prescribed premeasured dose of medication into the dispensing cup of the nebulizer. (4) Assistance with self-administration of medication does not include: (a) Mixing, compounding, converting, or calculating medication doses, except for measuring a prescribed amount of liquid medication or breaking a scored tablet or crushing a tablet as prescribed. (b) The preparation of syringes for injection or the administration of medications by any injectable route. (c) Administration of medications by way of a tube inserted in a cavity of the body. (d) Administration of parenteral preparations. (e) The use of irrigations or debriding agents used in the treatment of a skin condition. (f) Assisting with rectal, urethral, or vaginal preparations. (g) Assisting with medications ordered by the physician or health care professional with prescriptive authority to be given "as needed," unless the order is written with specific parameters that preclude independent judgment on the part of the unlicensed person, and the resident requesting the medication is aware of his or her need for the medication and understands the purpose for taking the medication. (h) Medications for which the time of administration, the amount, the strength of	A 052			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910267	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 10/07/2025
NAME OF PROVIDER OR SUPPLIER BROOKDALE CHAMBREL PINECASTLE			STREET ADDRESS, CITY, STATE, ZIP CODE 1801 SE 24TH ROAD OCALA, FL 34471		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 052	Continued From page 2 dosage, the method of administration, or the reason for administration requires judgment or discretion on the part of the unlicensed person. (5) Assistance with the self-administration of medication by an unlicensed person as described in this section shall not be considered administration as defined in s. 465.003. 59A-36.008 (3) ASSISTANCE WITH SELF-ADMINISTRATION. (a) Any unlicensed person providing assistance with self-administration of medication must be 18 years of age or older, trained to assist with self-administered medication pursuant to the training requirements of Rule 59A-36.011, F.A.C., and must be available to assist residents with self-administered medications in accordance with procedures described in Section 429.256, F.S. and this rule. (b) In addition to the specifications of Section 429.256(3), F.S., assistance with self-administration of medication includes, orally advising the resident of the name and dosage of the medication and verbally prompting a resident to take medications as prescribed. (c) In order to facilitate assistance with self-administration, trained staff may prepare and make available such items as water, juice, cups, and spoons. Trained staff may also return unused doses to the medication container. Medication, which appears to have been contaminated, must not be returned to the container. (d) Trained staff must observe the resident take the medication. Any concerns about the resident's reaction to the medication or suspected noncompliance must be reported to the resident's health care provider and documented in the resident's record.	A 052			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910267	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 10/07/2025
NAME OF PROVIDER OR SUPPLIER BROOKDALE CHAMBREL PINECASTLE			STREET ADDRESS, CITY, STATE, ZIP CODE 1801 SE 24TH ROAD OCALA, FL 34471		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 052	Continued From page 3 (e) When a resident who receives assistance with medication is away from the facility and from facility staff, the following options are available to enable the resident to take medication as prescribed: 1. The health care provider may prescribe a medication schedule that coincides with the resident's presence in the facility. 2. The medication container may be given to the resident, a friend, or family member upon leaving the facility, with this fact noted in the resident's medication record. 3. The medication may be transferred to a pill organizer pursuant to the requirements of subsection (2), and given to the resident, a friend, or family member upon leaving the facility, with this fact noted in the resident's medication record, or 4. Medications may be separately prescribed and dispensed in an easier to use form, such as unit dose packaging. (f) Assistance with self-administration of medication does not include the activities detailed in Section 429.256(4), F.S. (g) As used in Section 429.256(4)(h), F.S., the terms "judgment" and "discretion" mean interpreting vital signs and evaluating or assessing a resident's condition. (h) All trained staff must adhere to the facility's infection control policy and procedures when assisting with the self-administration of medication. This Statute or Rule is not met as evidenced by: Based on observation and interview, the facility failed to ensure 2 of 3 sampled residents received proper assistance with self-administration of medication by failing to orally advise the residents of the medication	A 052			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910267	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 10/07/2025
NAME OF PROVIDER OR SUPPLIER BROOKDALE CHAMBREL PINECASTLE			STREET ADDRESS, CITY, STATE, ZIP CODE 1801 SE 24TH ROAD OCALA, FL 34471		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 052	Continued From page 4 name and dosage, Resident #16 and Resident #17. Findings include: During an observation conducted on 10/07/25 beginning at 08:34 AM, Staff D, Licensed Practical Nurse (LPN) did not orally advise Resident #16 of the medication names and dosages before handing her a cup of pills. During an observation conducted on 10/07/25 beginning at 08:46 AM, Staff D did not orally advise Resident #17 of the medication names and dosages before handing her a cup of pills. During an interview conducted on 10/07/25 at 09:08 AM, Staff D stated that the residents seen today all know their medications and will ask her if they want to be reminded of what they are taking. She stated that she does not always tell residents what they are taking. During an interview conducted on 10/07/25 at 01:12 PM, the Health and Wellness Coordinator said, "The majority of our residents know their medications and can recognize the size and shape. Personally, yes, I think they [the staff] should tell them what they are taking." When asked if any residents have signed a waiver to opt out of being orally advised of the medication names and dosages, she said, "No, as far as I am aware." Review of facility policies titled "Medication & Treatment - General Guidelines for Medication Administration/Assistance," revised 09/2025, and "Medication & Treatment - Administration/Assistance," revised 07/2024, revealed no mention of orally advising residents	A 052			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910267	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 10/07/2025
NAME OF PROVIDER OR SUPPLIER BROOKDALE CHAMBREL PINECASTLE			STREET ADDRESS, CITY, STATE, ZIP CODE 1801 SE 24TH ROAD OCALA, FL 34471		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 052	Continued From page 5 of medication name and dosage when staff provide assistance with medication self-administration. Class III	A 052			
A 200	59A-36.025 FAC Emergency Environmental Control 59A-36.025 Emergency Environmental Control for Assisted Living Facilities. (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the assisted living facility, to ensure that current licensees of assisted living facilities will be equipped to ensure ambient air temperatures will be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is appropriate for resident care needs and life safety requirements. For planning purposes, no less than twenty (20) net square feet per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed capacity as the number of residents to be used in the calculation to determine the required square footage. This may include areas that are less	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910267	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 10/07/2025
NAME OF PROVIDER OR SUPPLIER BROOKDALE CHAMBREL PINECASTLE			STREET ADDRESS, CITY, STATE, ZIP CODE 1801 SE 24TH ROAD OCALA, FL 34471		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 6 than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving provider for evacuees when the conditions stated in Section 408.821, F.S. and subsection 59A-36.019(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained. 2. The alternate power source and fuel supply shall be located in an area(s) in accordance with local zoning and the Florida Building Code. 3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly, this rule does not limit the types of systems or equipment that may be used to achieve ambient temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to operate the systems and equipment. a. An assisted living facility in an evacuation zone pursuant to Chapter 252, F. S. must maintain an alternative power source and fuel as required by this subsection at all times when the assisted living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if evacuation is necessary.	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910267	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 10/07/2025
NAME OF PROVIDER OR SUPPLIER BROOKDALE CHAMBREL PINECASTLE			STREET ADDRESS, CITY, STATE, ZIP CODE 1801 SE 24TH ROAD OCALA, FL 34471		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 7 b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly described in the emergency power plan. c. A multistory facility, whose comprehensive emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional equipment so it can safely operate in a location protected from flooding or storm surge damage. (b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the alternate power source to maintain ambient temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours after the loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel storage. 1. Facilities must store minimum amounts of fuel onsite as follows: a. A facility with a licensed capacity of 16 beds or less must store 48 hours of fuel onsite. b. A facility with a licensed capacity of 17 or more beds must store 72 hours of fuel onsite. 2. An assisted living facility located in an area in a declared state of emergency area pursuant to Section 252.36, F.S. that may impact primary power delivery must secure ninety-six (96) hours of fuel. The assisted living facility may utilize	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910267	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 10/07/2025
NAME OF PROVIDER OR SUPPLIER BROOKDALE CHAMBREL PINECASTLE			STREET ADDRESS, CITY, STATE, ZIP CODE 1801 SE 24TH ROAD OCALA, FL 34471		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 8 portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency. 3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule. 4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living facility must develop a plan that includes maximum onsite fuel storage allowable by the ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a carbon monoxide alarm. (2) SUBMISSION OF THE PLAN. (a) Each new assisted living facility shall submit the plan required under this rule prior to obtaining a license. (b) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the county emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally authorized entity. If the plan is maintained in an	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910267	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 10/07/2025
NAME OF PROVIDER OR SUPPLIER BROOKDALE CHAMBREL PINECASTLE			STREET ADDRESS, CITY, STATE, ZIP CODE 1801 SE 24TH ROAD OCALA, FL 34471		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 9 electronic format, assisted living facility staff must be readily available to access and produce the plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within 30 days of the approval of the plan from the county emergency management agency, the assisted living facility shall submit in writing proof of the approval to the Agency for Health Care Administration to assistedliving@ahca.myflorida.com. (c) The assisted living facility shall submit a consumer-friendly summary of the emergency power plan to the Agency. The Agency shall post the summary and notice of the approval and implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the county emergency management agency and update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall, no later than June 1, 2018, have implemented the plan required under this rule. (b) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (c) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan concurrent with any such additions, modifications, alterations, refurbishment, renovations or reconstruction.	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910267	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 10/07/2025
NAME OF PROVIDER OR SUPPLIER BROOKDALE CHAMBREL PINECASTLE			STREET ADDRESS, CITY, STATE, ZIP CODE 1801 SE 24TH ROAD OCALA, FL 34471		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 10 (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can effectively and immediately activate, operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in ambient air temperatures inside the facility. Procedures must address the care of residents occupying the facility during a declared state of emergency, specifically, a description of the methods to be used to mitigate the potential for heat related injury including: 1. The use of cooling devices and equipment; 2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration; 3. Wellness checks by assisted living facility staff to monitor for signs of dehydration and heat injury; and 4. A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy. (b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted living facility staff must be readily available to access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request. (c) The written policies and procedures must be readily available for inspection by each resident;	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910267	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 10/07/2025
NAME OF PROVIDER OR SUPPLIER BROOKDALE CHAMBREL PINECASTLE			STREET ADDRESS, CITY, STATE, ZIP CODE 1801 SE 24TH ROAD OCALA, FL 34471		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 11 each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by law. (6) REVOCATION OF LICENSE, FINES OR SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by Chapter 429, Part I, or Chapter 408, Part II, F.S., including, but not limited to, license revocation, license suspension, and the imposition of administrative fines. (7) COMPREHENSIVE EMERGENCY MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION. (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon the initial submission of the plan to the county emergency management agency that the plan has been submitted for review and approval; 2. Upon final implementation of the plan by the assisted living facility. 3. Annual submissions and approvals of the plan do not require notification to residents or their legal representatives unless a significant modification as defined in Rule 59A-36.019, F.A.C., has been made to the plan. (b) Each assisted living facility must maintain a	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910267	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 10/07/2025
NAME OF PROVIDER OR SUPPLIER BROOKDALE CHAMBREL PINECASTLE			STREET ADDRESS, CITY, STATE, ZIP CODE 1801 SE 24TH ROAD OCALA, FL 34471		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 12 copy of each notification set forth in paragraph (a) above in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the notifications, either in electronic or paper format, upon request. This Statute or Rule is not met as evidenced by: Based on observation, interview, and record review, the facility failed to maintain an alternate power source such as a generator(s), maintained at the assisted living facility. This had the potential to affect all 118 residents currently residing at the facility. Findings include: During an observation on 10/07/25 at 11:30 AM, no alternate power source was observed onsite to provide power to the assisted living facility in the event of the loss of primary electrical power. During an interview on 10/07/25 at 11:30 AM, the Maintenance Director said, "The ALF [assisted living facility] building does not have a generator. The facility has an arrangement to receive portable generators in the event of an emergency, but the ED [Executive Director] knows more about that." During an interview on 10/07/25 at 12:05 PM, the Executive Director explained that the ALF building receives portable generators from the facility's management company in the event of an emergency. He clarified that the ALF building	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910267	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 10/07/2025
NAME OF PROVIDER OR SUPPLIER BROOKDALE CHAMBREL PINECASTLE			STREET ADDRESS, CITY, STATE, ZIP CODE 1801 SE 24TH ROAD OCALA, FL 34471		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 13 does not have a generator currently onsite and said, "there are no portable generators here right now." Review of the facility's "2025 Emergency Manual" read, "Portable Generators (if needed): Coordination of [management company's name] owned portable generators needs to be handled at the direction of Regional Asset Management in advance of and during emergent events. There are 11 [management company's name] owned generators stages in key locations in the East and West Divisions. Each generator has cabling included to accommodate most temporary installations. Transportation of generators will be coordinated between Regional Asset Management and our Fleet Department." Class III	A 200			