

**AGENCY FOR HEALTH CARE
ADMINISTRATION**

PRINTED: 08/31/2018
FORM APPROVED

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965273	(X3) DATE SURVEY COMPLETED 08/15/2018
NAME OF PROVIDER OR SUPPLIER HARBOR INN OF VENICE SOUTH	STREET ADDRESS, CITY, STATE, ZIP CODE 160 RUTLAND ROAD VENICE, FL 34293	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
0000 - Initial Comments An unannounced emergency power plan monitoring visit was conducted ... at Harbor Inn South, an assisted living facility (license number #9691) in Venice, Florida. The following is description of the deficiency. 0200 - Emergency Environmental Control - 58A-5.036 FAC Based on observation, staff interview and review of the facility Emergency Power Plan (EPP) the facility failed to ensure they implemented all the components as described in the EPP. Failing to have gasoline on hand during a weather event can potentially effect the health and well-being of the residents. The findings included: On ... a review of the facility EPP approved by the county on 11/ ... and implemented by the facility on ... For 96 hours the generator will require at least 90 gallons of gasoline. The generator holds 6 gallons of gas, 18 five gallon approved gas cans will be kept on site in an exterior shed. As soon as a hurricane advisory is issued the facility will make sure the tanks are full and will remain full and refill when needed after the emergency. On ... at 11:30 a.m., a tour of the facility was conducted with the Assistant Administrator. She said the facility will have 50 gallons of gasoline on hand. She said the Owner will acquire the rest in the event of an emergency. She confirmed the facility did not have any gasoline as required by their EPP. Class III		