

**AGENCY FOR HEALTH CARE
ADMINISTRATION**

PRINTED: 09/18/2018
FORM APPROVED

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11953246	(X3) DATE SURVEY COMPLETED 08/23/2018
NAME OF PROVIDER OR SUPPLIER MARIBEL PARADISE HOME INC	STREET ADDRESS, CITY, STATE, ZIP CODE 651 EAST 49 STREET HIALEAH, FL 33013	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
0000 - Initial Comments A Complaint Survey (CCR#2018012805) was conducted on 08/23/2018. Maribel Paradise Home Inc. (License # 12258) had a deficiency identified at the time of the survey: 0200 - Emergency Environmental Control - 58A-5.036 FAC Based on observation, record review and interview the facility failed to be in compliance with the emergency power plan. Findings included: During tour of the facility on 08/23/2018 at 12:05 PM observed there was a portable generator with 10 gallons of gasoline stored in the shed in the patio. Observed the facility did not have a working monoxide detector. On 08/23/2018 at 1:05 PM the Administrator that she was going to buy the monoxide detector at the local store. On 08/23/2018 at 1:20 PM the Administrator stated a city ordinance stated that the facility could only keep 10 gallons of gasoline on the premises but she did not have any documentation of the ordinance. Record review revealed the emergency power plan was approved on 08/23/2018 and implemented on 08/23/2018. Emergency power plan stated that the facility would be cooled with fans and air conditioner. Record revealed there were no written policies and procedures to ensure the facility can effectively and immediately operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. On 08/23/2018 at 12:30 PM the Administrator stated that her consultant was preparing the policies and procedures. On 08/23/2018 at 1:14 PM the Administrator that she did not have a portable air conditioner and that she was going to buy one. Class III		