

**AGENCY FOR HEALTH CARE
ADMINISTRATION**

PRINTED: 09/27/2018
FORM APPROVED

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910977	(X3) DATE SURVEY COMPLETED 08/23/2018
NAME OF PROVIDER OR SUPPLIER LAS MERCEDES BOARDING HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 3418 SW 23RD TERRACE MIAMI, FL 33145	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
0000 - Initial Comments A Complaint Investigation (CCR2018012819) was conducted on Las Mercedes Boarding Home (License #5295) had a deficiency at the time of the investigation. 0200 - Emergency Environmental Control - 58A-5.036 FAC Based on record review and interview, the facility failed to develop and implement written policies and procedures to ensure that it can effectively and immediately activate, operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The facility also failed to notify each resident and the resident's legal representative in writing about its Emergency Power Plan (EPP). A review of the facility's (EPP) record on revealed that it did not have a written EPP policies and procedures. The facility also did not have proof of notification having been given to residents. During an interview on at 2:09 PM with Staff C acknowledged the findings. Class III		