

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965204	(X3) DATE SURVEY COMPLETED 09/06/2018
NAME OF PROVIDER OR SUPPLIER RAFFA CORP	STREET ADDRESS, CITY, STATE, ZIP CODE 13961 SW 75 STREET MIAMI, FL 33183	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
0000 - Initial Comments A Generator Monitoring survey was conducted on at Raffa Corp. (license #9688). The facility had a deficiency identified at the time of the survey: 0200 - Emergency Environmental Control - 58A-5.036 FAC Based on observation, and interview, the facility failed to have 48 hours of fuel stored onsite. Findings Include: Observation on at 10:10 AM found the facility did not have 48 hours of fuel stored onsite. Interview conducted on at 10:15 AM, the Administrator confirmed that the facility did not have fuel stored on site. Class III		