

**AGENCY FOR HEALTH CARE
ADMINISTRATION**

PRINTED: 11/06/2018
FORM APPROVED

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966210	(X3) DATE SURVEY COMPLETED 09/19/2018
NAME OF PROVIDER OR SUPPLIER SAN JUDAS LOVE & CARE	STREET ADDRESS, CITY, STATE, ZIP CODE 17715 NW 87 COURT MIAMI LAKES, FL 33018	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
0000 - Initial Comments A generator monitoring survey was conducted on ... at San Judas Love & Care (license # 10450). San Judas Love & Care had deficiencies at the time of the survey. 0200 - Emergency Environmental Control - 58A-5.036 FAC Based on observation and interview, the facility failed to be in compliance with the emergency environmental control requirements. Findings included: Observation on ... at 12:00 pm revealed that the facility had a container of five gallons of gasoline inside of the garage. The facility did not have enough gasoline and/or any fuel in the facility for least 48 hours of energy in case of emergency. Further observations on ... at 12:00 pm revealed that the facility had 2 empty containers of five gallons. Interview on ... at 12:10 pm Staff A stated that the facility has in storage 1 x 5 = 5 gallons, which will be okay for 10 hours. Interview on ... at 12:30 pm Staff A stated that she call AHCA, and they explained her that she did not need to have 15 gallons of gasoline in the facility storage. Class III		