

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967553	(X3) DATE SURVEY COMPLETED 11/28/2018
NAME OF PROVIDER OR SUPPLIER AVA CARES III	STREET ADDRESS, CITY, STATE, ZIP CODE 2318 CHERRY RIDGE LANE BRANDON, FL 33511	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
0000 - Initial Comments Assisted Living Facility On 11/28/2018, a biennial survey was conducted at Ava Cares III (License #11578) an Assisted Living Facility located in Brandon, FL. Deficiencies were identified at the time of the visit. 0085 - Training - Nutrition & Food Service - 58A-5.0191(7) FAC Based on record review and interview, the facility failed to ensure there was a food service designee for the facility. Findings Included: Employee record reviews of the facility employees on 11/28/2018 revealed there were no identified food service designee responsible for the facility's food service and the day-to-day supervision of food service and there were no staff that had received training as a food service designee. An interview conducted on 11/28/2018 at 11:35am with the Administrator. The Administrator confirmed there was no food designee for the facility and there is no staff that received trainings as a food service designee. Class III 0161 - Records - Staff - 429.275(2) FS; 58A-5.024(2) FAC Based on record review and interview the facility failed to conduct and maintain documentation verifying staff participated in elopement drills. Findings Included: Record review of the facility's elopement policy and procedure revealed there was no documentation of Elopement Drills conducted by the facility. Interview conducted on 11/28/2018 at 12:35pm with Staff A revealed the facility does not conduct Elopement Drills as there are no residents that elope from the facility.		

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967553	(X3) DATE SURVEY COMPLETED 11/28/2018
NAME OF PROVIDER OR SUPPLIER AVA CARES III	STREET ADDRESS, CITY, STATE, ZIP CODE 2318 CHERRY RIDGE LANE BRANDON, FL 33511	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
Interview conducted on at 12:42pm with Staff C revealed they have not participated in an elopement drill and the facility does not conduct elopement drills. An interview was conducted on at 12:47pm with the Administrator. The Administrator confirmed the facility had not conducted any elopement drills and there was no documentation of elopement drills. Class III 0200 - Emergency Environmental Control - 58A-5.036 FAC Based on observation, record review and interview the facility failed to install a generator and maintain sufficient fuel supply as per approved emergency power plan. Findings Included: Record review of the facility's approved emergency power plan with an approval date revealed that per the plan, the facility should have installed a 10,000 watt Dual Fuel Generator and maintained sufficient fuel supply. An observation was conducted on at 12:15pm of a white box with "DuroMax Duel Fuel generator" written on the box. An interview was conducted on at 12:24pm with the Administrator. The Administrator confirmed the box contained the generator and the facility had not installed the generator approved in their approved emergency power plan. The Administrator also confirmed they do not have sufficient fuel supply stored at the facility. Class III		