

**AGENCY FOR HEALTH CARE
ADMINISTRATION**

PRINTED: 01/03/2019
FORM APPROVED

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968413	(X3) DATE SURVEY COMPLETED R 11/20/2018
NAME OF PROVIDER OR SUPPLIER PLANTATION OAKS SENIOR LIVING	STREET ADDRESS, CITY, STATE, ZIP CODE 9309 S ORANGE BLOSSOM TRAIL ORLANDO, FL 32837	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
0000 - Initial Comments A revisit to a monitoring visit was conducted on 11/20/2018. Plantation Oaks Senior Living license # 12300 had a deficiency found at the time of the visit. 0030 - Resident Care - Rights & Facility Procedures - 58A-5.0182(6) FAC; 429.28() FS Based on observation, interview and record review, the facility failed to honor resident's rights to be treated with respect and did not post and make residents, families and visitors aware the facility was under water restrictions because of a _____ (Legionnaire's _____, a form of _____) outbreak. Findings: A tour of the facility on _____ at 9 AM noted that there were not any signs posted alerting residents, family or visitors of the water restriction because of _____ (Legionnaire's _____) outbreak. In an interview on _____ at 9:20 AM with the administrator said high power showers were installed in each bathroom, contacted DOH to make them aware and get approval from them. Should get letter of clearance today. During this time all restrictions were maintained as before, nothing was changed. An e-mail from the administrator was not received. An e-mail from the facility owner was received by the local area office on _____ at 12 PM. The e-mail contained an attachment, a letter dated _____ from DOH. The letter indicated DOH in Orange County received a request by the administration of the facility to notify the Agency of the status of the re-inspection pending for the facility. DOH has been in contact with the administration of the facility and are currently working through the water management plan developed by the facility and consultants. The facility recently replaced their water heater as part of the remediation process and DOH have granted an extension of the re-inspection while they work on the remediation and following the water management plan. The facility is still under water restrictions, as they have not been cleared by DOH to be free of _____ in the water system. Class III		