

**AGENCY FOR HEALTH CARE
ADMINISTRATION**

PRINTED: 01/08/2019
FORM APPROVED

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11953545	(X3) DATE SURVEY COMPLETED 11/29/2018
NAME OF PROVIDER OR SUPPLIER SEA VIEW INN AT FOREST LAKES	STREET ADDRESS, CITY, STATE, ZIP CODE 3548 SEA VIEW STREET SARASOTA, FL 34239	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
0000 - Initial Comments An unannounced emergency power plan monitoring survey was conducted on at Sea View Inn at Forest Lakes, an assisted living facility (license #8290) in Sarasota Florida. The following is a description of the deficiency. 0200 - Emergency Environmental Control - 58A-5.036 FAC Based on observation and staff interview, the facility failed to ensure compliance with the Emergency Environmental Control Plan for assisted living facilities. The findings included: On at approximately 2:15 p.m., record review revealed no evidence of an approved emergency power plan. On at approximately 2:35 p.m., the facility designee confirmed the facility does not have an approved emergency power plan at this time. She said the plan was originally submitted to the county last year, resubmitted to the county on and they are awaiting approval. On at approximately 2:25 p.m., observation revealed no evidence of a monoxide detector in the facility. This was confirmed at the time of the observation by the facility designee. On at approximately 2:30 p.m. the facility designee confirmed there was no monoxide detector in the facility and said one will "Be installed next week." Class III		