

**AGENCY FOR HEALTH CARE
ADMINISTRATION**

PRINTED: 01/31/2019
FORM APPROVED

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11965138	(X3) DATE SURVEY COMPLETED 01/03/2019
NAME OF PROVIDER OR SUPPLIER BROOKDALE DR PHILLIPS AL	STREET ADDRESS, CITY, STATE, ZIP CODE 8001 PIN OAK DRIVE ORLANDO, FL 32819	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
0000 - Initial Comments An unannounced monitoring visit related to emergency environmental control plan was conducted on Brookdale Dr Phillips Assisted Living Facility, had a deficiency at the time of the visit. 0200 - Emergency Environmental Control - 58A-5.036 FAC Based on record reviews, observation and interviews the facility failed to ensure the safety of residents by completing all components of the emergency environmental action plan. Findings include: On at 1:00 p.m. during an interview and tour of the facility, the agency did not observe any equipment to provide alternative power source during an emergency. Interview with the administrator revealed they were in the process of obtaining quotes and installation for the alternate power source. Class III		