

**AGENCY FOR HEALTH CARE
ADMINISTRATION**

PRINTED: 01/31/2019
FORM APPROVED

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11964948	(X3) DATE SURVEY COMPLETED 01/03/2019
NAME OF PROVIDER OR SUPPLIER BROOKDALE DR PHILLIPS MC	STREET ADDRESS, CITY, STATE, ZIP CODE 8015 PIN OAK DR. ORLANDO, FL 32819	

SUMMARY STATEMENT OF DEFICIENCIES
(FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)

0000 - Initial Comments

An unannounced monitoring visit related to emergency environmental control plan was conducted on Brookdale Dr Phillips Memory Care Unit, had a deficiency at the time of the visit.

0200 - Emergency Environmental Control - 58A-5.036 FAC

Based on record reviews, observation and interviews the facility failed to ensure the safety of residents by completing all components of the emergency environmental action plan.

Findings include:

On at 2:30 p.m. during an interview and tour of the facility, the agency did not observe any equipment to provide alternative power source during an emergency. Interview with the administrator revealed they were in the process of obtaining quotes and installation for the alternate power source.

Class III