

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11967228	(X3) DATE SURVEY COMPLETED 12/27/2018
NAME OF PROVIDER OR SUPPLIER THORNTON GARDENS III	STREET ADDRESS, CITY, STATE, ZIP CODE 3119 FLORENE DRIVE ORLANDO, FL 32806	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
0000 - Initial Comments An unannounced monitoring visit related to emergency environmental control planning was conducted at Thorton Gardens III (license #11269) on Deficient practices were found at the time of the visit. 0200 - Emergency Environmental Control - 58A-5.036 FAC Based on interview, record review and observation, the facility failed to ensure the safety of residents by completing all components of the emergency environmental action plan. Findings: During the review of records on, at 12:45 p.m. the emergency management plan was requested. No written plan could be produced. Interview with the attendant revealed that no generator, spot coolers or fuel was on site and no training had been conducted to respond to a power outage.		