

**AGENCY FOR HEALTH CARE
ADMINISTRATION**

PRINTED: 02/21/2019
FORM APPROVED

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911311	(X3) DATE SURVEY COMPLETED 01/09/2019
NAME OF PROVIDER OR SUPPLIER FLORIDA SHORES OF MELBOURNE 1 ALF	STREET ADDRESS, CITY, STATE, ZIP CODE 2155 KEYSTONE AVENUE MELBOURNE, FL 32904	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
0000 - Initial Comments An unannounced monitoring visit related to emergency environmental control planning was conducted on Florida Shores of Melbourne (license #7324) had deficiencies at the time of the visit. 0181 - Emergency Plan Approval - 58A-5.026(2) FAC Based on interview and record review, the facility failed to submit a Comprehensive Emergency Management Plan (CEMP) for approval by Brevard County. Findings: During the review of records on , at approximately 11:00 am, the CEMP approval letter was reviewed. The letter was dated No more recent letter could be produced. Class III 0200 - Emergency Environmental Control - 58A-5.036 FAC Based on interview and record review, the facility failed to ensure the safety of residents by completing all components of the emergency environmental action plan. Findings: During the review of records on , at 10:45 a.m. the emergency power plan was requested. The plan was incomplete. The generator was in place and a propane tank was on-site but the propane was not connected to the generator due to delays in installation and permitting. Class III		