STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X3) DATE SURVEY COMPLETED
	AL11966197	R **03/20/2019**
NAME OF PROVIDER OR SUPPLIER **EDEN MANOR**	STREET ADDRESS, CITY, STATE, ZIP CODE **5047 CLARCONA OCOEE ROAD** **ORLANDO, FL 32810**	

SUMMARY STATEMENT OF DEFICIENCIES
(FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)

0000 - Initial Comments

An unannounced monitoring revisit related to emergency environmental control plan was conducted on . . . . . Eden Manor, had deficient practice at the time of the monitoring visit.

0200 - Emergency Environmental Control - 58A-5.036 FAC

Based on record reviews, observation and interviews the facility failed to ensure the safety of residents by completing all components of the emergency environmental action plan.

Findings include:

On at 10:00 a.m. during an interview with staff and tour of the facility, the agency observed a generator in the garage area. Interview with the staff revealed they were unaware of how to operate the backup emergency generator.

Class III