

**AGENCY FOR HEALTH CARE
ADMINISTRATION**

PRINTED: 04/16/2019
FORM APPROVED

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966307	(X3) DATE SURVEY COMPLETED R 04/01/2019
NAME OF PROVIDER OR SUPPLIER HUDSON MANOR	STREET ADDRESS, CITY, STATE, ZIP CODE 115 EAST DAVIS BLVD TAMPA, FL 33606	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
0000 - Initial Comments ASSISTED LIVING FACILITY A revisit to a biennial survey was conducted at Hudson Manor (Assisted Living Facility) on . At the time of the revisit, the facility had deficient practice. Lic #10528 0200 - Emergency Environmental Control - 58A-5.036 FAC Based on record review and interview, the facility did not implement their emergency power plan by , , and has not implemented their emergency power plan and purchased monoxide detectors as of , , . Findings included: During the facility tour on , from 9:45am to 10:30am, no monoxide detectors were observed in the facility. The Administrator stated on at 12:00 pm that the monoxide detectors will be provided when the generator is installed -- generator is on premises, need to prep ground for generator, electricity is hooked up, need to hook up wiring to the generator once installed. On , the Director of Operations provided additional documentation of progress regarding the generator and stated that the facility is waiting on the local authority who is currently processing the permit to complete the installation -- stated that it will be completed within 30 days and monoxide detectors will be installed when the generator is installed and will be purchased for each floor. Record review of the emergency power plan on revealed the plan was approved on . The facility did not apply for an extension until , four and one-half months after the power plan was supposed to be implemented. The facility sent in the extension notification and asked for an extension until , but the extension date for assisted living facilities was . As of , there was no approval notice for an extension until and the facility had not implemented their power plan as of . Uncorrected Class III		