

**AGENCY FOR HEALTH CARE
ADMINISTRATION**

PRINTED: 05/03/2019
FORM APPROVED

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11932435	(X3) DATE SURVEY COMPLETED R 04/18/2019
NAME OF PROVIDER OR SUPPLIER SHARICK'S DECK RETIREMENT RANCH	STREET ADDRESS, CITY, STATE, ZIP CODE 4506 BRUTON ROAD PLANT CITY, FL 33565	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
0000 - Initial Comments A revisit to a biennial survey with limited mental health (LMH) was conducted at Sharick's Deck Retirement Ranch on . A deficiency was found at the time of the survey. 0200 - Emergency Environmental Control - 58A-5.036 FAC Based on observation interview and attempted record review, the facility failed to obtain approval for its emergency environmental control plan (EECP) from the local emergency management agency and failed to acquire an alternate power source with required amount of fuel. Findings included: An interview was conducted with the Administrator at 10:50 AM on concerning the facility's EECP. The Administrator stated that they had not received approval yet for their EECP. No documentation of approval of the plan was provided during survey. The Administrator stated on at the same time that they had not yet obtained an alternate power source and the fuel needed to maintain it for the minimum required amount of time. No power source or fuel was observed throughout the survey. Class III		