

**AGENCY FOR HEALTH CARE
ADMINISTRATION**

PRINTED: 05/30/2019
FORM APPROVED

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11953542	(X3) DATE SURVEY COMPLETED 04/16/2019
NAME OF PROVIDER OR SUPPLIER PALMS OF LONGWOOD (THE)	STREET ADDRESS, CITY, STATE, ZIP CODE 480 EAST CHURCH AVENUE LONGWOOD, FL 32750	
SUMMARY STATEMENT OF DEFICIENCIES (FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)		
0000 - Initial Comments A complaint investigation #2019001599 was conducted at The Palms of Longwood Assisted Living Facility, License #5315 on . The facility had a deficiency at the time of the survey. 0200 - Emergency Environmental Control - 58A-5.036 FAC Based on observation and interview, the facility failed to have an alternate power source (generator) on the premises to provide air temperatures that will maintained at below 81 degrees Fahrenheit for a minimum of ninety-six (96 hours) in the event of the loss of primary electrical power and there was no monoxide detector alarm installed; and the facility failed to maintain a copy of its approved Emergency Power Plan (EPP) readily available for review by the Agency; and the facility failed to notify in writing each resident and the resident's legal representative within five (5) business days for submission of the plan to the local emergency management agency and that the plan had been submitted for review and approval as required. Findings: During an observation on at 3:30 PM, there was no alternate power source (generator) onsite and no monoxide detector on the premises. In conversation with the Administrator and Maintenance Director who both stated that there was no generator on site at the facility and waiting on their big generator they ordered last . In addition, the Administrator asked to provide a copy of the Emergency Power Plan (EPP) and she said she did not have one. There was no documented evidence that the required letters sent to the residents or the resident's legal representative regarding submission of the plan within 5 days to the local emergency management agency and no letters sent to residents or resident's legal representative of the EPP approval. On at 4:30 PM, during exit interview with the Administrator, Director of Marketing, and the Director of Nursing they confirmed the finding. Class III		