

**AGENCY FOR HEALTH CARE
ADMINISTRATION**

PRINTED: 05/30/2019
FORM APPROVED

STATEMENT OF DEFICIENCIES	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11968537	(X3) DATE SURVEY COMPLETED 04/18/2019
NAME OF PROVIDER OR SUPPLIER ELITE MANOR-KISSIMMEE	STREET ADDRESS, CITY, STATE, ZIP CODE 4034 SUNNY DAY WAY KISSIMMEE, FL 34744	

SUMMARY STATEMENT OF DEFICIENCIES
(FINDINGS PRECEDED BY TAGS AND REGULATORY IDENTIFYING INFORMATION)

0000 - Initial Comments

An unannounced monitoring visit related to emergency environmental control plan was conducted at Elite Manor, located in Kissimmee, Florida on Deficient practice was found at the time of the monitoring visit.

0200 - Emergency Environmental Control - 58A-5.036 FAC

Based on record reviews, observation and interviews the facility failed to ensure the safety of residents by completing all components of the emergency environmental action plan.

Findings include:

On at 1:30 p.m. during an interview with the Care Giver and tour of the facility, the agency representative observed a generator in the garage area. Interview with the Care Giver revealed they have not been trained on the operation of the backup emergency generator. A request was also made for the facility's approved Emergency Power Plan, at which time the Care Giver was unable to provide a copy.

Class III