

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910758	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/20/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

WIRICK (THE)

**434 4TH STREET, NORTH
SAINT PETERSBURG, FL 33701**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 000	Initial Comments A monitoring visit was conducted at The Wirick on Deficiencies were identified at the time of the survey.	A 000		
A 160 SS=D	58A-5.024(1) FAC Records - Facility The facility must maintain required records in a manner that makes such records readily available at the licensee's physical address for review by a legally authorized entity. If records are maintained in an electronic format, facility staff must be readily available to access the data and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce documents, records, or other such data, either in electronic or paper format, upon request. (1) FACILITY RECORDS. Facility records must include: (a) The facility's license displayed in a conspicuous and public place within the facility. (b) An up-to-date admission and discharge log listing the names of all residents and each resident's: 1. Date of admission, the facility or place from which the resident was admitted, and if applicable, a notation indicating that the resident was admitted with a; and 2. Date of discharge, reason for discharge, and identification of the facility or home address to which the resident was discharged. Readmission of a resident to the facility after discharge requires a new entry in the log. Discharge of a resident is not required if the facility is holding a bed for a resident who is out of the facility but intending to return pursuant to Rule 58A-5.025, F.A.C. If the resident dies while in the care of the facility, the log must indicate the date of (c) A log listing the names of all temporary	A 160		

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910758	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/20/2019
NAME OF PROVIDER OR SUPPLIER WIRICK (THE)		STREET ADDRESS, CITY, STATE, ZIP CODE 434 4TH STREET, NORTH SAINT PETERSBURG, FL 33701	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) (X5) COMPLETE DATE
A 160	Continued From page 1 emergency placement and respite care residents if not included on the log described in paragraph (b). (d) The facility's emergency management plan, with documentation of review and approval by the county emergency management agency, as described in Rule 58A-5.026, F.A.C., that must be readily available by facility staff. (e) The facility's liability insurance policy required in Rule 58A-5.021, F.A.C.; (f) For facilities that have a surety bond, a copy of the surety bond currently in effect as required by Rule 58A-5.021, F.A.C. (g) The admission package presented to new or prospective residents (less the resident's contract) described in Rule 58A-5.0181, F.A.C. (h) If the facility advertises that it provides special care for persons with _____'s _____ or related _____, a copy of all such facility advertisements as required by Section 429.177, F.S. (i) A grievance procedure for receiving and responding to resident complaints and recommendations as described in Rule 58A-5.0182, F.A.C. (j) All food service records required in Rule 58A-5.020, F.A.C., including menus planned and served and county health department inspection reports. Facilities that contract for food services, must include a copy of the contract for food services and the food service contractor's license or certificate to operate. (k) All fire safety inspection reports issued by the local authority or the State Fire Marshal pursuant to Section 429.41, F.S., and Rule Chapter 69A-40, F.A.C., issued within the last 2 years. (l) All sanitation inspection reports issued by the county health department pursuant to Section 381.031, F.S., and Chapter 64E-12, F.A.C.,	A 160	

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910758	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/20/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

WIRICK (THE)

**434 4TH STREET, NORTH
SAINT PETERSBURG, FL 33701**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 160	Continued From page 2 issued within the last 2 years. (m) Pursuant to Section 429.35, F.S., all completed survey, inspection and complaint investigation reports, and notices of sanctions and moratoriums issued by the agency within the last 5 years. (n) The facility's resident elopement response policies and procedures. (o) The facility's documented resident elopement response drills. (p) For facilities licensed as limited mental health, extended congregate care, or limited nursing services, records required as stated in Rules 58A-5.029, 58A-5.030 and 58A-5.031, F.A.C., respectively. This Statute or Rule is not met as evidenced by: Based on record review and interview, the facility did not maintain all required fire safety inspection reports issued by the local authority or the State Fire Marshal. Findings included: During the monitoring visit, a review of the facility's latest fire department visit report from indicated approximately six (6) pending violations that required follow-up. Further review of this document found that the facility was given until to correct these concerns. However, no subsequent visit report could be located. Interview with the administrator at 1:25pm on revealed that "although his facility had addressed all of the issues, the fire department had not yet come out, and he hadn't called them to let them know his facility was ready for a revisit." Thus, the facility had not obtained all required inspection reports by the date of the monitoring visit.	A 160		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910758	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/20/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

WIRICK (THE)

**434 4TH STREET, NORTH
SAINT PETERSBURG, FL 33701**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 160	Continued From page 3 Class III	A 160		
A 181 SS=D	58A-5.026(2) FAC Emergency Plan Approval (2) EMERGENCY PLAN APPROVAL. The plan must be submitted for review and approval to the local emergency management agency. (a) If the local emergency management agency requires revisions to the emergency management plan, such revisions must be made and the plan resubmitted to the local office within 30 days of receiving notification that the plan must be revised. (b) A new facility as described in Rule 58A-5.023, F.A.C., and facilities whose ownership has been transferred, must submit an emergency management plan within 30 days after obtaining a license. (c) The facility must review its emergency management plan on an annual basis. Any substantive changes must be submitted to the local emergency agency for review and approval. 1. Changes in the name, address, telephone number, or position of staff listed in the plan are not considered substantive revisions for the purposes of this rule. 2. Changes in the identification of specific staff must be submitted to the local emergency management agency annually as a signed and dated addendum that is not subject to review and approval. (d) The local emergency management agency is the final administrative authority for emergency management plans prepared by assisted living facilities. (e) Any plan approved by the local emergency management agency is considered to have met all the criteria and conditions established in this rule.	A 181		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910758	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/20/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

WIRICK (THE)

**434 4TH STREET, NORTH
SAINT PETERSBURG, FL 33701**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 181	Continued From page 4 This Statute or Rule is not met as evidenced by: Based on record review and interview, the facility did not have an emergency management plan that had been officially reviewed and approved by the local emergency management agency. Findings include: Review of an emergency management plan furnished by the administrator during the _____ monitoring visit found a document from _____ that had not been formally reviewed and approved by a third party. Interview with the administrator at 1:15pm on _____ indicated that he was unable to find a copy of his facility's most recent emergency management plan that had been reviewed and approved by the local emergency management office. Class III	A 181		
A 200 SS=G	58A-5.036 FAC Emergency Environmental Control (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the assisted living facility, to ensure that current licensees of assisted living facilities will be equipped to ensure _____ air temperatures will	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910758	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/20/2019
NAME OF PROVIDER OR SUPPLIER WIRICK (THE)		STREET ADDRESS, CITY, STATE, ZIP CODE 434 4TH STREET, NORTH SAINT PETERSBURG, FL 33701	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)
A 200	Continued From page 5 be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is appropriate for resident care needs and life safety requirements. For planning purposes, no less than twenty (20) net square per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed capacity as the number of residents to be used in the to determine the required square footage. This may include areas that are less than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving provider for evacuees when the conditions stated in Section 408.821, F.S., and subsection 58A-5.026(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained. 2. The alternate power source and fuel supply shall be located in an area(s) in accordance with local zoning and the Florida Building Code. 3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly, this rule does not limit the types of systems or	A 200	

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910758	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/20/2019
NAME OF PROVIDER OR SUPPLIER WIRICK (THE)		STREET ADDRESS, CITY, STATE, ZIP CODE 434 4TH STREET, NORTH SAINT PETERSBURG, FL 33701	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)
A 200	Continued From page 6 equipment that may be used to achieve temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to operate the systems and equipment. a. An assisted living facility in an evacuation zone pursuant to Chapter 252, F.S., must maintain an alternative power source and fuel as required by this subsection at all times when the assisted living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if evacuation is necessary. b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly described in the emergency power plan. c. A multistory facility, whose comprehensive emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional equipment so it can safely operate in a location protected from flooding or storm surge damage. (b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the alternate power source to maintain temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours after the	A 200	

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910758	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/20/2019
NAME OF PROVIDER OR SUPPLIER WIRICK (THE)		STREET ADDRESS, CITY, STATE, ZIP CODE 434 4TH STREET, NORTH SAINT PETERSBURG, FL 33701	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) (X5) COMPLETE DATE
A 200	Continued From page 7 loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel storage. 1. Facilities must store minimum amounts of fuel onsite as follows: a. A facility with a licensed capacity of 16 beds or less must store 48 hours of fuel onsite. b. A facility with a licensed capacity of 17 or more beds must store 72 hours of fuel onsite. 2. An assisted living facility located in an area in a declared state of emergency area pursuant to Section 252.36, F.S., that may impact primary power delivery must secure ninety-six (96) hours of fuel. The assisted living facility may utilize portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency. 3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule. 4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living facility must develop a plan that includes maximum onsite fuel storage allowable by the ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a _____ monoxide alarm. (2) SUBMISSION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall submit its plan	A 200	

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910758	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/20/2019
NAME OF PROVIDER OR SUPPLIER WIRICK (THE)		STREET ADDRESS, CITY, STATE, ZIP CODE 434 4TH STREET, NORTH SAINT PETERSBURG, FL 33701	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)
A 200	Continued From page 8 to the local emergency management agency for review within 30 days of the effective date of this rule. Assisted living facility plans previously submitted and approved pursuant to Emergency Rule 58AER17-1, F.A.C., will require resubmission only if changes are made to the plan. (b) Each new assisted living facility shall submit the plan required under this rule prior to obtaining a license. (c) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the local emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally authorized entity. If the plan is maintained in an electronic format, assisted living facility staff must be readily available to access and produce the plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within two (2) business days of the approval of the plan from the local emergency management agency, the assisted living facility shall submit in writing proof of the approval to the Agency for Health Care Administration. (c) The assisted living facility shall submit a consumer-friendly summary of the emergency power plan to the Agency. The Agency shall post the summary and notice of the approval and	A 200	

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910758	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 06/20/2019
NAME OF PROVIDER OR SUPPLIER WIRICK (THE)		STREET ADDRESS, CITY, STATE, ZIP CODE 434 4TH STREET, NORTH SAINT PETERSBURG, FL 33701		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 9 implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the local emergency management agency and update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall, no later than _____, have implemented the plan required under this rule. (b) The Agency shall allow an extension to _____ to providers in compliance with subsection (c), below, and who can show delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes. Assisted living facilities shall notify the Agency that they will utilize the extension and keep the Agency apprised of progress on a quarterly basis to ensure there are no unnecessary delays. If an assisted living facility can show in its quarterly progress reports that unavoidable delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes will occur beyond the initial extension date, the assisted living facility may request a waiver pursuant to Section 120.542, F.S. (c) During the extension period, an assisted living facility must make arrangements pending full implementation of its plan that provides the residents with an area or areas to congregate that meets the safe indoor air temperature requirements of paragraph (1)(a), for a minimum of ninety-six (96) hours. 1. An assisted living facility not located in an evacuation zone must either have an alternative power source onsite or have a contract in place for delivery of an alternative power source and	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910758	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 06/20/2019
NAME OF PROVIDER OR SUPPLIER WIRICK (THE)		STREET ADDRESS, CITY, STATE, ZIP CODE 434 4TH STREET, NORTH SAINT PETERSBURG, FL 33701			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 10 fuel when requested. Within twenty-four (24) hours of the issuance of a state of emergency for an event that may impact primary power delivery for the area of the assisted living facility, it must have the alternative power source and no less than ninety-six (96) hours of fuel stored onsite. 2. An assisted living facility located in an evacuation zone pursuant to Chapter 252, F.S., must either: a. Fully and safely evacuate its residents prior to the arrival of the event, or b. Have an alternative power source and no less than ninety-six (96) hours of fuel stored onsite, within twenty-four (24) hours of the issuance of a state of emergency for the area of the assisted living facility. (d) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (e) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan concurrent with any such additions, modifications, alterations, refurbishment, renovations or reconstruction. (f) The Agency for Health Care Administration may request cooperation from the State Fire Marshal to conduct inspections to ensure implementation of the plan in compliance with this rule. (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can effectively and immediately activate, operate and maintain the alternate power source and any fuel	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910758	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 06/20/2019
NAME OF PROVIDER OR SUPPLIER WIRICK (THE)			STREET ADDRESS, CITY, STATE, ZIP CODE 434 4TH STREET, NORTH SAINT PETERSBURG, FL 33701		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 11 required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in air temperatures inside the facility. Procedures must address the care of residents occupying the facility during a declared state of emergency, specifically, a description of the methods to be used to mitigate the potential for heat related injury including: 1. The use of cooling devices and equipment; 2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration; 3. Wellness checks by assisted living facility staff to monitor for signs of ... and heat injury; and, 4. A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy. (b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted living facility staff must be readily available to access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request. (c) The written policies and procedures must be readily available for inspection by each resident; each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by law. (6) REVOCATION OF LICENSE, FINES OR	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910758	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 06/20/2019
NAME OF PROVIDER OR SUPPLIER WIRICK (THE)			STREET ADDRESS, CITY, STATE, ZIP CODE 434 4TH STREET, NORTH SAINT PETERSBURG, FL 33701		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
A 200	Continued From page 12 SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by Chapter 429, Part I, F.S., or Chapter 408, Part II, F.S., including, but not limited to, license revocation, license suspension, and the imposition of administrative fines. (7) COMPREHENSIVE EMERGENCY MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION. (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon submission of the plan to the local emergency management agency that the plan has been submitted for review and approval; 2. Upon final implementation of the plan by the assisted living facility. (b) Each assisted living facility must maintain a copy of each notification set forth in paragraph (a), above, in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the notifications, either in electronic or paper format, upon request.	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11910758	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/20/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

WIRICK (THE)

**434 4TH STREET, NORTH
SAINT PETERSBURG, FL 33701**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 13 This Statute or Rule is not met as evidenced by: Based on interview and observation, the facility failed to have an implemented emergency power plan, nor did it maintain an alternative power source or monoxide detector on the premises. Findings included: Interview with the administrator at 10:00am by telephone and in person at 12:25pm on _____ revealed that he had not yet written an emergency power plan for the facility. The Administrator stated he wasn't sure how he would be able to acquire a generator that would specifically meet his needs and those of his residents. Further interview with the administrator found that no alternative power source had been purchased whatsoever, and no monoxide detector was on the premises. During the tour of the facility from 12:45pm to 2pm, no generator or monoxide detector were observed. A follow-up interview was conducted with the administrator at 2:20pm on _____ provided no explanation other than "he wasn't sure who to talk to" or "he was _____ about the requirements of the new law." Class II	A 200		