

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
CZ816	408.809(2)(a-c); 59A-35.090(2)(d)-(3) Background Screening-Compliance Attestation 408.809 (2) Every 5 years following his or her licensure, employment, or entry into a contract in a capacity that under subsection (1) would require level 2 background screening under chapter 435, each such person must submit to level 2 background rescreening as a condition of retaining such license or continuing in such employment or contractual status. For any such rescreening, the agency shall request the Department of Law Enforcement to forward the person's _____ to the Federal Bureau of Investigation for a national criminal history record check unless the person's _____ are enrolled in the Federal Bureau of Investigation's national retained print notification program. If the _____ of such a person are not retained by the Department of Law Enforcement under s. 943.05(2)(g) and (h), the person must submit _____ electronically to the Department of Law Enforcement for state processing, and the Department of Law Enforcement shall forward the _____ to the Federal Bureau of Investigation for a national criminal history record check. The _____ shall be retained by the Department of Law Enforcement under s. 943.05(2)(g) and (h) and enrolled in the national retained print notification program when the Department of Law Enforcement begins participation in the program. The cost of the state and national criminal history records checks required by level 2 screening may be borne by the licensee or the person _____. Until a specified agency is fully implemented in the clearinghouse created under s. 435.12, the agency may accept as satisfying the requirements of this section proof of compliance with level 2 screening standards submitted within _____	CZ816		

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
CZ816	Continued From page 1 the previous 5 years to meet any provider or professional licensure requirements of the agency, the Department of Health, the Department of Elderly Affairs, the Agency for Persons with _____, the Department of Children and Families, or the Department of Financial Services for an applicant for a certificate of authority or provisional certificate of authority to operate a continuing care retirement community under chapter 651, provided that: (a) The screening standards and disqualifying offenses for the prior screening are equivalent to those specified in s. 435.04 and this section; (b) The person subject to screening has not had a break in service from a position that requires level 2 screening for more than 90 days; and (c) Such proof is accompanied, under penalty of perjury, by an attestation of compliance with chapter 435 and this section using forms provided by the agency. 59A-35.090(2) Processing Screening Requests, Required Documents and Fees. (d) An Attestation of Compliance with Background Screening Requirements, AHCA Form 3100-0008, _____, herein incorporated by reference, available at http://www.flrules.org/Gateway/reference.asp?No=Ref-09106, and available from the Agency for Health Care Administration at: http://ahca.myflorida.com/MCHQ/Central_Service/s/Background_Screening/Regulations_Forms.shtml. This form must be completed by the individual and retained by the provider upon hire to attest that they meet the requirements for qualifying for employment, they have not been unemployed for more than 90 days from a position that requires Level 2 screening, and they agree to inform the employer immediately if _____ for any	CZ816		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
CZ816	Continued From page 2 disqualifying offense. (e) An administrator or chief financial officer must be screened and qualified prior to to the position. (3) Results of Screening and Notification. (a) Final results of background screening requests will be provided through the Agency's secure website that may be accessed by all health care providers applying for or actively licensed through the Agency that are registered with the Care Provider Background Screening Clearinghouse. The secure website is located at: apps.ahca.myflorida.com/SingleSignOnPortal. (b) If a Level 2 criminal history is incomplete, a certified letter will be sent to the individual being screened requesting the report and court disposition information. If the letter is returned unclaimed, a copy of the letter will be sent by regular mail. Pursuant to section 435.05(1)(d), F.S., the missing information must be filed with the Agency within 30 days of the Agency's request or the individual is subject to disqualification in accordance with section 435.06(3), F.S. (c) The eligibility results of employee screening and the signed Attestation referenced in subsection 59A-35.090(2), F.A.C., must be in the employee's personnel file, maintained by the employee's personnel file, maintained by the provider. This Statute or Rule is not met as evidenced by: Based on record review and interview the facility failed to maintain the signed attestation in the employee's personnel file for 3 (Administrator, Staff A, and B) of 3 personnel files reviewed. The findings included:	CZ816		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
CZ816	Continued From page 3 The Administrator's personnel file revealed she had been with the facility since opening in 1986. There was no signed attestation in the file. Staff A's personnel file revealed a hire date of . Staff A's personnel file contained no signed attestations. Staff B's personnel file revealed he had been with the facility since opening in 1986. Staff B's personnel file contained no signed attestations. On at 2:30 p.m., the Administrator said she hadn't realized these needed to be in the files. Unclassified	CZ816		
A 000	Initial Comments An unannounced abbreviated biennial with limited nursing services and an emergency power plan monitoring survey was completed on at Kingshouse Retirement Center, an assisted living facility in Labelle, Florida. The following is a description of the deficiencies.	A 000		
A 026	58A-5.0182(2) FAC Resident Care - Social & Leisure Activities (2) SOCIAL AND LEISURE ACTIVITIES. Residents shall be encouraged to participate in social, recreational, educational and other activities within the facility and the community. (a) The facility must provide an ongoing activities program. The program must provide diversified individual and group activities in keeping with each resident's needs, abilities, and interests. (b) The facility must consult with the residents in	A 026		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 026	Continued From page 4 selecting, planning, and scheduling activities. The facility must demonstrate residents' participation through one or more of the following methods: resident meetings, committees, a resident council, a monitored suggestion box, group discussions, questionnaires, or any other form of communication appropriate to the size of the facility. (c) Scheduled activities must be available at least 6 days a week for a total of not less than 12 hours per week. Watching television is not an activity for the purpose of meeting the 12 hours per week of scheduled activities unless the television program is a special one-time event of special interest to residents of the facility. A facility whose residents choose to attend day programs conducted at adult day care centers, senior centers, mental health centers, or other day programs may count those attendance hours towards the required 12 hours per week of scheduled activities. An activities calendar must be posted in common areas where residents normally congregate. (d) If residents assist in planning a special activity such as an outing, seasonal festivity, or an excursion, up to 3 hours may be counted toward the required activity time. This Statute or Rule is not met as evidenced by: Based on observation, record review and interview, the facility failed to provide activities at least 6 days per week for a total of not less than 12 hours per week for 5 (Residents #2, #3, #4, #5, and #6) of 6 residents interviewed. The findings included: On _____ at 11:19 a.m., Resident #2 said the facility provided exercises to do. Resident #2 said other than that you are free to do what you	A 026		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 026	Continued From page 5 want to do. On at 11:45 a.m., Resident #3 said the facility provided exercises to do. Resident #3 said you could also shop. On at 11:45 a.m., Resident #4 said the facility provided exercises like "Other than that we just watch TV all the time. We watch TV and just sit and wait for food. " On at 12:00 p.m., Resident #5 was found in his room. He said this is it. He knows they have exercises, but he doesn't go to that activity. On at 11:20 a.m., Resident #6 said she watches TV, talks to people and knits. Resident #6 said the facility does not have Bingo which she loves. She said they used to have Bingo and used to have entertainment coming in, but no longer. A review of the activity calendar for revealed it had spaces to fill in for which resident participated in which activity offered. The calendar was blank indicating no residents had participated in any activities. On at 1:41 p.m., Staff A who directs the morning activities said they do exercise class, coloring, and go outside to feed squirrels/ birds. He said it was hard for the residents to agree on movies. He said they used to have a church service come in, but that does not occur any more. He said we have coloring once a week, go outside twice a week for roughly an hour, and exercise twice a week for about 40 minutes. That is like 5 days for 5 hours. He agreed that currently the facility only provided 5 hours of activities a week. He said he did not realize it	A 026		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 026	Continued From page 6 was so deficient. Class III	A 026		
A 093	58A-5.020(2) FAC Food Service - Dietary Standards (2) DIETARY STANDARDS. (a) The meals provided by the assisted living facility must be planned based on the current USDA Dietary Guidelines for Americans, 2010, which are incorporated by reference and available for review at: http://www.flrules.org/Gateway/reference.asp?No=Ref-04003 , and the current summary of Dietary Reference Intakes established by the Food and Nutrition Board of the Institute of Medicine of the National Academies, 2010, which are incorporated by reference and available for review at: http://iom.edu/Activities/Nutrition/SummaryDRIs/~media/Files/Activity%20Files/Nutrition/DRIs/New%20Material/5DR1%20Values%20SummaryTables%2014.pdf . Therapeutic diets must meet these nutritional standards to the extent possible. (b) The residents' nutritional needs must be met by offering a variety of meals adapted to the food habits, preferences, and physical abilities of the residents, and must be prepared through the use of standardized recipes. For facilities with a licensed capacity of 16 or fewer residents, standardized recipes are not required. Unless a resident chooses to eat less, the facility must serve the standard minimum portions of food according to the Dietary Reference Intakes. (c) All regular and therapeutic menus to be used by the facility must be reviewed annually by a licensed or registered dietitian, a licensed nutritionist, or a registered dietetic technician	A 093		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 093	Continued From page 7 supervised by a licensed or registered dietitian, or a licensed nutritionist to ensure the meals meet the nutritional standards established in this rule. The annual review must be documented in the facility files and include the original signature of the reviewer, registration or license number, and date reviewed. Portion sizes must be indicated on the menus or on a separate sheet. 1. Daily food servings may be divided among three or more meals per day, including snacks, as necessary to accommodate resident needs and preferences. 2. Menu items may be substituted with items of comparable nutritional value based on the seasonal availability of fresh produce or the preferences of the residents. (d) Menus must be dated and planned at least 1 week in advance for both regular and therapeutic diets. Residents must be encouraged to participate in menu planning. Planned menus must be conspicuously posted or easily available to residents. Regular and therapeutic menus as served, with substitutions noted before or when the meal is served, must be kept on file in the facility for 6 months. (e) Therapeutic diets must be prepared and served as ordered by the health care provider. 1. Facilities that offer residents a variety of food choices through a select menu, buffet style dining, or family style dining are not required to document what is eaten unless a health care provider's order indicates that such monitoring is necessary. However, the food items that enable residents to comply with the therapeutic diet must be identified on the menus developed for use in the facility. 2. The facility must document a resident's refusal to comply with a therapeutic diet and provide notification to the resident's health care provider	A 093		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 06/03/2019
NAME OF PROVIDER OR SUPPLIER KINGSHOUSE RETIREMENT CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 151 SOUTH MISSOURI STREET LA BELLE, FL 33935		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 093	Continued From page 8 of such refusal. (f) For facilities serving three or more meals a day, no more than 14 hours must elapse between the end of an evening meal containing a protein food and the beginning of a morning meal. Intervals between meals must be evenly distributed throughout the day with not less than 2 hours nor more than 6 hours between the end of one meal and the beginning of the next. For residents without access to kitchen facilities, snacks must be offered at least once per day. Snacks are not considered to be meals for the purposes of the time between meals. (g) Food must be served attractively at safe and palatable temperatures. All residents must be encouraged to eat at tables in the dining areas. A supply of eating ware sufficient for all residents, including adaptive equipment if needed by any resident, must be on (h) A 3-day supply of nonperishable food, based on the number of weekly meals the facility has with residents to serve, must be on at all times. The quantity must be based on the resident census and not on licensed capacity. The supply must consist of foods that can be stored safely without refrigeration. Water sufficient for drinking and food preparation must also be stored, or the facility must have a plan for obtaining water in an emergency, with the plan coordinated with and reviewed by the local disaster preparedness authority This Statute or Rule is not met as evidenced by: Based on observation and interview, the facility failed to maintain a 3 day supply of nonperishable foods, based on the number of meals to residents. The facility lacked an adequate milk supply to meet the needs of the 10 residents in house on the day of the survey.	A 093			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 093	Continued From page 9 The findings included: A review of the nonperishable food supply was completed on The facility was found to have only ounce cans of evaporated milk which when reconstituted would be 48 ounces of milk. The facility needed 480 ounces of milk for 10 residents for a 3 day supply. On at 2:00 p.m., the cook said the residents drink gallons of milk a week, plus the milk they use to cook. Class III	A 093		
A 200	58A-5.036 FAC Emergency Environmental Control (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the assisted living facility, to ensure that current licensees of assisted living facilities will be equipped to ensure air temperatures will be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 10 appropriate for resident care needs and life safety requirements. For planning purposes, no less than twenty (20) net square . . . per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed capacity as the number of residents to be used in the to determine the required square footage. This may include areas that are less than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving provider for evacuees when the conditions stated in Section 408.821, F.S., and subsection 58A-5.026(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained. 2. The alternate power source and fuel supply shall be located in an area(s) in accordance with local zoning and the Florida Building Code. 3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly, this rule does not limit the types of systems or equipment that may be used to achieve temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 06/03/2019
NAME OF PROVIDER OR SUPPLIER KINGSHOUSE RETIREMENT CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 151 SOUTH MISSOURI STREET LA BELLE, FL 33935		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 11 operate the systems and equipment. a. An assisted living facility in an evacuation zone pursuant to Chapter 252, F.S., must maintain an alternative power source and fuel as required by this subsection at all times when the assisted living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if evacuation is necessary. b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly described in the emergency power plan. c. A multistory facility, whose comprehensive emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional equipment so it can safely operate in a location protected from flooding or storm surge damage. (b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the alternate power source to maintain temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours after the loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel storage. 1. Facilities must store minimum amounts of fuel onsite as follows: a. A facility with a licensed capacity of 16 beds or	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 12 less must store 48 hours of fuel onsite. b. A facility with a licensed capacity of 17 or more beds must store 72 hours of fuel onsite. 2. An assisted living facility located in an area in a declared state of emergency area pursuant to Section 252.36, F.S., that may impact primary power delivery must secure ninety-six (96) hours of fuel. The assisted living facility may utilize portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency. 3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule. 4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living facility must develop a plan that includes maximum onsite fuel storage allowable by the ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a monoxide alarm. (2) SUBMISSION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall submit its plan to the local emergency management agency for review within 30 days of the effective date of this rule. Assisted living facility plans previously submitted and approved pursuant to Emergency Rule 58AER17-1, F.A.C., will require resubmission only if changes are made to the plan.	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 13 (b) Each new assisted living facility shall submit the plan required under this rule prior to obtaining a license. (c) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the local emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally authorized entity. If the plan is maintained in an electronic format, assisted living facility staff must be readily available to access and produce the plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within two (2) business days of the approval of the plan from the local emergency management agency, the assisted living facility shall submit in writing proof of the approval to the Agency for Health Care Administration. (c) The assisted living facility shall submit a consumer-friendly summary of the emergency power plan to the Agency. The Agency shall post the summary and notice of the approval and implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the local emergency management agency and update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN.	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 14 (a) Each assisted living facility licensed prior to the effective date of this rule shall, no later than _____, have implemented the plan required under this rule. (b) The Agency shall allow an extension up to _____ to providers in compliance with subsection (c), below, and who can show delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes. Assisted living facilities shall notify the Agency that they will utilize the extension and keep the Agency apprised of progress on a quarterly basis to ensure there are no unnecessary delays. If an assisted living facility can show in its quarterly progress reports that unavoidable delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes will occur beyond the initial extension date, the assisted living facility may request a waiver pursuant to Section 120.542, F.S. (c) During the extension period, an assisted living facility must make arrangements pending full implementation of its plan that provides the residents with an area or areas to congregate that meets the safe indoor air temperature requirements of paragraph (1)(a), for a minimum of ninety-six (96) hours. 1. An assisted living facility not located in an evacuation zone must either have an alternative power source onsite or have a contract in place for delivery of an alternative power source and fuel when requested. Within twenty-four (24) hours of the issuance of a state of emergency for an event that may impact primary power delivery for the area of the assisted living facility, it must have the alternative power source and no less than ninety-six (96) hours of fuel stored onsite. 2. An assisted living facility located in an	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 15 evacuation zone pursuant to Chapter 252, F.S., must either: a. Fully and safely evacuate its residents prior to the arrival of the event, or b. Have an alternative power source and no less than ninety-six (96) hours of fuel stored onsite, within twenty-four (24) hours of the issuance of a state of emergency for the area of the assisted living facility. (d) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (e) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan concurrent with any such additions, modifications, alterations, refurbishment, renovations or reconstruction. (f) The Agency for Health Care Administration may request cooperation from the State Fire Marshal to conduct inspections to ensure implementation of the plan in compliance with this rule. (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can effectively and immediately activate, operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in air temperatures inside the facility. Procedures must address the care of residents occupying the facility during a declared state of emergency, specifically, a description of	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 16 the methods to be used to mitigate the potential for heat related injury including: 1. The use of cooling devices and equipment; 2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration; 3. Wellness checks by assisted living facility staff to monitor for signs of _____ and heat injury; and, 4. A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy. (b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted living facility staff must be readily available to access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request. (c) The written policies and procedures must be readily available for inspection by each resident; each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by law. (6) REVOCATION OF LICENSE, FINES OR SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by Chapter 429, Part I, F.S., or Chapter 408, Part II, F.S., including, but not limited to, license revocation, license suspension, and the imposition of administrative fines.	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 17 (7) COMPREHENSIVE EMERGENCY MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION. (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon submission of the plan to the local emergency management agency that the plan has been submitted for review and approval; 2. Upon final implementation of the plan by the assisted living facility. (b) Each assisted living facility must maintain a copy of each notification set forth in paragraph (a), above, in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the notifications, either in electronic or paper format, upon request. This Statute or Rule is not met as evidenced by: Based on observation, interview, and record review, the facility failed to have an Emergency Power Plan (EPP) approved by the local Emergency Management Agency. The facility also failed to ensure an alternate power source such as a generator was readily available at the	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 18 facility to ensure the facility air temperature will be maintained at or below 81 degrees Fahrenheit for a minimum of 96 hours in the event of the loss of primary electrical power. In addition the facility failed to provide evidence of written policies and procedures to ensure the facility can effectively and immediately operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The findings included: On at 11 a.m., Staff C said the facility had received an extension for the EPP until , but currently had no EPP or further extension approved by the county. Staff C said the fixed generator on site was not yet fully operational, but he could run this with an electrical power cord plugged into an outlet. He also said he would power this by unhooking the propane from the stove and use that propane to run the generator. Staff C said a second fixed generator would be arriving in a few weeks. Staff C said there are two portable generators available for use about a mile away from the facility but there was no fuel available at the facility to operate them. Staff C said since they had not yet fully implemented their plan, residents and legal representatives had not been notified. Staff C said there were no written policies or procedures for the alternate power source, as the company installing them would be giving a training on that when fully installed. Staff C said there was no or scheduled maintenance of the 2 new generators set up yet as they are not fully installed and operational yet, and that the two generators off site had no formal maintenance or testing.	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 19 Observation revealed there were no CO2 detectors onsite. On at 11:30 a.m., Staff C said it would be a few weeks until the 2 new fixed generators would be operational. Class III	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
CZ816	408.809(2)(a-c); 59A-35.090(2)(d)-(3) Background Screening-Compliance Attestation 408.809 (2) Every 5 years following his or her licensure, employment, or entry into a contract in a capacity that under subsection (1) would require level 2 background screening under chapter 435, each such person must submit to level 2 background rescreening as a condition of retaining such license or continuing in such employment or contractual status. For any such rescreening, the agency shall request the Department of Law Enforcement to forward the person's _____ to the Federal Bureau of Investigation for a national criminal history record check unless the person's _____ are enrolled in the Federal Bureau of Investigation's national retained print notification program. If the _____ of such a person are not retained by the Department of Law Enforcement under s. 943.05(2)(g) and (h), the person must submit _____ electronically to the Department of Law Enforcement for state processing, and the Department of Law Enforcement shall forward the _____ to the Federal Bureau of Investigation for a national criminal history record check. The _____ shall be retained by the Department of Law Enforcement under s. 943.05(2)(g) and (h) and enrolled in the national retained print notification program when the Department of Law Enforcement begins participation in the program. The cost of the state and national criminal history records checks required by level 2 screening may be borne by the licensee or the person _____. Until a specified agency is fully implemented in the clearinghouse created under s. 435.12, the agency may accept as satisfying the requirements of this section proof of compliance with level 2 screening standards submitted within _____	CZ816		

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
CZ816	Continued From page 1 the previous 5 years to meet any provider or professional licensure requirements of the agency, the Department of Health, the Department of Elderly Affairs, the Agency for Persons with _____, the Department of Children and Families, or the Department of Financial Services for an applicant for a certificate of authority or provisional certificate of authority to operate a continuing care retirement community under chapter 651, provided that: (a) The screening standards and disqualifying offenses for the prior screening are equivalent to those specified in s. 435.04 and this section; (b) The person subject to screening has not had a break in service from a position that requires level 2 screening for more than 90 days; and (c) Such proof is accompanied, under penalty of perjury, by an attestation of compliance with chapter 435 and this section using forms provided by the agency. 59A-35.090(2) Processing Screening Requests, Required Documents and Fees. (d) An Attestation of Compliance with Background Screening Requirements, AHCA Form 3100-0008, _____, herein incorporated by reference, available at http://www.flrules.org/Gateway/reference.asp?No=Ref-09106, and available from the Agency for Health Care Administration at: http://ahca.myflorida.com/MCHQ/Central_Service/s/Background_Screening/Regulations_Forms.shtml. This form must be completed by the individual and retained by the provider upon hire to attest that they meet the requirements for qualifying for employment, they have not been unemployed for more than 90 days from a position that requires Level 2 screening, and they agree to inform the employer immediately if _____ for any	CZ816		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
CZ816	Continued From page 2 disqualifying offense. (e) An administrator or chief financial officer must be screened and qualified prior to _____ to the position. (3) Results of Screening and Notification. (a) Final results of background screening requests will be provided through the Agency's secure website that may be accessed by all health care providers applying for or actively licensed through the Agency that are registered with the Care Provider Background Screening Clearinghouse. The secure website is located at: apps.ahca.myflorida.com/SingleSignOnPortal. (b) If a Level 2 criminal history is incomplete, a certified letter will be sent to the individual being screened requesting the _____ report and court disposition information. If the letter is returned unclaimed, a copy of the letter will be sent by regular mail. Pursuant to section 435.05(1)(d), F.S., the missing information must be filed with the Agency within 30 days of the Agency's request or the individual is subject to disqualification in accordance with section 435.06(3), F.S. (c) The eligibility results of employee screening and the signed Attestation referenced in subsection 59A-35.090(2), F.A.C., must be in the employee's personnel file, maintained by the employee's personnel file, maintained by the provider. This Statute or Rule is not met as evidenced by: Based on record review and interview the facility failed to maintain the signed attestation in the employee's personnel file for 3 (Administrator, Staff A, and B) of 3 personnel files reviewed. The findings included:	CZ816		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
CZ816	Continued From page 3 The Administrator's personnel file revealed she had been with the facility since opening in 1986. There was no signed attestation in the file. Staff A's personnel file revealed a hire date of . Staff A's personnel file contained no signed attestations. Staff B's personnel file revealed he had been with the facility since opening in 1986. Staff B's personnel file contained no signed attestations. On at 2:30 p.m., the Administrator said she hadn't realized these needed to be in the files. Unclassified	CZ816		
A 000	Initial Comments An unannounced abbreviated biennial with limited nursing services and an emergency power plan monitoring survey was completed on at Kingshouse Retirement Center, an assisted living facility in Labelle, Florida. The following is a description of the deficiencies.	A 000		
A 026	58A-5.0182(2) FAC Resident Care - Social & Leisure Activities (2) SOCIAL AND LEISURE ACTIVITIES. Residents shall be encouraged to participate in social, recreational, educational and other activities within the facility and the community. (a) The facility must provide an ongoing activities program. The program must provide diversified individual and group activities in keeping with each resident's needs, abilities, and interests. (b) The facility must consult with the residents in	A 026		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 026	Continued From page 4 selecting, planning, and scheduling activities. The facility must demonstrate residents' participation through one or more of the following methods: resident meetings, committees, a resident council, a monitored suggestion box, group discussions, questionnaires, or any other form of communication appropriate to the size of the facility. (c) Scheduled activities must be available at least 6 days a week for a total of not less than 12 hours per week. Watching television is not an activity for the purpose of meeting the 12 hours per week of scheduled activities unless the television program is a special one-time event of special interest to residents of the facility. A facility whose residents choose to attend day programs conducted at adult day care centers, senior centers, mental health centers, or other day programs may count those attendance hours towards the required 12 hours per week of scheduled activities. An activities calendar must be posted in common areas where residents normally congregate. (d) If residents assist in planning a special activity such as an outing, seasonal festivity, or an excursion, up to 3 hours may be counted toward the required activity time. This Statute or Rule is not met as evidenced by: Based on observation, record review and interview, the facility failed to provide activities at least 6 days per week for a total of not less than 12 hours per week for 5 (Residents #2, #3, #4, #5, and #6) of 6 residents interviewed. The findings included: On _____ at 11:19 a.m., Resident #2 said the facility provided exercises to do. Resident #2 said other than that you are free to do what you	A 026		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 026	Continued From page 5 want to do. On at 11:45 a.m., Resident #3 said the facility provided exercises to do. Resident #3 said you could also shop. On at 11:45 a.m., Resident #4 said the facility provided exercises like "Other than that we just watch TV all the time. We watch TV and just sit and wait for food. " On at 12:00 p.m., Resident #5 was found in his room. He said this is it. He knows they have exercises, but he doesn't go to that activity. On at 11:20 a.m., Resident #6 said she watches TV, talks to people and knits. Resident #6 said the facility does not have Bingo which she loves. She said they used to have Bingo and used to have entertainment coming in, but no longer. A review of the activity calendar for revealed it had spaces to fill in for which resident participated in which activity offered. The calendar was blank indicating no residents had participated in any activities. On at 1:41 p.m., Staff A who directs the morning activities said they do exercise class, coloring, and go outside to feed squirrels/ birds. He said it was hard for the residents to agree on movies. He said they used to have a church service come in, but that does not occur any more. He said we have coloring once a week, go outside twice a week for roughly an hour, and exercise twice a week for about 40 minutes. That is like 5 days for 5 hours. He agreed that currently the facility only provided 5 hours of activities a week. He said he did not realize it	A 026		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 026	Continued From page 6 was so deficient. Class III	A 026		
A 093	58A-5.020(2) FAC Food Service - Dietary Standards (2) DIETARY STANDARDS. (a) The meals provided by the assisted living facility must be planned based on the current USDA Dietary Guidelines for Americans, 2010, which are incorporated by reference and available for review at: http://www.flrules.org/Gateway/reference.asp?No=Ref-04003 , and the current summary of Dietary Reference Intakes established by the Food and Nutrition Board of the Institute of Medicine of the National Academies, 2010, which are incorporated by reference and available for review at: http://iom.edu/Activities/Nutrition/SummaryDRIs/~media/Files/Activity%20Files/Nutrition/DRIs/New%20Material/5DR1%20Values%20SummaryTables%2014.pdf . Therapeutic diets must meet these nutritional standards to the extent possible. (b) The residents' nutritional needs must be met by offering a variety of meals adapted to the food habits, preferences, and physical abilities of the residents, and must be prepared through the use of standardized recipes. For facilities with a licensed capacity of 16 or fewer residents, standardized recipes are not required. Unless a resident chooses to eat less, the facility must serve the standard minimum portions of food according to the Dietary Reference Intakes. (c) All regular and therapeutic menus to be used by the facility must be reviewed annually by a licensed or registered dietitian, a licensed nutritionist, or a registered dietetic technician	A 093		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 093	Continued From page 7 supervised by a licensed or registered dietitian, or a licensed nutritionist to ensure the meals meet the nutritional standards established in this rule. The annual review must be documented in the facility files and include the original signature of the reviewer, registration or license number, and date reviewed. Portion sizes must be indicated on the menus or on a separate sheet. 1. Daily food servings may be divided among three or more meals per day, including snacks, as necessary to accommodate resident needs and preferences. 2. Menu items may be substituted with items of comparable nutritional value based on the seasonal availability of fresh produce or the preferences of the residents. (d) Menus must be dated and planned at least 1 week in advance for both regular and therapeutic diets. Residents must be encouraged to participate in menu planning. Planned menus must be conspicuously posted or easily available to residents. Regular and therapeutic menus as served, with substitutions noted before or when the meal is served, must be kept on file in the facility for 6 months. (e) Therapeutic diets must be prepared and served as ordered by the health care provider. 1. Facilities that offer residents a variety of food choices through a select menu, buffet style dining, or family style dining are not required to document what is eaten unless a health care provider's order indicates that such monitoring is necessary. However, the food items that enable residents to comply with the therapeutic diet must be identified on the menus developed for use in the facility. 2. The facility must document a resident's refusal to comply with a therapeutic diet and provide notification to the resident's health care provider	A 093		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 06/03/2019
NAME OF PROVIDER OR SUPPLIER KINGSHOUSE RETIREMENT CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 151 SOUTH MISSOURI STREET LA BELLE, FL 33935		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 093	Continued From page 8 of such refusal. (f) For facilities serving three or more meals a day, no more than 14 hours must elapse between the end of an evening meal containing a protein food and the beginning of a morning meal. Intervals between meals must be evenly distributed throughout the day with not less than 2 hours nor more than 6 hours between the end of one meal and the beginning of the next. For residents without access to kitchen facilities, snacks must be offered at least once per day. Snacks are not considered to be meals for the purposes of the time between meals. (g) Food must be served attractively at safe and palatable temperatures. All residents must be encouraged to eat at tables in the dining areas. A supply of eating ware sufficient for all residents, including adaptive equipment if needed by any resident, must be on (h) A 3-day supply of nonperishable food, based on the number of weekly meals the facility has with residents to serve, must be on at all times. The quantity must be based on the resident census and not on licensed capacity. The supply must consist of foods that can be stored safely without refrigeration. Water sufficient for drinking and food preparation must also be stored, or the facility must have a plan for obtaining water in an emergency, with the plan coordinated with and reviewed by the local disaster preparedness authority This Statute or Rule is not met as evidenced by: Based on observation and interview, the facility failed to maintain a 3 day supply of nonperishable foods, based on the number of meals to residents. The facility lacked an adequate milk supply to meet the needs of the 10 residents in house on the day of the survey.	A 093			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 093	Continued From page 9 The findings included: A review of the nonperishable food supply was completed on The facility was found to have only ounce cans of evaporated milk which when reconstituted would be 48 ounces of milk. The facility needed 480 ounces of milk for 10 residents for a 3 day supply. On at 2:00 p.m., the cook said the residents drink gallons of milk a week, plus the milk they use to cook. Class III	A 093		
A 200	58A-5.036 FAC Emergency Environmental Control (1) DETAILED EMERGENCY ENVIRONMENTAL CONTROL PLAN. Each assisted living facility shall prepare a detailed plan ("plan") to serve as a supplement to its Comprehensive Emergency Management Plan, to address emergency environmental control in the event of the loss of primary electrical power in that assisted living facility which includes the following information: (a) The acquisition of a sufficient alternate power source such as a generator(s), maintained at the assisted living facility, to ensure that current licensees of assisted living facilities will be equipped to ensure air temperatures will be maintained at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. 1. The required temperature must be maintained in an area or areas, determined by the assisted living facility, of sufficient size to maintain residents safely at all times and that is	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 10 appropriate for resident care needs and life safety requirements. For planning purposes, no less than twenty (20) net square . . . per resident must be provided. The assisted living facility may use eighty percent (80%) of its licensed bed capacity as the number of residents to be used in the to determine the required square footage. This may include areas that are less than the entire assisted living facility if the assisted living facility's comprehensive emergency management plan includes allowing a resident to congregate when he or she desires in portions of the building where temperatures will be maintained and includes procedures for monitoring residents for signs of heat related injury as required by this rule. This rule does not prohibit a facility from acting as a receiving provider for evacuees when the conditions stated in Section 408.821, F.S., and subsection 58A-5.026(5), F.A.C., are met. The plan shall include information regarding the area(s) within the assisted living facility where the required temperature will be maintained. 2. The alternate power source and fuel supply shall be located in an area(s) in accordance with local zoning and the Florida Building Code. 3. Each assisted living facility is unique in size; the types of care provided; the physical and mental capabilities and needs of residents; the type, frequency, and amount of services and care offered; and staffing characteristics. Accordingly, this rule does not limit the types of systems or equipment that may be used to achieve temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours in the event of the loss of primary electrical power. The plan shall include information regarding the systems and equipment that will be used by the assisted living facility and the fuel required to	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED 06/03/2019
NAME OF PROVIDER OR SUPPLIER KINGSHOUSE RETIREMENT CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 151 SOUTH MISSOURI STREET LA BELLE, FL 33935		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
A 200	Continued From page 11 operate the systems and equipment. a. An assisted living facility in an evacuation zone pursuant to Chapter 252, F.S., must maintain an alternative power source and fuel as required by this subsection at all times when the assisted living facility is occupied but is permitted to utilize a mobile generator(s) to enable portability if evacuation is necessary. b. Assisted living facilities located on a single campus with other facilities under common ownership, may share fuel, alternative power resources, and resident space available on the campus if such resources are sufficient to support the requirements of each facility's residents, as specified in this rule. Details regarding how resources will be shared and any necessary movement of residents must be clearly described in the emergency power plan. c. A multistory facility, whose comprehensive emergency management plan is to move residents to a higher floor during a flood or surge event, must place its alternative power source and all necessary additional equipment so it can safely operate in a location protected from flooding or storm surge damage. (b) The acquisition of sufficient fuel, and safe maintenance of that fuel at the facility, to ensure that in the event of the loss of primary electrical power there is sufficient fuel available for the alternate power source to maintain temperatures at or below 81 degrees Fahrenheit for a minimum of ninety-six (96) hours after the loss of primary electrical power during a declared state of emergency. The plan must include information regarding fuel source and fuel storage. 1. Facilities must store minimum amounts of fuel onsite as follows: a. A facility with a licensed capacity of 16 beds or	A 200			

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 12 less must store 48 hours of fuel onsite. b. A facility with a licensed capacity of 17 or more beds must store 72 hours of fuel onsite. 2. An assisted living facility located in an area in a declared state of emergency area pursuant to Section 252.36, F.S., that may impact primary power delivery must secure ninety-six (96) hours of fuel. The assisted living facility may utilize portable fuel storage containers for the remaining fuel necessary for ninety-six (96) hours during the period of a declared state of emergency. 3. Piped natural gas is an allowable fuel source and meets the onsite fuel supply requirements under this rule. 4. If local ordinances or other regulations limit the amount of onsite fuel storage for the assisted living facility's location, then the assisted living facility must develop a plan that includes maximum onsite fuel storage allowable by the ordinance or regulation and a reliable method to obtain the maximum additional fuel at least 24 hours prior to depletion of onsite fuel. (c) The acquisition of services necessary to maintain, and test the equipment and its functions to ensure the safe and sufficient operation of the alternate power source maintained at the assisted living facility. (d) The acquisition and maintenance of a monoxide alarm. (2) SUBMISSION OF THE PLAN. (a) Each assisted living facility licensed prior to the effective date of this rule shall submit its plan to the local emergency management agency for review within 30 days of the effective date of this rule. Assisted living facility plans previously submitted and approved pursuant to Emergency Rule 58AER17-1, F.A.C., will require resubmission only if changes are made to the plan.	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 13 (b) Each new assisted living facility shall submit the plan required under this rule prior to obtaining a license. (c) Each existing assisted living facility that undergoes any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of its systems or equipment affecting the facility's compliance with this rule shall amend its plan and submit it to the local emergency management agency for review and approval. (3) APPROVED PLANS. (a) Each assisted living facility must maintain a copy of its approved plan in a manner that makes the plan readily available at the licensee's physical address for review by a legally authorized entity. If the plan is maintained in an electronic format, assisted living facility staff must be readily available to access and produce the plan. For purposes of this section, "readily available" means the ability to immediately produce the plan, either in electronic or paper format, upon request. (b) Within two (2) business days of the approval of the plan from the local emergency management agency, the assisted living facility shall submit in writing proof of the approval to the Agency for Health Care Administration. (c) The assisted living facility shall submit a consumer-friendly summary of the emergency power plan to the Agency. The Agency shall post the summary and notice of the approval and implementation of the assisted living facility emergency power plans on its website within ten (10) business days of the plan's approval by the local emergency management agency and update within ten (10) business days of implementation. (4) IMPLEMENTATION OF THE PLAN.	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 14 (a) Each assisted living facility licensed prior to the effective date of this rule shall, no later than _____, have implemented the plan required under this rule. (b) The Agency shall allow an extension up to _____ to providers in compliance with subsection (c), below, and who can show delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes. Assisted living facilities shall notify the Agency that they will utilize the extension and keep the Agency apprised of progress on a quarterly basis to ensure there are no unnecessary delays. If an assisted living facility can show in its quarterly progress reports that unavoidable delays caused by necessary construction, delivery of ordered equipment, zoning or other regulatory approval processes will occur beyond the initial extension date, the assisted living facility may request a waiver pursuant to Section 120.542, F.S. (c) During the extension period, an assisted living facility must make arrangements pending full implementation of its plan that provides the residents with an area or areas to congregate that meets the safe indoor air temperature requirements of paragraph (1)(a), for a minimum of ninety-six (96) hours. 1. An assisted living facility not located in an evacuation zone must either have an alternative power source onsite or have a contract in place for delivery of an alternative power source and fuel when requested. Within twenty-four (24) hours of the issuance of a state of emergency for an event that may impact primary power delivery for the area of the assisted living facility, it must have the alternative power source and no less than ninety-six (96) hours of fuel stored onsite. 2. An assisted living facility located in an	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 15 evacuation zone pursuant to Chapter 252, F.S., must either: a. Fully and safely evacuate its residents prior to the arrival of the event, or b. Have an alternative power source and no less than ninety-six (96) hours of fuel stored onsite, within twenty-four (24) hours of the issuance of a state of emergency for the area of the assisted living facility. (d) Each new assisted living facility shall implement the plan required under this rule prior to obtaining a license. (e) Existing assisted living facilities that undergo any additions, modifications, alterations, refurbishment, renovations or reconstruction that require modification of the systems or equipment affecting the assisted living facility's compliance with this rule shall implement its amended plan concurrent with any such additions, modifications, alterations, refurbishment, renovations or reconstruction. (f) The Agency for Health Care Administration may request cooperation from the State Fire Marshal to conduct inspections to ensure implementation of the plan in compliance with this rule. (5) POLICIES AND PROCEDURES. (a) Each assisted living facility shall develop and implement written policies and procedures to ensure that the assisted living facility can effectively and immediately activate, operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The procedures shall ensure that residents do not experience complications from fluctuations in air temperatures inside the facility. Procedures must address the care of residents occupying the facility during a declared state of emergency, specifically, a description of	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 16 the methods to be used to mitigate the potential for heat related injury including: 1. The use of cooling devices and equipment; 2. The use of refrigeration and freezers to produce ice and appropriate temperatures for the maintenance of medicines requiring refrigeration; 3. Wellness checks by assisted living facility staff to monitor for signs of _____ and heat injury; and, 4. A provision for obtaining medical intervention from emergency services for residents whose life safety is in jeopardy. (b) Each assisted living facility shall maintain the written policies and procedures in a manner that makes them readily available at the licensee's physical address for review by a legally authorized entity. If the policies and procedures are maintained in an electronic format, assisted living facility staff must be readily available to access the policies and procedures and produce the requested information. For purposes of this section, "readily available" means the ability to immediately produce the policies and procedures, either in electronic or paper format, upon request. (c) The written policies and procedures must be readily available for inspection by each resident; each resident's legal representative, designee, surrogate, guardian, attorney in fact, or case manager; each resident's estate; and such additional parties as authorized in writing or by law. (6) REVOCATION OF LICENSE, FINES OR SANCTIONS. For a violation of any part of this rule, the Agency for Health Care Administration may seek any remedy authorized by Chapter 429, Part I, F.S., or Chapter 408, Part II, F.S., including, but not limited to, license revocation, license suspension, and the imposition of administrative fines.	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 17 (7) COMPREHENSIVE EMERGENCY MANAGEMENT PLAN. (a) Assisted living facilities whose comprehensive emergency management plan is to evacuate must comply with this rule. (b) Each facility whose plan has been approved shall submit the plan as an addendum with any future submissions for approval of its comprehensive emergency management plan. (8) NOTIFICATION. (a) Within five (5) business days, each assisted living facility must notify in writing, unless permission for electronic communication has been granted, each resident and the resident's legal representative: 1. Upon submission of the plan to the local emergency management agency that the plan has been submitted for review and approval; 2. Upon final implementation of the plan by the assisted living facility. (b) Each assisted living facility must maintain a copy of each notification set forth in paragraph (a), above, in a manner that makes each notification readily available at the licensee's physical address for review by a legally authorized entity. If the notifications are maintained in an electronic format, facility staff must be readily available to access and produce the notifications. For purposes of this section, "readily available" means the ability to immediately produce the notifications, either in electronic or paper format, upon request. This Statute or Rule is not met as evidenced by: Based on observation, interview, and record review, the facility failed to have an Emergency Power Plan (EPP) approved by the local Emergency Management Agency. The facility also failed to ensure an alternate power source such as a generator was readily available at the	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 18 facility to ensure the facility air temperature will be maintained at or below 81 degrees Fahrenheit for a minimum of 96 hours in the event of the loss of primary electrical power. In addition the facility failed to provide evidence of written policies and procedures to ensure the facility can effectively and immediately operate and maintain the alternate power source and any fuel required for the operation of the alternate power source. The findings included: On at 11 a.m., Staff C said the facility had received an extension for the EPP until , but currently had no EPP or further extension approved by the county. Staff C said the fixed generator on site was not yet fully operational, but he could run this with an electrical power cord plugged into an outlet. He also said he would power this by unhooking the propane from the stove and use that propane to run the generator. Staff C said a second fixed generator would be arriving in a few weeks. Staff C said there are two portable generators available for use about a mile away from the facility but there was no fuel available at the facility to operate them. Staff C said since they had not yet fully implemented their plan, residents and legal representatives had not been notified. Staff C said there were no written policies or procedures for the alternate power source, as the company installing them would be giving a training on that when fully installed. Staff C said there was no or scheduled maintenance of the 2 new generators set up yet as they are not fully installed and operational yet, and that the two generators off site had no formal maintenance or testing.	A 200		

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11911335	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 06/03/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

KINGSHOUSE RETIREMENT CENTER

**151 SOUTH MISSOURI STREET
LA BELLE, FL 33935**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 200	Continued From page 19 Observation revealed there were no CO2 detectors onsite. On _____ at 11:30 a.m., Staff C said it would be a few weeks until the 2 new fixed generators would be operational. Class III	A 200		