

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966444	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/15/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

LANGDON HALL OF BRADENTON

**1120 33 AVENUE WEST
BRADENTON, FL 34205**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 000	Initial Comments A complaint investigation (Complaint Number: 2019009717 and 2019013537) was conducted at Langdon Hall Assisted Living Facility on The facility had deficiencies at the time of the survey.	A 000		
A 181 SS=G	58A-5.026(2) FAC Emergency Plan Approval (2) EMERGENCY PLAN APPROVAL. The plan must be submitted for review and approval to the local emergency management agency. (a) If the local emergency management agency requires revisions to the emergency management plan, such revisions must be made and the plan resubmitted to the local office within 30 days of receiving notification that the plan must be revised. (b) A new facility as described in Rule 58A-5.023, F.A.C., and facilities whose ownership has been transferred, must submit an emergency management plan within 30 days after obtaining a license. (c) The facility must review its emergency management plan on an annual basis. Any substantive changes must be submitted to the local emergency agency for review and approval. 1. Changes in the name, address, telephone number, or position of staff listed in the plan are not considered substantive revisions for the purposes of this rule. 2. Changes in the identification of specific staff must be submitted to the local emergency management agency annually as a signed and dated addendum that is not subject to review and approval. (d) The local emergency management agency is the final administrative authority for emergency management plans prepared by assisted living facilities.	A 181		

AHCA Form 3020-0001

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Agency for Health Care Administration

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: AL11966444	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 09/15/2019
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

LANGDON HALL OF BRADENTON

**1120 33 AVENUE WEST
BRADENTON, FL 34205**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 181	Continued From page 1 (e) Any plan approved by the local emergency management agency is considered to have met all the criteria and conditions established in this rule. This Statute or Rule is not met as evidenced by: Based on record review, interview, observation the facility failed to have an emergency power plan approved by the local emergency management agency. Finding included: A record review conducted on _____ revealed that the facility does not have a current emergency power plan approved by the local emergency management agency. In an interview with the interim administrator conducted on _____ at 4:55 PM she stated that the facility does not have an approved emergency power plan. That the facility does have a rental agreement in place while they wait on the generator to be installed in _____. Review of the rental quote revealed that it had not been signed by either party. An observation conducted on _____ at 5:32 PM revealed a small portable generator on site with no fuel. Class II	A 181		