STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	6022178	A. BUILDING: _____ B. WING _____	01/29/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
CLARK-LINDSEY VILLAGE, INC	101 W WINDSOR RD URBANA, IL 61802

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A 000	Initial Comment Annual Licensure Survey 295.2040 c) 1) 2) 3)	A 000		
A2040	Section 295.2040 Disaster Preparedness This Regulation is not met as evidenced by: Type One Violation Section 295.2040 Disaster Preparedness c) At least six drills shall be conducted per year on a bimonthly basis. At least two of the drills shall be conducted during the night when residents are sleeping. All drills shall be held under varied conditions to: 1) Ensure that all personnel on all shifts are trained to perform assigned tasks; 2) Ensure that all personnel on all shifts are familiar with the use of the fire fighting equipment in the facility; 3) Evaluate the effectiveness of disaster plans, procedures and training. Based on interview and record review the establishment failed to conduct six drills per year on a bimonthly basis. This failure creates a substantial probability of severe harm to all 58 residents who reside in the establishment. Findings include: On 1/29/26 the establishment provided fire drills were reviewed. Fire drills were documented on	A2040		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	6022178	A. BUILDING: _____ B. WING _____	01/29/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
CLARK-LINDSEY VILLAGE, INC	101 W WINDSOR RD URBANA, IL 61802

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
A2040	Continued From page 1 3/8/25 at 1:00AM, 4/14/25 at 3:00PM, at 6/2/25 3:50PM, at 7/24/25 3:00PM, 8/29/25 at 3:45PM, 10/31/25 at 10:00AM, 11/25/25 at 3:35PM, and on 12/29/25 at 12:55AM. On 1/29/26 at 1:25PM, E1 Executive Director confirmed that no May 2025 fire drill was completed.	A2040		