

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205122	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	RECEIVED JUL 07 2023 06/23/2023
NAME OF PROVIDER OR SUPPLIER HARBOR HILL CENTER		STREET ADDRESS, CITY, STATE, ZIP CODE 2 FOOTBRIDGE RD BELFAST, ME 04915	

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	INITIAL COMMENTS Federal Complaint Survey Survey Date: 6/23/23 Intake #: 2ET021 Harbor Hill Center, a long-term care facility, is not in substantial compliance with the National Fire Protection Association 101 Life Safety Code, 2012 Edition as referenced in 42 CFR 483.90 (a - d) - Physical Environment.	K 000	Harbor Hill Center provides this plan of correction without admitting or denying the validity or existence of the alleged deficiency. The Plan of Correction is prepared and executed solely because it is required by federal and state law.	
K 223 SS=E	Doors with Self-Closing Devices CFR(s): NFPA 101 Doors with Self-Closing Devices Doors in an exit passageway, stairway enclosure, or horizontal exit, smoke barrier, or hazardous area enclosure are self-closing and kept in the closed position, unless held open by a release device complying with 7.2.1.8.2 that automatically closes all such doors throughout the smoke compartment or entire facility upon activation of: * Required manual fire alarm system; and * Local smoke detectors designed to detect smoke passing through the opening or a required smoke detection system; and * Automatic sprinkler system, if installed; and * Loss of power. 18.2.2.2.7, 18.2.2.2.8, 19.2.2.2.7, 19.2.2.2.8 This REQUIREMENT is not met as evidenced by: Based on observations and interview, the Nursing Facility failed to ensure the kitchen door and the storage door on first floor are self-closing and kept in the closed position at all time in accordance with NFPA 101 19.2.2.2.7, 19.2.2.2.8 Findings:	K 223		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

Nancy Hanan

TITLE

Administrator

(X6) DATE

7/7/23

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that the safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205122	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING B. WING _____	(X3) DATE SURVEY COMPLETED 06/23/2023
---	---	---	---

NAME OF PROVIDER OR SUPPLIER HARBOR HILL CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 2 FOOTBRIDGE RD BELFAST, ME 04915
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------------	--	---------------------	--	----------------------------

K 223 Continued From page 1

Based on observation and interview on 06/23/23 between the hours of 9 am and 11 am, in the accompany of the Assistant Administrator, did observe:

- 1) Kitchen door was being held open with a door wedge.
- 2) Storage room door on first floor was being held open with a door wedge.

This was confirmed by the Assistant Administrator at time of tour.

K 233 SS=D Clear Width of Exit and Exit Access Doors CFR(s): NFPA 101

Clear Width of Exit and Exit Access Doors 2012 EXISTING
Exit access doors and exit doors are of the swinging type and are at least 32 inches in clear width. Exceptions are provided for existing 34-inch doors and for existing 28-inch doors where the fire plan does not require evacuation by bed, gurney, or wheelchair.
19.2.3.6, 19.2.3.7
This REQUIREMENT is not met as evidenced by:

Based on observations, the Nursing Facility failed to ensure the means of egress was free from all obstructions in accordance with NFPA 101 19.2.3.6, 19.2.3.7

Based on observation and interview on 06/23/23 between the hours of 9 am and 11 am, in the accompany of the Assistant Administrator, did observe:

K 223

- 1) The door wedge holding open the kitchen door was removed.
- 2) The door wedge holding open the storage room door was removed.

Staff will be inserviced NFPA 101, 2012 Edition, Section 19.2.2.2.7, 19.2.2.2.8.

The kitchen door and storage room will be inspected monthly for the next three months and findings will be reviewed at the monthly Quality Assurance Performance Improvement (QAPI) Committee meeting.

Administrator/Designee to monitor.

K 233

The walking ramp obstructing the Exit door in Rehab has been relocated.

Staff will be inserviced on NFPA 102, 2012 Edition, Clear Width of Exit and Exit Access Doors, 19.2.3.6, 19.2.3.7.

The exit door will be inspected monthly for the next three months and the findings will be reviewed at the monthly QAPI Committee meeting.

Administrator/Designee to monitor.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205122	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 06/23/2023
---	---	--	---

RECEIVED

NAME OF PROVIDER OR SUPPLIER

HARBOR HILL CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE 2023

2 FOOTBRIDGE RD
BELFAST, ME 04915 BY: _____

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------------	--	---------------------	--	----------------------------

K 233 Continued From page 2
Findings:

1) Exit door in the physical therapy room was obstructed by PT walking ramp with rails.

This was confirmed by the Assistant Administrator at time of tour.

K 353 Sprinkler System - Maintenance and Testing
SS=D CFR(s): NFPA 101

Sprinkler System - Maintenance and Testing
Automatic sprinkler and standpipe systems are inspected, tested, and maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintaining of Water-based Fire Protection Systems. Records of system design, maintenance, inspection and testing are maintained in a secure location and readily available.

a) Date sprinkler system last checked

b) Who provided system test

c) Water system supply source

Provide in REMARKS information on coverage for any non-required or partial automatic sprinkler system.

9.7.5, 9.7.7, 9.7.8, and NFPA 25

This REQUIREMENT is not met as evidenced by:

Based on observations and interview, the facility failed to ensure that Sprinkler System was inspected, tested, and maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems. This deficient practice could affect the entire facility, patients/residents,

K 233

K 353

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205122	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	RECEIVED JUL 07 2023	(X3) DATE SURVEY COMPLETED 06/23/2023
---	---	--	-------------------------	---

NAME OF PROVIDER OR SUPPLIER HARBOR HILL CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 2 FOOTBRIDGE RD BELFAST, ME 04915
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 353	Continued From page 3 visitors, and members of facility staff in this location(S). Findings: Based on observation and interview on 06/23/23 between the hours of 9 am and 11 am, in the accompany of the Assistant Administrator, did observe: Two sprinkler head located in the kitchen and Landry room were "loaded" with debris . This could affect the operation of the sprinkler head. These findings were verified by the Assistant Administrator and Director of Maintenance at the time of observations.	K 353	The loaded sprinkler head in the kitchen and laundry room will be brought back to compliance by our licensed fire protection vendor. Progress of the work will be reviewed at the monthly QAPI Committee meeting. Administrator/Designee to monitor.	7/6/23 7/25/23
K 361 SS=E	Corridors - Areas Open to Corridor CFR(s): NFPA 101 Corridors - Areas Open to Corridor Spaces (other than patient sleeping rooms, treatment rooms and hazardous areas), waiting areas, nurse's stations, gift shops, and cooking facilities, open to the corridor are in accordance with the criteria under 18.3.6.1 and 19.3.6.1. 18.3.6.1, 19.3.6.1 This REQUIREMENT is not met as evidenced by: Based on observations , the Nursing Facility failed to ensure that all the rooms were being maintained to resist the passage of smoke to the corridor area in accordance with NFPA 101 19.3.6.1.	K 361		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205122	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	RECEIVED JUL 07 2023 (X3) DATE SURVEY COMPLETED 06/23/2023
---	---	--	--

NAME OF PROVIDER OR SUPPLIER

HARBOR HILL CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

2 FOOTBRIDGE RD
BELFAST, ME 04915

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 361	Continued From page 4 Findings: Based on observation and interview on 06/23/23 between the hours of 9 am and 11 am, in the company of the Assistant Administrator, did observe: 1) The fire sprinkler room has openings/penetrations above the door at ceiling height 2) Electrical room has openings/penetrations above the doors. This was observed by the Assistant Administrator and the Director of Maintenance	K 361	1) The openings/penetration above the door at ceiling height located in the fire sprinkler room will be sealed in accordance with NFPA 101, 2012 Edition, 19.3.6.2, 19.3.6.2.7. 2) The openings/penetration above the doors located in the electrical room will be sealed in accordance with NFPA 101, 2012 Edition, 19.3.6.2, 19.3.6.2.7. Maintenance staff will be inserviced on NFPA 101, 2012 Edition, Corridors, Construction of Walls. 1 hour rated fire walls will be inspected to ensure all penetrations are sealed in accordance with NFPA 101, 2012 Edition, 19.3.6.2, 19.3.6.2.7.	7/21/23 7/21/23 7/15/23 7/22/23
K 920 SS=D	Electrical Equipment - Power Cords and Extens CFR(s): NFPA 101 Electrical Equipment - Power Cords and Extension Cords Power strips in a patient care vicinity are only used for components of movable patient-care-related electrical equipment (PCREE) assemblies that have been assembled by qualified personnel and meet the conditions of 10.2.3.6. Power strips in the patient care vicinity may not be used for non-PCREE (e.g., personal electronics), except in long-term care resident rooms that do not use PCREE. Power strips for PCREE meet UL 1363A or UL 60601-1. Power strips for non-PCREE in the patient care rooms (outside of vicinity) meet UL 1363. In non-patient care rooms, power strips meet other UL standards. All power strips are used with general precautions. Extension cords are not used as a substitute for fixed wiring of a structure. Extension cords used temporarily are removed	K 920	Administrator/Designee to monitor.	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205122	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING B. WING _____	RECEIVED JUL 07 2023 06/23/2023
---	---	---	---------------------------------------

NAME OF PROVIDER OR SUPPLIER

HARBOR HILL CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

2 FOOTBRIDGE RD BY:
BELFAST, ME 04915

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------------	--	---------------------	--	----------------------------

K 920 Continued From page 5

immediately upon completion of the purpose for which it was installed and meets the conditions of 10.2.4.

10.2.3.6 (NFPA 99), 10.2.4 (NFPA 99), 400-8 (NFPA 70), 590.3(D) (NFPA 70), TIA 12-5 This REQUIREMENT is not met as evidenced by:

Based on observations, the Nursing Facility failed to ensure extension cords and power strips were installed in accordance with 10.2.4.10.2.3.6 (NFPA 99), 10.2.4 (NFPA 99), 400-8 (NFPA 70), 590.3(D) (NFPA 70), TIA 12-5

Findings:

Based on observation and interview on 06/23/23 between the hours of 9 am and 11 am, in the accompany of the Assistant Administrator, did observe:

- 1) Two banks of Direct TV receivers in activity directors office first floor, had multiple power strips and extension cord being used as permanent wiring.
- 2) Reception desk front entry was using extension cord and power strip that was being used for permanent wiring.

This was observed by the Assistant Administrator and the Maintenance Director

K 920

1. The multiple power & extension cord powering up the two banks of Direct TV receivers have been removed and permanent wiring will be installed.

2. The extension cord & power strip at the Reception desk have been removed.

Staff will be educated on NFPA 101, 2012 Edition, Electrical Equipment - Power Cords and Extension Cords.

Monthly inspections will be conducted for the next three months to ensure extension cords are not being used. Findings will be reviewed at the monthly QAPI Committee Meeting.

Administrator/Designee to monitor

Removed
on 6/23/23

7/21/23

6/23/23

7/15/23