

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/28/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205176		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 02/27/2024	
NAME OF PROVIDER OR SUPPLIER FOREST HILL MANOR				STREET ADDRESS, CITY, STATE, ZIP CODE 25 BOLDUC AVE FORT KENT, ME 04743			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 000	Initial Comments			E 000			
	Federal Recertification Survey Survey Date: 02/27/2024						
K 000	Forest Hill Manor, a long term care facility, is in substantial compliance with 42 Code of Federal Regulations Part 483.73 Requirement for Long Term Care Facilities Emergency Preparedness. INITIAL COMMENTS			K 000			
	Federal Recertification Survey: Survey Date: 02/27/2024						
K 761 SS=D	Forest Hill Manor, a Long Term Care Facility, was surveyed to the National Fire Protection Association 101 Life Safety Code 2012 Edition as reference on 42 CFR 483.90 (a-d) physical environment and is not in substantial compliance. Maintenance, Inspection & Testing - Doors CFR(s): NFPA 101			K 761			
	Maintenance, Inspection & Testing - Doors Fire doors assemblies are inspected and tested annually in accordance with NFPA 80, Standard for Fire Doors and Other Opening Protectives. Non-rated doors, including corridor doors to patient rooms and smoke barrier doors, are routinely inspected as part of the facility maintenance program. Individuals performing the door inspections and testing possess knowledge, training or experience that demonstrates ability. Written records of inspection and testing are maintained and are available for review. 19.7.6, 8.3.3.1 (LSC) 5.2, 5.2.3 (2010 NFPA 80) This REQUIREMENT is not met as evidenced by:						

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/28/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205176	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 02/27/2024
NAME OF PROVIDER OR SUPPLIER FOREST HILL MANOR			STREET ADDRESS, CITY, STATE, ZIP CODE 25 BOLDUC AVE FORT KENT, ME 04743		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 761	Continued From page 1 Based on observation and record review, the long-term care facility failed to conduct fire door inspections program that ensure they are inspected, tested, and maintained in accordance with NFPA 80, Standard for Fire Door and Other Opening Protective's in accordance with 2012 edition of NFPA 101 sections 19.7.6, 7.2.1.15 - 7.2.1.15.8, 8.3.3.1, NFPA 80 5.2, 5.2.3. Findings: On 2/27/2024, between 09:00 AM and 12:00 PM, this surveyor, observed the following findings with the Director of maintenance and the Administrator. 1. The facility failed to complete the assessment of all fire doors in the facility. The facility did not provide documentation that the fire doors throughout the facility had been inspected since 7/26/2022 by qualified employee, or a outside qualified vendor. 2. Individuals shall be knowledgeable and demonstrate understanding when testing fire doors. No documentation of training for door inspections was provide for any individual at the facility. This surveyor confirmed this finding with Maintenance and the Administrator the time of the observation and review.	K 761			