

FAX COVER SHEET

TO: Mark Jacobs, Administrator
Maine Veterans Home - Scarborough
Ronald.J.Peaslee@Maine.Gov, Phone # 441-1293
Gregory.J.Day@Maine.Gov, Phone # 441-0622

DATE: August 30, 2023

FAX NUMBER: 883-~~7184~~ 7852

FROM: Joanne.Cummings@Maine.Gov

PHONE: (207) 626-3882

PAGES INCLUDING COVER: 26

On August 29, 2023, your facility was found not to be in substantial compliance, with the participation requirements for Life Safety Code and Emergency Preparedness.

Please do not send your plan of correction to the office via US Mail or fax

Please email back the plan of correction to: FMOHealthcare@Maine.gov.



52 State House Station

(207) 626-3870

(207) 287-6251 Fax



State of Maine
Department of Public Safety
Office of Fire Marshal
52 State House Station
Augusta, ME 04333-0052

JANET T. MILLS
GOVERNOR

MICHAEL SAUSCHUCK
COMMISSIONER

RICHARD MCCARTHY
STATE FIRE MARSHAL

August 30, 2023

Maine Veterans Home - Scarborough
Attn: Mark Jacobs, Administrator
290 Us Rt 1
Scarborough, ME 04074

Provider ID#: 205127
Facility ID#: 3109
Event ID#: L12U21

Administrator Jacobs,

On **August 29, 2023**, the Office of the Fire Marshal conducted a Life Safety Code and Emergency Preparedness survey to determine if your facility complies with Federal participation requirements for nursing facilities in the Medicare and/or Medicaid program (In which you will be receiving a Form CMS-2567 for Life Safety Code and Emergency Preparedness). Your facility was found not to be in substantial compliance with the participation requirements for Life Safety Code and Emergency Preparedness.

The Federal regulatory requirements referenced in this letter are found in Title 42, Code of Federal Regulations (CFR) and in the National Fire Protection Association (NFPA)101 Life Safety Code Standard, 2012 Edition.

PLAN OF CORRECTION

Attached is Form CMS-2567 "Statement of Deficiencies" which enumerates the deficiencies found as a result of the survey. A Plan of Correction (POC) must be submitted by the **tenth (10th) calendar day** from your receipt of this letter. **Please note that a POC is not needed for isolated deficiencies which cause no harm (S/S of A).** Your POC must contain the following:

- What corrective action(s) will be accomplished for those residents found to have been affected by the deficient practice;
- How you will identify other residents having the potential to be affected by the same deficient practice and what corrective action will be taken;

- Indicate how the facility plans to monitor its performance to make sure that solutions are sustained. The facility must develop a plan for ensuring that correction is achieved and sustained. This plan must be implemented, and the corrective action evaluated for its effectiveness. The plan of correction is integrated into the quality assurance system;
- **Include dates when corrective action will be completed.** The corrective action completion dates must be acceptable to the State. If the plan of correction is unacceptable for any reason, the State will notify the facility;
- Include documentation to support a waiver request (if appropriate).

You are required to record your plan of correction in the appropriate column on the enclosed Form(s) CMS-2567. **Sign, date, and indicate your title in the blocks provided on page one.** Return the forms(s) with the POC to **State of Maine, Department of Public Safety, Office of State Fire Marshal, 45 Commerce Drive, 52 State House Station, Augusta, ME 04330-0052.**

Remedies will be recommended for imposition by the Centers for Medicare & Medicaid Services (CMS) Regional Office if your facility has failed to achieve substantial compliance by **October 16, 2023** (Opportunity to Correct). Informal dispute resolution for the cited deficiencies will not delay the imposition of the recommended enforcement actions. A change in the seriousness of the noncompliance may result in a change in the remedy selected. When this occurs, you will be advised of any change in remedy.

RECOMMENDED REMEDIES

Based on the deficiencies cited during the Life Safety Code and Emergency Preparedness Survey of **August 29, 2023**, we are recommending to CMS the imposition of the following remedy(ies):

A Civil Monetary Penalty per day to be determined by CMS.

Directed Plan of Correction (DPOC) effective immediately. The State Agency directs the plan of correction noted on the attached CMS-2567 for deficiencies E036(SS=F), E037(SS=F), E039(SS=F), K211(SS=E), K353(SS=D), K372(SS=D) & K919(SS=D) (Tags). [42 CFR 488.424]

If you do not achieve substantial compliance by **November 30, 2023**, the CMS Regional Office or State Medicaid Agency must deny payments for new (Medicare/Medicaid) admissions. In addition, we may recommend that **termination of your provider agreement be effective on March 1, 2024**, if substantial compliance is not achieved by that time. [42 CFR 488.456]. **Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.**

ALLEGATION OF COMPLIANCE

The Plan of Correction will serve as your allegation of compliance until substantiated by a revisit or other means. If upon revisit your facility has not achieved substantial compliance, recommended remedies may be imposed as determined by the CMS Regional Office and continue until substantial compliance is achieved. Additionally, CMS Regional Office may impose revised/additional remedies, if appropriate.

INFORMAL DISPUTE RESOLUTION

In accordance with 42 Code of Federal Regulations §488.331, you have one opportunity to question cited deficiencies through an IDR process. You may also contest scope and severity assessments for deficiencies, which may have resulted in a finding of substandard quality of care (SQC) or immediate jeopardy. To be given such an opportunity, you are required to send your written request, along with the specific deficiencies (or why you are disputing the scope and severity assessments of deficiencies which have been found to constitute SQC or immediate jeopardy) to **Fire Marshal Richard McCarthy** at the address below. This request must be sent during the same 10 calendar days you have for submitting a POC for the cited deficiencies. An incomplete IDR process will not delay the effective date of any enforcement action. IDR in no way is to be construed as a formal evidentiary hearing. It is an informal administrative process to discuss deficiencies. If counsel will accompany you, you must indicate this in your request for IDR so that we may also have counsel present.

Please email back the plan of correction to: FMOHealthcare@maine.gov.

If you have any questions, please contact me at (207) 626-3880.

Yours for Better Fire Prevention,



Richard McCarthy
Assistant State Fire Marshal

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 000	Initial Comments Federal Recertification Survey Survey Dates: 08-29-23 Maine Veterans Home - Scarborough, a long term care facility, is not in substantial compliance with 42 Code of Federal Regulations Part 483.73 Requirement for Long Term Care Facilities for Emergency Preparedness.	E 000			
E 036 SS=F	EP Training and Testing CFR(s): 483.73(d) §403.748(d), §416.54(d), §418.113(d), §441.184(d), §460.84(d), §482.15(d), §483.73(d), §483.475(d), §484.102(d), §485.68(d), §485.542(d), §485.625(d), §485.727(d), §485.920(d), §486.360(d), §491.12(d), §494.62(d). *[For RNCHIs at §403.748, ASCs at §416.54, Hospice at §418.113, PRTFs at §441.184, PACE at §460.84, Hospitals at §482.15, HHAs at §484.102, CORFs at §485.68, REHs at §485.542, CAHs at §486.625, "Organizations" under 485.727, CMHCs at §485.920, OPOs at §486.360, and RHC/FHQs at §491.12:] (d) Training and testing. The [facility] must develop and maintain an emergency preparedness training and testing program that is based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, policies and procedures at paragraph (b) of this section, and the communication plan at paragraph (c) of this section. The training and testing program must be reviewed and updated at least every 2 years. *[For LTC facilities at §483.73(d):] (d) Training	E 036			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 036	Continued From page 1 and testing. The LTC facility must develop and maintain an emergency preparedness training and testing program that is based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, policies and procedures at paragraph (b) of this section, and the communication plan at paragraph (c) of this section. The training and testing program must be reviewed and updated at least annually. *[For ICF/IIDs at §483.475(d):] Training and testing. The ICF/IID must develop and maintain an emergency preparedness training and testing program that is based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, policies and procedures at paragraph (b) of this section, and the communication plan at paragraph (c) of this section. The training and testing program must be reviewed and updated at least every 2 years. The ICF/IID must meet the requirements for evacuation drills and training at §483.470(i). *[For ESRD Facilities at §494.62(d):] Training, testing, and orientation. The dialysis facility must develop and maintain an emergency preparedness training, testing and patient orientation program that is based on the emergency plan set forth in paragraph (a) of this section, risk assessment at paragraph (a)(1) of this section, policies and procedures at paragraph (b) of this section, and the communication plan at paragraph (c) of this section. The training, testing and orientation program must be evaluated and updated at every 2 years. This REQUIREMENT is not met as evidenced by:	E 036			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 036	Continued From page 2 Based on observation, interview, and record review, the long term care facility failed to include the training and testing program in the Emergency Preparedness Plan. Finding: On 08/29/2023, between 08:00 am and 10:30 am, a surveyor, with the Facilities Director present, observed the following: 1. Documentation was not included in the Emergency Preparedness Plan to indicate that there was program to train and test staff on the use of this Plan. The surveyor confirmed this finding with the Facilities Director at the time of record review.	E 036			
E 037 SS=F	EP Training Program CFR(s): 483.73(d)(1) §403.748(d)(1), §416.54(d)(1), §418.113(d)(1), §441.184(d)(1), §460.84(d)(1), §482.15(d)(1), §483.73(d)(1), §483.475(d)(1), §484.102(d)(1), §485.68(d)(1), §485.542(d)(1), §485.625(d)(1), §485.727(d)(1), §485.920(d)(1), §486.360(d)(1), §491.12(d)(1). *[For RNCHIs at §403.748, ASCs at §416.54, Hospitals at §482.15, ICF/IIDs at §483.475, HHAs at §484.102, REHs at §485.542, "Organizations" under §485.727, OPOs at §486.360, RHC/FQHCs at §491.12:] (1) Training program. The [facility] must do all of the following: (i) Initial training in emergency preparedness policies and procedures to all new and existing staff, individuals providing services under	E 037			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 037	Continued From page 3 arrangement, and volunteers, consistent with their expected roles. (ii) Provide emergency preparedness training at least every 2 years. (iii) Maintain documentation of all emergency preparedness training. (iv) Demonstrate staff knowledge of emergency procedures. (v) If the emergency preparedness policies and procedures are significantly updated, the [facility] must conduct training on the updated policies and procedures. *[For Hospices at §418.113(d):] (1) Training. The hospice must do all of the following: (i) Initial training in emergency preparedness policies and procedures to all new and existing hospice employees, and individuals providing services under arrangement, consistent with their expected roles. (ii) Demonstrate staff knowledge of emergency procedures. (iii) Provide emergency preparedness training at least every 2 years. (iv) Periodically review and rehearse its emergency preparedness plan with hospice employees (including nonemployee staff), with special emphasis placed on carrying out the procedures necessary to protect patients and others. (v) Maintain documentation of all emergency preparedness training. (vi) If the emergency preparedness policies and procedures are significantly updated, the hospice must conduct training on the updated policies and procedures. *[For PRTFs at §441.184(d):] (1) Training	E 037			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 037	Continued From page 4 program. The PRTF must do all of the following: (i) Initial training in emergency preparedness policies and procedures to all new and existing staff, individuals providing services under arrangement, and volunteers, consistent with their expected roles. (ii) After initial training, provide emergency preparedness training every 2 years. (iii) Demonstrate staff knowledge of emergency procedures. (iv) Maintain documentation of all emergency preparedness training. (v) If the emergency preparedness policies and procedures are significantly updated, the PRTF must conduct training on the updated policies and procedures. *[For PACE at §460.84(d):] (1) The PACE organization must do all of the following: (i) Initial training in emergency preparedness policies and procedures to all new and existing staff, individuals providing on-site services under arrangement, contractors, participants, and volunteers, consistent with their expected roles. (ii) Provide emergency preparedness training at least every 2 years. (iii) Demonstrate staff knowledge of emergency procedures, including informing participants of what to do, where to go, and whom to contact in case of an emergency. (iv) Maintain documentation of all training. (v) If the emergency preparedness policies and procedures are significantly updated, the PACE must conduct training on the updated policies and procedures. *[For LTC Facilities at §483.73(d):] (1) Training Program. The LTC facility must do all of the	E 037			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 037	Continued From page 5 following: (i) Initial training in emergency preparedness policies and procedures to all new and existing staff, individuals providing services under arrangement, and volunteers, consistent with their expected role. (ii) Provide emergency preparedness training at least annually. (iii) Maintain documentation of all emergency preparedness training. (iv) Demonstrate staff knowledge of emergency procedures. *[For CORFs at §485.68(d):](1) Training. The CORF must do all of the following: (i) Provide initial training in emergency preparedness policies and procedures to all new and existing staff, individuals providing services under arrangement, and volunteers, consistent with their expected roles. (ii) Provide emergency preparedness training at least every 2 years. (iii) Maintain documentation of the training. (iv) Demonstrate staff knowledge of emergency procedures. All new personnel must be oriented and assigned specific responsibilities regarding the CORF's emergency plan within 2 weeks of their first workday. The training program must include instruction in the location and use of alarm systems and signals and firefighting equipment. (v) If the emergency preparedness policies and procedures are significantly updated, the CORF must conduct training on the updated policies and procedures. *[For CAHs at §485.625(d):] (1) Training program. The CAH must do all of the following:	E 037			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 037	Continued From page 6 (i) Initial training in emergency preparedness policies and procedures, including prompt reporting and extinguishing of fires, protection, and where necessary, evacuation of patients, personnel, and guests, fire prevention, and cooperation with firefighting and disaster authorities, to all new and existing staff, individuals providing services under arrangement, and volunteers, consistent with their expected roles. (ii) Provide emergency preparedness training at least every 2 years. (iii) Maintain documentation of the training. (iv) Demonstrate staff knowledge of emergency procedures. (v) If the emergency preparedness policies and procedures are significantly updated, the CAH must conduct training on the updated policies and procedures. *[For CMHCs at §485.920(d):] (1) Training. The CMHC must provide initial training in emergency preparedness policies and procedures to all new and existing staff, individuals providing services under arrangement, and volunteers, consistent with their expected roles, and maintain documentation of the training. The CMHC must demonstrate staff knowledge of emergency procedures. Thereafter, the CMHC must provide emergency preparedness training at least every 2 years. This REQUIREMENT is not met as evidenced by: Based on observation, interview, and record review, the long term care facility failed to include the training and testing program in the Emergency Preparedness Plan. Finding:	E 037			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023	
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH				STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 037	Continued From page 7 On 08/29/2023, between 08:00 am and 10:30 am, a surveyor, with the Facilities Director present, observed the following: 1. Documentation was not included in the Emergency Preparedness Plan to include the curriculum of the training program or demonstration of staff knowledge of the Emergency Preparedness procedures. The surveyor confirmed this finding with the Facilities Director at the time of record review.			E 037			
E 039 SS=F	EP Testing Requirements CFR(s): 483.73(d)(2) §416.54(d)(2), §418.113(d)(2), §441.184(d)(2), §460.84(d)(2), §482.15(d)(2), §483.73(d)(2), §483.475(d)(2), §484.102(d)(2), §485.68(d)(2), §485.542(d)(2), §485.625(d)(2), §485.727(d)(2), §485.920(d)(2), §491.12(d)(2), §494.62(d)(2). *[For ASCs at §416.54, CORFs at §485.68, REHs at §485.542, OPO, "Organizations" under §485.727, CMHCs at §485.920, RHCs/FQHCs at §491.12, and ESRD Facilities at §494.62]: (2) Testing. The [facility] must conduct exercises to test the emergency plan annually. The [facility] must do all of the following: (i) Participate in a full-scale exercise that is community-based every 2 years; or (A) When a community-based exercise is not accessible, conduct a facility-based functional exercise every 2 years; or (B) If the [facility] experiences an actual natural or man-made emergency that requires			E 039			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 039	Continued From page 8 activation of the emergency plan, the [facility] is exempt from engaging in its next required community-based or individual, facility-based functional exercise following the onset of the actual event. (ii) Conduct an additional exercise at least every 2 years, opposite the year the full-scale or functional exercise under paragraph (d)(2)(i) of this section is conducted, that may include, but is not limited to the following: (A) A second full-scale exercise that is community-based or individual, facility-based functional exercise; or (B) A mock disaster drill; or (C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan. (iii) Analyze the [facility's] response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the [facility's] emergency plan, as needed. *[For Hospices at 418.113(d):] (2) Testing for hospices that provide care in the patient's home. The hospice must conduct exercises to test the emergency plan at least annually. The hospice must do the following: (i) Participate in a full-scale exercise that is community based every 2 years; or (A) When a community based exercise is not accessible, conduct an individual facility based functional exercise every 2 years; or (B) If the hospice experiences a natural or man-made emergency that requires activation of the emergency plan, the hospital is exempt from	E 039			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
E 039	Continued From page 11 functional exercise; or (B) A mock disaster drill; or (C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan. (iii) Analyze the [facility's] response to and maintain documentation of all drills, tabletop exercises, and emergency events and revise the [facility's] emergency plan, as needed. *[For PACE at §460.84(d):] (2) Testing. The PACE organization must conduct exercises to test the emergency plan at least annually. The PACE organization must do the following: (i) Participate in an annual full-scale exercise that is community-based; or (A) When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise; or (B) If the PACE experiences an actual natural or man-made emergency that requires activation of the emergency plan, the PACE is exempt from engaging in its next required full-scale community based or individual, facility-based functional exercise following the onset of the emergency event. (ii) Conduct an additional exercise every 2 years opposite the year the full-scale or functional exercise under paragraph (d)(2)(i) of this section is conducted that may include, but is not limited to the following: (A) A second full-scale exercise that is community-based or individual, a facility based	E 039		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 039	Continued From page 10 community-based or a facility based functional exercise; or (B) A mock disaster drill; or (C) A tabletop exercise or workshop led by a facilitator that includes a group discussion using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan. (iii) Analyze the hospice's response to and maintain documentation of all drills, tabletop exercises, and emergency events and revise the hospice's emergency plan, as needed. *[For PRFTs at §441.184(d), Hospitals at §482.15(d), CAHs at §485.625(d):] (2) Testing. The [PRTF, Hospital, CAH] must conduct exercises to test the emergency plan twice per year. The [PRTF, Hospital, CAH] must do the following: (i) Participate in an annual full-scale exercise that is community-based; or (A) When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise; or (B) If the [PRTF, Hospital, CAH] experiences an actual natural or man-made emergency that requires activation of the emergency plan, the [facility] is exempt from engaging in its next required full-scale community based or individual, facility-based functional exercise following the onset of the emergency event. (ii) Conduct an [additional] annual exercise or and that may include, but is not limited to the following: (A) A second full-scale exercise that is community-based or individual, a facility-based	E 039			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 039	Continued From page 9 engaging in its next required full scale community-based exercise or individual facility-based functional exercise following the onset of the emergency event. (ii) Conduct an additional exercise every 2 years, opposite the year the full-scale or functional exercise under paragraph (d)(2)(i) of this section is conducted, that may include, but is not limited to the following: (A) A second full-scale exercise that is community-based or a facility based functional exercise; or (B) A mock disaster drill; or (C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan. (3) Testing for hospices that provide inpatient care directly. The hospice must conduct exercises to test the emergency plan twice per year. The hospice must do the following: (i) Participate in an annual full-scale exercise that is community-based; or (A) When a community-based exercise is not accessible, conduct an annual individual facility-based functional exercise; or (B) If the hospice experiences a natural or man-made emergency that requires activation of the emergency plan, the hospice is exempt from engaging in its next required full-scale community based or facility-based functional exercise following the onset of the emergency event. (ii) Conduct an additional annual exercise that may include, but is not limited to the following: (A) A second full-scale exercise that is	E 039			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023	
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH				STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE			
E 039	Continued From page 13 a facilitator includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan. (iii) Analyze the [LTC facility] facility's response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the [LTC facility] facility's emergency plan, as needed. *[For ICF/IIDs at §483.475(d)]: (2) Testing. The ICF/IID must conduct exercises to test the emergency plan at least twice per year. The ICF/IID must do the following: (i) Participate in an annual full-scale exercise that is community-based; or (A) When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise; or (B) If the ICF/IID experiences an actual natural or man-made emergency that requires activation of the emergency plan, the ICF/IID is exempt from engaging in its next required full-scale community-based or individual, facility-based functional exercise following the onset of the emergency event. (ii) Conduct an additional annual exercise that may include, but is not limited to the following: (A) A second full-scale exercise that is community-based or an individual, facility-based functional exercise; or (B) A mock disaster drill; or (C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.	E 039					

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 039	Continued From page 14 (iii) Analyze the ICF/IID's response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the ICF/IID's emergency plan, as needed. *[For HHAs at §484.102] (d)(2) Testing. The HHA must conduct exercises to test the emergency plan at least annually. The HHA must do the following: (i) Participate in a full-scale exercise that is community-based; or (A) When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise every 2 years; or. (B) If the HHA experiences an actual natural or man-made emergency that requires activation of the emergency plan, the HHA is exempt from engaging in its next required full-scale community-based or individual, facility based functional exercise following the onset of the emergency event. (ii) Conduct an additional exercise every 2 years, opposite the year the full-scale or functional exercise under paragraph (d)(2)(i) of this section is conducted, that may include, but is not limited to the following: (A) A second full-scale exercise that is community-based or an individual, facility-based functional exercise; or (B) A mock disaster drill; or (C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan.	E 039			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 039	Continued From page 12 functional exercise; or (B) A mock disaster drill; or (C) A tabletop exercise or workshop that is led by a facilitator and includes a group discussion, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan. (iii) Analyze the PACE's response to and maintain documentation of all drills, tabletop exercises, and emergency events and revise the PACE's emergency plan, as needed. *[For LTC Facilities at §483.73(d):] (2) The [LTC facility] must conduct exercises to test the emergency plan at least twice per year, including unannounced staff drills using the emergency procedures. The [LTC facility, ICF/IID] must do the following: (i) Participate in an annual full-scale exercise that is community-based; or (A) When a community-based exercise is not accessible, conduct an annual individual, facility-based functional exercise. (B) If the [LTC facility] facility experiences an actual natural or man-made emergency that requires activation of the emergency plan, the LTC facility is exempt from engaging its next required a full-scale community-based or individual, facility-based functional exercise following the onset of the emergency event. (ii) Conduct an additional annual exercise that may include, but is not limited to the following: (A) A second full-scale exercise that is community-based or an individual, facility based functional exercise; or (B) A mock disaster drill; or (C) A tabletop exercise or workshop that is led by	E 039			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 039	Continued From page 15 (iii) Analyze the HHA's response to and maintain documentation of all drills, tabletop exercises, and emergency events, and revise the HHA's emergency plan, as needed. *[For OPOs at §486.360] (d)(2) Testing. The OPO must conduct exercises to test the emergency plan. The OPO must do the following: (i) Conduct a paper-based, tabletop exercise or workshop at least annually. A tabletop exercise is led by a facilitator and includes a group discussion, using a narrated, clinically relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan. If the OPO experiences an actual natural or man-made emergency that requires activation of the emergency plan, the OPO is exempt from engaging in its next required testing exercise following the onset of the emergency event. (ii) Analyze the OPO's response to and maintain documentation of all tabletop exercises, and emergency events, and revise the [RNHCI's and OPO's] emergency plan, as needed. *[RNCHIs at §403.748]: (d)(2) Testing. The RNHCI must conduct exercises to test the emergency plan. The RNHCI must do the following: (i) Conduct a paper-based, tabletop exercise at least annually. A tabletop exercise is a group discussion led by a facilitator, using a narrated, clinically-relevant emergency scenario, and a set of problem statements, directed messages, or prepared questions designed to challenge an emergency plan. (ii) Analyze the RNHCI's response to and	E 039			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 039	Continued From page 16 maintain documentation of all tabletop exercises, and emergency events, and revise the RNHCI's emergency plan, as needed. This REQUIREMENT is not met as evidenced by: Based on observation, interview, and record review, the long term care facility failed to include documentation to indicate full-scale exercise and table top exercises were conducted in the Emergency Preparedness Plan. Finding: On 08/29/2023, between 08:00 am and 10:30 am, a surveyor, with the Facilities Director present, observed the following: 1. Documentation was not included in the Emergency Preparedness Plan to indicate that a full-scale exercise or table top exercises were conducted in the last 12 months. The surveyor confirmed this finding with the Facilities Director at the time of record review.	E 039			
K 000	INITIAL COMMENTS Federal Recertification Survey Survey Dates: 08/29/2023 Life Safety Code Statement Facility was surveyed pursuant to the National Fire Protection Association 101 Life Safety Code, 2012 Edition as referenced in 42 CFR 483.90 (a - d) - Physical Environment and at the time of the inspection, the facility is not in substantial compliance.	K 000			
K 211	Means of Egress - General	K 211			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 211 SS=E	Continued From page 17 CFR(s): NFPA 101 Means of Egress - General Aisles, passageways, corridors, exit discharges, exit locations, and accesses are in accordance with Chapter 7, and the means of egress is continuously maintained free of all obstructions to full use in case of emergency, unless modified by 18/19.2.2 through 18/19.2.11. 18.2.1, 19.2.1, 7.1.10.1 This REQUIREMENT is not met as evidenced by: Based on observation the long term care facility failed to ensure that the exit corridors remained free of obstructions per NFPA 101, Life Safety Code, 2012 Edition, Section 19.2.3.4. Findings: On 08/29/2023, between 08:00 am and 10:30 am, a surveyor, with the Facilities Technician present, observed the following: 1. On C Wing, a straight back chair was found stored in the corridor outside Room 37/38. There was a sign on the adjacent wall calling it out as a Charting Area, Two straight back chairs were found stored in the corridor outside Room 6 and a hand sanitizer stand was found in the exit corridor outside the Dining area. 2. On B Wing, a hand sanitizer stand and a straight back chair was found stored in the exit corridor outside the Dining area. The surveyor confirmed these findings with the Facilities Technician at the time of the observation.	K 211			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 353 K 353 SS=D	Continued From page 18 Sprinkler System - Maintenance and Testing CFR(s): NFPA 101 Sprinkler System - Maintenance and Testing Automatic sprinkler and standpipe systems are inspected, tested, and maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintaining of Water-based Fire Protection Systems. Records of system design, maintenance, inspection and testing are maintained in a secure location and readily available. a) Date sprinkler system last checked _____ b) Who provided system test _____ c) Water system supply source _____ Provide in REMARKS information on coverage for any non-required or partial automatic sprinkler system. 9.7.5, 9.7.7, 9.7.8, and NFPA 25 This REQUIREMENT is not met as evidenced by: Based on observation the long term care facility failed to maintain the required ceiling assembly for a sprinkler protected facility per NFPA 13, Standard for the Installation of Sprinkler Systems, 2010 Edition, Section 8.6.4.1.1 and NFPA 101, Life Safety Code, 2012 Edition, Section 19.3.5.1. Finding: On 08/29/2023, between 08:00 am and 10:30 am, a surveyor, with the Facilities Technician present, observed the following: 1. A ceiling tile was out of place in the Kitchen Water Heater Room. This ceiling assembly is in	K 353 K 353			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 353	Continued From page 19 in place so that the appropriate temperature of the stairwell will activate the required sprinkler heads when reached.	K 353			
K 372 SS=D	The surveyor confirmed this finding with the Facilities Technician at the time of the observation. Subdivision of Building Spaces - Smoke Barrie CFR(s): NFPA 101 Subdivision of Building Spaces - Smoke Barrier Construction 2012 EXISTING Smoke barriers shall be constructed to a 1/2-hour fire resistance rating per 8.5. Smoke barriers shall be permitted to terminate at an atrium wall. Smoke dampers are not required in duct penetrations in fully ducted HVAC systems where an approved sprinkler system is installed for smoke compartments adjacent to the smoke barrier. 19.3.7.3, 8.6.7.1(1) Describe any mechanical smoke control system in REMARKS. This REQUIREMENT is not met as evidenced by: Based on observations and interview with the Maintenance Technician the facility failed to meet the requirements of the National Fire Protection Association (NFPA) 101, Life Safety Code, 2012 edition for smoke barrier enclosures in accordance with 19.3.7.3. Findings include: Observations found that 2 smoke barrier walls had penetrations in them, therefore not maintaining a smoke tight resistive rating during a	K 372			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 372	Continued From page 20 facility tour on 08/29/2023 between 08:00am and 10:30am with the Maintenance Technician. 1. A section of the Smoke barrier wall above the double doors by Wing A, had a conduit penetration through the wall and a bundle of cables that were penetrating the wall in the smoke barrier above the ceiling. All smoke barrier wall penetrations are required to be sealed in accordance with the wall listing. 2. A section of the Smoke barrier wall above the double doors by Wing C had a bundle of cables penetrating the smoke barrier above the ceiling. All smoke barrier wall penetrations are required to be sealed in accordance with the wall listing. This deficient practice could affect the occupants, visitors and staff while trying to exit the building or sheltering in place. These findings were verified by the Maintenance Technician at the time of observation.	K 372			
K 919 SS=D	Electrical Equipment - Other CFR(s): NFPA 101 Electrical Equipment - Other List in the REMARKS section any NFPA 99 Chapter 10, Electrical Equipment, requirements that are not addressed by the provided K-Tags, but are deficient. This information, along with the applicable Life Safety Code or NFPA standard citation, should be included on Form CMS-2567. Chapter 10 (NFPA 99) This REQUIREMENT is not met as evidenced by: Based on observation and interview, the long term care facility failed to comply with NFPA 99,	K 919			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/30/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/29/2023
NAME OF PROVIDER OR SUPPLIER MAINE VETERANS HOME - SCARBOROUGH			STREET ADDRESS, CITY, STATE, ZIP CODE 290 US RT 1 SCARBOROUGH, ME 04074		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 919	Continued From page 21 Healthcare Facilities Code, 2012 sections 10.5.2.7, 10.5.3.1, & NFPA 101, Life Safety Code, 2012 Edition. Finding: On 08/29/2023, between 08:00 am and 10:30 am, a surveyor, with the Facilities Technician present, observed the following: 1. On C Wing, multiple wheelchair batteries were found charging in the common area. Policies are required to be established for appliances not supplied by the facility Batteries shall not be charged in any resident area, in any area open to residents or exit corridors. Batteries shall be charged within the guidelines set forth by the manufactures recommendations. Batteries are required to be charged in a rated room not open to residents, or the general public. The surveyor confirmed this finding with the Facilities Technician at the time of the observation.	K 919			