

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/31/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205105	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 01/30/2024
NAME OF PROVIDER OR SUPPLIER WESTGATE CENTER FOR REHAB & ALZHEIMERS CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 750 UNION ST BANGOR, ME 04401		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 000	Initial Comments	E 000			
	Federal Recertification Survey Survey Date 1/30/2024				
	Westgate Center for Rehab & Alzheimers Care, a long term care facility, is in substantial compliance with 42 Code of Federal Regulations Part 483.73 Requirement for Long Term Care Facilities Emergency Preparedness.				
K 000	INITIAL COMMENTS	K 000			
	Federal Recertification Survey: Survey Date: 01/30/2024				
	Westgate Center for Rehab & Alzheimers Care, a Long Term Care Facility, was surveyed to the National Fire Protection Association 101 Life Safety Code 2012 Edition as reference on 42 CFR 483.90 (a-d) physical environment and is not in substantial compliance.				
K 761 SS=D	Maintenance, Inspection & Testing - Doors CFR(s): NFPA 101	K 761			
	Maintenance, Inspection & Testing - Doors Fire doors assemblies are inspected and tested annually in accordance with NFPA 80, Standard for Fire Doors and Other Opening Protectives. Non-rated doors, including corridor doors to patient rooms and smoke barrier doors, are routinely inspected as part of the facility maintenance program. Individuals performing the door inspections and testing possess knowledge, training or experience that demonstrates ability. Written records of inspection and testing are maintained and are available for review. 19.7.6, 8.3.3.1 (LSC) 5.2, 5.2.3 (2010 NFPA 80)				

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/31/2024
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 205105	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 01/30/2024
NAME OF PROVIDER OR SUPPLIER WESTGATE CENTER FOR REHAB & ALZHEIMERS CARE			STREET ADDRESS, CITY, STATE, ZIP CODE 750 UNION ST BANGOR, ME 04401	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 761	Continued From page 1 This REQUIREMENT is not met as evidenced by: Based on observation and record review, the long-term care facility failed to conduct fire door inspections that ensured fire doors are inspected, tested, and maintained in accordance with NFPA 80, Standard for Fire Door and Other Opening Protectives in accordance with NFPA 101 18.7.6, 19.7.6, 8.3.3.1, NFPA 80 5.2, 5.2.3. Findings: On 01/30/2024, between 09:00 AM and 12:30 PM, surveyor 39983, observed the following findings with the Maintenance Director. 1. The facility failed to complete the assessment of 4 of 7 sets of fire doors in the facility. The flooring in the corridors has been replaced, covering the existing latch, not allowing the 90 minute fire doors to latch properly at the floor in 4 corridors. 2. A set of fire doors located next to the nurses station in the Acadia Wing have a gap exceeding 1/8" between the pair of doors. This surveyor confirmed this finding with the Maintenance Director at the time of the observation and review.	K 761		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

AH
"A" FORM

STATEMENT OF ISOLATED DEFICIENCIES WHICH CAUSE NO HARM WITH ONLY A POTENTIAL FOR MINIMAL HARM FOR SNFs AND NFs		PROVIDER # 205105	MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	DATE SURVEY COMPLETE: 1/30/2024
NAME OF PROVIDER OR SUPPLIER WESTGATE CENTER FOR REHAB & ALZHEIMERS		STREET ADDRESS, CITY, STATE, ZIP CODE 750 UNION ST BANGOR, ME		
ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES			
K 321	Hazardous Areas - Enclosure CFR(s): NFPA 101 Hazardous Areas - Enclosure Hazardous areas are protected by a fire barrier having 1-hour fire resistance rating (with 3/4 hour fire rated doors) or an automatic fire extinguishing system in accordance with 8.7.1 or 19.3.5.9. When the approved automatic fire extinguishing system option is used, the areas shall be separated from other spaces by smoke resisting partitions and doors in accordance with 8.4. Doors shall be self-closing or automatic-closing and permitted to have nonrated or field-applied protective plates that do not exceed 48 inches from the bottom of the door. Describe the floor and zone locations of hazardous areas that are deficient in REMARKS. 19.3.2.1, 19.3.5.9 Area Automatic Sprinkler Separation N/A a. Boiler and Fuel-Fired Heater Rooms b. Laundries (larger than 100 square feet) c. Repair, Maintenance, and Paint Shops d. Soiled Linen Rooms (exceeding 64 gallons) e. Trash Collection Rooms (exceeding 64 gallons) f. Combustible Storage Rooms/Spaces (over 50 square feet) g. Laboratories (if classified as Severe Hazard - see K322) This REQUIREMENT is not met as evidenced by: The facility failed to protect hazardous area fire barrier walls and ceiling, having 1-hour fire resistance rating in accordance with NFPA 101 Section 19.3.5.9 Finding: Based on interview and observation on 01/30/24 between hours of 9:00 AM and 12:30 PM. surveyor 39983 accompanied with the Maintenance Director did observe the following: 1. Penetrations in 1-hour rated fire wall in laundry room. Two penetrations located in ceiling above the washing machines where electric conduit is fed through. These observations were observed by this surveyor, and Maintenance Director. These penetrations were repaired during the inspection by the time of exit interview with administrator.			

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of

The above isolated deficiencies pose no actual harm to the residents

STATEMENT OF ISOLATED DEFICIENCIES WHICH CAUSE NO HARM WITH ONLY A POTENTIAL FOR MINIMAL HARM FOR SNFs AND NFs		PROVIDER # 205105	MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	DATE SURVEY COMPLETE: 1/30/2024
NAME OF PROVIDER OR SUPPLIER WESTGATE CENTER FOR REHAB & ALZHEIMERS		STREET ADDRESS, CITY, STATE, ZIP CODE 750 UNION ST BANGOR, ME		
ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES			
K 353	Continued From Page 1			
K 353	Sprinkler System - Maintenance and Testing CFR(s): NFPA 101 Sprinkler System - Maintenance and Testing Automatic sprinkler and standpipe systems are inspected, tested, and maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintaining of Water-based Fire Protection Systems. Records of system design, maintenance, inspection and testing are maintained in a secure location and readily available. a) Date sprinkler system last checked _____ b) Who provided system test _____ c) Water system supply source _____ Provide in REMARKS information on coverage for any non-required or partial automatic sprinkler system. 9.7.5, 9.7.7, 9.7.8, and NFPA 25 This REQUIREMENT is not met as evidenced by: Based on observations, the facility failed to ensure that Sprinkler System was inspected, tested, and maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems, 2011 edition, Chapter 5, section 5.2.1.1.1 Findings: During survey on 01/30/24 between hours of 9:00 AM and 12:30 PM., surveyor 47175 accompanied with the Maintenance Director did observe the following: 1. One sprinkler head located in the shower room next to the admissions office, the escutcheon ring was not tight up to the ceiling causing a gap that could allow the passage of smoke. This was repaired during the inspection by the time the surveyor had the exit interview. These findings were verified by the Maintenance Director at the time of observation.			