

MSDH - Health Facilities Licensure and Certification

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 25CG	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 11/29/2023
NAME OF PROVIDER OR SUPPLIER PINE FOREST HEALTH AND REHABILITATION		STREET ADDRESS, CITY, STATE, ZIP CODE 1116 FOREST AVENUE JACKSON, MS 39206		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 000	Initial Comments 42 CFR 483.70(a) The facility must meet the applicable provisions of the 2012 (existing) Edition of the Life Safety Code (LSC) of the National Fire Protection Association (NFPA) ...	M 000		
M1245	45.41.1 Date of Construction & Life Safety... Date of Construction and Life Safety Code Compliance. 1. Buildings constructed after the effective date of these regulations shall comply with the edition of the Life Safety Code (NFPA 101) effective on the date of construction. 2. Buildings constructed prior to the effective date of these regulations shall comply with Chapter 13 of the Life Safety Code (NFPA 101), 1985 edition. This Statute is not met as evidenced by: Based on observations and documentation review, the facility failed to meet Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection System Components as required by NFPA 25 5. The deficient practice had potential to affect the entire facility on the day of survey. Findings Include: One 11/29/23 at 2:00 PM, observation and record review revealed the facility failed to provide the annual Inspection of the sprinkler system for current year (2023). The last documented and known date of fire sprinkler system inspection was 2/8/22.	M1245	1. On 11/30/2023, Facility contracted Sprinkler Monitoring company conducted an Inspection of Fire Sprinkler Systems and determined Facility equipment to be compliant and in working order. 2. According the Inspection on 11/30/2023, zero residents were determined to be affected. 3. Facility QAPI Committee (consisting of Administrator, Director of Nursing (DON), Infection Control Preventionist (IFCP), Medical Director (MD), Social Services (SS), Activity Director (AD), Assistant Director of Nursing (ADON), Certified Dietary Manager (CDM), and Therapy Director (DOR)) met on 12/20/2023 to review cited regulation. QAPI Committee	1/2/24

Mississippi State Department of Health

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

12/29/23

MSDH - Health Facilities Licensure and Certification

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 25CG	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 11/29/2023
NAME OF PROVIDER OR SUPPLIER PINE FOREST HEALTH AND REHABILITATION		STREET ADDRESS, CITY, STATE, ZIP CODE 1116 FOREST AVENUE JACKSON, MS 39206		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M1245	Continued From page 1 The finding was acknowledged by the Administrator and Maintenance Supervisor during the exit interview on 11/29/23.	M1245	reviewed the policy/procedure , Life Safety Code with no recommended changes to the policy/procedure. Plant Operations Manager was inserviced on Facility policy and procedure on the importance of maintaining Life Safety Code regulatory standards pertaining to Fire Sprinkler Systems by outsourced Sprinkler contractor. 4. Facility scheduled and contracted an annual inspection with Contracted Sprinkler Monitoring Company according to contract for December 2024 to ensure future regulatory compliance. Plant Operations Manager will report monthly compliance using TELS Life Safety Software for Fire Sprinkler Monitoring Systems to QAPI Committee who will monitor monthly as part of its standard agenda. Any concerns identified will be noted, assessed and corrected immediately.	