

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/19/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 255269	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - BUILDING 02 B. WING _____		(X3) DATE SURVEY COMPLETED 05/09/2023
NAME OF PROVIDER OR SUPPLIER OXFORD HEALTH & REHAB CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 1301 BELK BOULEVARD OXFORD, MS 38655		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	INITIAL COMMENTS 42 CFR 483.70(a) The facility must meet the applicable provisions of the 2012 (existing) Edition of the Life Safety Code (LSC) of the National Fire Protection Association (NFPA) ...	K 000			
K 916 SS=E	Electrical Systems - Essential Electric Syste CFR(s): NFPA 101 Electrical Systems - Essential Electric System Alarm Annunciator A remote annunciator that is storage battery powered is provided to operate outside of the generating room in a location readily observed by operating personnel. The annunciator is hard-wired to indicate alarm conditions of the emergency power source. A centralized computer system (e.g., building information system) is not to be substituted for the alarm annunciator. 6.4.1.1.17, 6.4.1.1.17.5 (NFPA 99) This REQUIREMENT is not met as evidenced by: Based on observations, the facility failed to provide all the generator required components as in accordance with NFPA 110 section 5.6.6 and NFPA 99 section 6.4.1.1.17. The deficient practice affected 52 of 108 residents in the facility on the day of survey. Findings include: On 5/9/23 at 10:50 AM, observation revealed the C Hall generator lacked a remote annunciator	K 916	- The generator for C hall lacked a remote annunciator. Maintenance director notified Thompson -CAT on 5/9/2023 that an annunciator panel needed to be ordered and installed. Annunciator has been ordered and will be installed on 5/31/2023. - The facility determined that all residents have the potential to be affected. - Facility administrator held a 1:1 in service with maintenance director on maintaining proper essential electric alarm	6/25/23	

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

05/25/2023

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/19/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 255269	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - BUILDING 02 B. WING _____		(X3) DATE SURVEY COMPLETED 05/09/2023
NAME OF PROVIDER OR SUPPLIER OXFORD HEALTH & REHAB CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 1301 BELK BOULEVARD OXFORD, MS 38655		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 916	Continued From page 1 panel in a constantly monitored location of the facility (ex. Nurses station or receptionist desk ...). The facility contain two (2) generators (A Hall generator and C Hall generator).	K 916	systems. • The maintenance director will maintain and maintenance all alarm systems weekly for 4 consecutive weeks and then monthly thereafter. • Corrective action completion date: June 25, 2023		