

PRINTED: 07/28/2015
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES
AND PLAN OF CORRECTION

(X1) PROVIDER/SUPPLIER/CLIA
IDENTIFICATION NUMBER:

HAL096029

(X2) MULTIPLE CONSTRUCTION

A. BUILDING: 01

B. WING: _____

(X3) DATE SURVEY
COMPLETED

R
07/20/2015

NAME OF PROVIDER OR SUPPLIER

SUTTON'S RETIREMENT CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

4258 HWY 13 NORTH
GOLDSBORO, NC 27534

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
(C 000)	Initial Comments Report of a Follow Up Survey by Billy S. Bryant and Greg Cates conducted on 07/21/2015. Deficiencies noted during the Biennial Survey on 03/27/2015 remain to be corrected.	(C 000)		
(C 111)	Must Have Current San. & Fire Safety Reports SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0302 DESIGN AND CONSTRUCTION f) The facility shall have current sanitation and fire and building safety inspection reports which shall be maintained in the home and available for review. This Rule is not met as evidenced by: I. Based on interviews the current fire and building safety reports were not available for review at the time of the survey. A. Finding on 07/21/2015: 1. The following items from the previous biennial survey remain to be corrected. Findings on 03/27/2015 The following reports were not available at the time of the survey: d) Fire Marshals Report e) Fire Alarm Annual Test Report.	(C 111)		
(C 199)	Exhaust Ventilation SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (g) The spaces listed in this Paragraph shall be provided with exhaust ventilation at the rate of	(C 199)		

CONSTRUCTION SECTION
OCT 07 2015
RECEIVED

Fire Inspection
has been completed, 9/4/15
attached copy.

Division of Health Service Regulation
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

Ku S 202

TITLE

Administrator

(X6) DATE

9/24/15

STATE FORM

0000

3S4H22

If continuation sheet 1 of 2

PRINTED: 07/28/2015
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL096029	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED R 07/20/2015
--	---	---	---

NAME OF PROVIDER OR SUPPLIER SUTTON'S RETIREMENT CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 4258 HWY 13 NORTH GOLDSBORO, NC 27534
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
(C 199)	Continued From page 1 two cubic feet per minute per square foot. This requirement does not apply to facilities licensed before April 1, 1984, with natural ventilation in these specified spaces: (1) soiled linen storage; (2) soil utility room; (3) bathrooms and toilet rooms; (4) housekeeping closets; and (5) laundry area. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: I. Based on observation the the requirement of the rule is not met. Spaces with exhaust fans installed fans must be vented to the exterior of the building. A. Finding on 07/21/2015: 1. The following item from the previous biennial survey remains to be corrected: Findings on 03/27/2015: Exhaust fans have issues in the following locations: (b) The exhaust fan next to HVAC unit #2 is venting into the attic.	(C 199)	Mainten man has been out, had emergency surgery, supplies have been purchased, working on finding someone to work, he may be back couple weeks.	10/31/2015

Division of Health Service Regulation
STATE FORM

354H22

If continuation sheet 2 of 2

INSPECTION AND TESTING FORM

SERVICE ORGANIZATION

Name: D-atom
 Address: 1007 11th Street
 Representative: Chris Jones
 License No.: _____
 Telephone: 919-778-2670

MONITORING ENTITY

Contact: Security Central
 Telephone: _____
 Monitoring Account Ref. No.: _____

TYPE TRANSMISSION

- ☐ McCulloch
☐ Multiplex
☒ Digital
☐ Reverse Priority
☐ RF
☐ Other (Specify) _____

Control Unit Manufacturer: Inelita
 Circuit Styles: _____
 Number of Circuits: 10
 Software Rev.: _____

Last Date System Had Any Service Performed: _____
 Last Date that Any Software or Configuration Was Revised: _____

DATE: _____
 TIME: _____

PROPERTY NAME (USER)

Name: Sutton Retirement
 Address: 4255 Hwy 13 North
 Owner Contact: _____
 Telephone: 919-759-9695

APPROVING AGENCY

Contact: _____
 Telephone: _____

SERVICE

- ☐ Weekly
☐ Monthly
☐ Quarterly
☐ Semiannually
☒ Annually
☐ Other (Specify) _____

Model No.: MS 9200 UD

ALARM-INITIATING DEVICES AND CIRCUIT INFORMATION

Quantity

Circuit Style

10	B
4	B
15	B

Manual Fire Alarm Boxes
 Ion Detectors
 Photo Detectors
 Duct Detectors
 Heat Detectors
 Waterflow Switches
 Supervisory Switches
 Other (Specify): _____

Alarm verification feature is disabled _____ enabled _____

(NFPA Inspection and Testing, 1 of 4)

FIGURE 10.5.23 Example of an Inspection and Testing Form.

ALARM NOTIFICATION APPLIANCES AND CIRCUIT INFORMATION		
Quantity	Circuit Style	
6	15	Bells
37	8	Horns
		Chimes
		Strobes
		Speakers
		Other (Specify):
No. of alarm notification appliance circuits: _____		
Are circuits monitored for integrity? ☐ Yes ☐ No		
SUPERVISORY SIGNAL-INITIATING DEVICES AND CIRCUIT INFORMATION		
Quantity	Circuit Style	
		Building Temp.
		Site Water Temp.
		Site Water Level
		Fire Pump Power
		Fire Pump Running
		Fire Pump Auto Position
		Fire Pump or Pump Controller Trouble
		Fire Pump Running
		Generator In Auto Position
		Generator or Controller Trouble
		Switch Transfer
		Generator Engine Running
		Other:
SIGNALLING LINE CIRCUITS		
Quantity and style of signaling line circuits connected to system (see NFPA 72, Table 6.6.1):		
Quantity	Style(s)	
SYSTEM POWER SUPPLIES		
(a) Primary (Main): Nominal Voltage <u>120</u> Amps <u>70</u>		
Overcurrent Protection: Type <u>Breaker</u> Amps <u>10</u>		
Location (of Primary Supply Panelboard): <u>Kitchen</u>		
Disconnecting Means Location: <u>Panel D Breaker 16</u>		
(b) Secondary (Standby): <u>2</u> <u>12</u> Storage Battery: Amp-Hr. Rating <u>12</u>		
Calculated capacity to operate system, in hours: <u>24</u> <u>24</u> <u>60</u>		
Location of fuel storage: _____ Engine-driven generator dedicated to fire alarm system:		
TYPE BATTERY		
☐ Dry Cell		
☐ Nickel-Cadmium		
☒ Sealed Lead-Acid		
☐ Lead-Acid		
☐ Other (Specify):		
(c) Emergency or standby system used as a backup to primary power supply, instead of using a secondary power supply:		
_____ Emergency system described in NFPA 70, Article 700		
_____ Legally required standby described in NFPA 70, Article 701		
_____ Optional standby system described in NFPA 70, Article 702, which also meets the performance requirements of Article 700 or 701.		

(NFPA Inspection and Testing, 2 of 4)

FIGURE 10.6.2.3 Continued

PRIOR TO ANY TESTING					Who	Time
NOTIFICATIONS ARE MADE		Yes	No			
Monitoring Entity		☒	☐			
Building Occupants		☒	☐			
Building Management		☒	☐			
Other (Specify)		☒	☐			
AHJ Notified of Any Impairments		☐	☐			

SYSTEM TESTS AND INSPECTIONS				Comments
TYPE	Visual	Functional		
Control Unit	☒	☒		
Interface Equipment	☒	☒		
Lamps/LEDS	☒	☒		
Fuses	☒	☒		
Primary Power Supply	☒	☒		
Trouble Signals	☒	☒		
Disconnect Switches	☒	☒		
Ground-Fault Monitoring	☐	☒		

SECONDARY POWER				Comments
TYPE	Visual	Functional		
Battery Condition	☒	☒		
Load Voltage		☒		
Discharge Test		☒		
Charger Test		☐		
Specific Gravity		☐		

TRANSIENT SUPPRESSORS	☐			
REMOTE ANNUNCIATORS	☐	☐		
NOTIFICATION APPLIANCES				
Audible	☒	☒		
Visible	☒	☒		
Speakers	☒	☒		
Voice Clarity		☐		

INITIATING AND SUPERVISORY DEVICE TESTS AND INSPECTIONS							
Loc. & S/N	Device Type	Visual Check	Functional Test	Factory Setting	Measured Setting	Pass	Fail
		☐	☐			☐	☐
		☐	☐			☐	☐
		☐	☐			☐	☐
		☐	☐			☐	☐
		☐	☐			☐	☐
		☐	☐			☐	☐

Comments: _____

(NFPA Inspection and Testing, 3 of 4)

FIGURE 10.6.2.3 Continued

EMERGENCY COMMUNICATIONS EQUIPMENT		Visual	Functional	Comments	
Phone Set		☐	☐		
Phone Jacks		☐	☐		
Off-Hook Indicator		☐	☐		
Amplifier(s)		☐	☐		
Tone Generator(s)		☐	☐		
Call-in Signal		☐	☐		
System Performance		☐	☐		
INTERFACE EQUIPMENT		Visual	Device Operation	Simulated Operation	
(Specify) _____		☐	☐	☐	
(Specify) _____		☐	☐	☐	
(Specify) _____		☐	☐	☐	
SPECIAL HAZARD SYSTEMS					
(Specify) _____		☐	☐	☐	
(Specify) _____		☐	☐	☐	
(Specify) _____		☐	☐	☐	
Special Procedures: _____					
Comments: _____					
SUPERVISING STATION MONITORING		Yes	No	Time	Comments
Alarm Signal		☒	☐		
Alarm Restoration		☒	☐		
Trouble Signal		☒	☐		
Supervisory Signal		☒	☐		
Supervisory Restoration		☐	☐		
NOTIFICATIONS THAT TESTING IS COMPLETE		Yes	No	Who	Time
Building Management		☒	☐		
Monitoring Agency		☒	☐		
Building Occupants		☒	☐		
Other (Specify) _____		☐	☐		
The following did not operate correctly: _____					
System restored to normal operation: Date: _____ Time: _____					
THIS TESTING WAS PERFORMED IN ACCORDANCE WITH APPLICABLE NFPA STANDARDS.					
Name of Inspector: <u>Chris Jones</u>		Date: <u>7/21/15</u>		Time: <u>1200</u>	
Signature: <u>[Signature]</u>					
Name of Owner or Representative: _____					
Date: _____		Time: _____			
Signature: _____					
(NFPA Inspection and Testing, 4 of 4)					

FIGURE 10.6.2.3 Continued