

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL092024	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 01/11/2016
NAME OF PROVIDER OR SUPPLIER BRIGHTON GARDENS OF RALEIGH		STREET ADDRESS, CITY, STATE, ZIP CODE 3101 DURALEIGH ROAD RALEIGH, NC 27612		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments This is a Report of a Biennial Construction Survey conducted by Greg Cates and Frank Strickland on January 12, 2016. Based on information gathered from our files, the Facility was first licensed or submitted for licensure on or about January 16, 1996 for One-Hundred Fifteen (115) Beds, including Twenty-Five (25) Special Care Beds. Based on the above information, the facility is required to meet the 1996 Minimum and Desired Standards and Regulations for Homes for the Aged and Disabled; the applicable portions of the 2005 Rules for Adult Care Homes of Seven or More Beds; and the 1996 North Carolina State Building Code Section 409.1- Group I.	C 000		
C 116	Plans Submittals and Approvals SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0304 PLANS AND SPECIFICATIONS (a) When construction or remodeling of an adult care home is planned, two copies of Construction Documents and specifications shall be submitted by the applicant or appointed representative to the Division for review and approval. As a preliminary step to avoid last minute difficulty with final plan approval, Schematic Design Drawings and Design Development Drawings may be submitted for approval prior to the required submission of Construction Documents. (b) Approval of Construction Documents and specifications shall be obtained from the Division prior to licensure. Approval of Construction Documents shall expire after one year unless a building permit for the construction has been obtained. (c) If an approval expires, renewed approval	C 116		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL092024	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 01/11/2016
NAME OF PROVIDER OR SUPPLIER BRIGHTON GARDENS OF RALEIGH		STREET ADDRESS, CITY, STATE, ZIP CODE 3101 DURALEIGH ROAD RALEIGH, NC 27612		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 116	Continued From page 1 shall be issued by the Division, provided revised Construction Documents meeting all current regulations, codes and standards are submitted by the applicant or appointed representative and reviewed by the Division. (d) Any changes made during construction shall require the approval of the Division to assure that licensing requirements are maintained. (e) Completed construction or remodeling shall conform to the requirements of this Section including the operation of all building systems and shall be approved in writing by the Division prior to licensure or occupancy. Within 90 days following licensure, the owner or licensee shall submit documentation to the Division that "as built" drawings have been received from the builder. (f) The applicant or designated agent shall notify the Division when actual construction or remodeling starts and at points when construction is 50 percent, 75 percent and 90 percent complete and upon final completion. This Rule is not met as evidenced by: 1- Based on observations, the facility has failed to obtain the required approvals for changes to the magnetic locking systems. This may affect all persons in the Special Care Unit by prohibiting them from exiting in the event of an emergency. Findings include: a- On February 5, 2015, a letter was received by DHSR-Construction for "changes in the egress door operation" at the exterior doors. This document indicates that the doors were special locking and have emergency release switches at each exterior door. No	C 116		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL092024	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 01/11/2016
NAME OF PROVIDER OR SUPPLIER BRIGHTON GARDENS OF RALEIGH		STREET ADDRESS, CITY, STATE, ZIP CODE 3101 DURALEIGH ROAD RALEIGH, NC 27612		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 116	Continued From page 2 response was received by DHSR- Construction to the review letter sent April 21, 2015. At the January 11, 2016 survey, it was observed that there are no emergency release switches at the exterior doors and that changes appear to have been made to the previously existing system without approval from DHSR- Construction.	C 116		
C 164	Housekeeping and Furnishings-Clean, Repaired SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0306 HOUSEKEEPING AND FURNISHINGS (a) Adult care homes shall: (1) have walls, ceilings, and floors or floor coverings kept clean and in good repair; (2) have no chronic unpleasant odors; (3) have furniture clean and in good repair; (e) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1- Based on observations, the facility has failed to maintain the building and furnishings in good repair and clean. Findings include: a- The carpet in the Living of Room 357 is stained and discolored. b- One of the drawer pulls on the vanity in the bathroom of Room 164 is loose. c- The ceiling tiles in the Living Room of the Special Care Unit are stained and discolored. d- There is a ceiling tile missing in the Activity Room.	C 164		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL092024	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 01/11/2016
NAME OF PROVIDER OR SUPPLIER BRIGHTON GARDENS OF RALEIGH		STREET ADDRESS, CITY, STATE, ZIP CODE 3101 DURALEIGH ROAD RALEIGH, NC 27612		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 166	Housekeeping-Maintained Free of Hazards SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0306 HOUSEKEEPING AND FURNISHINGS (a) Adult care homes shall: (5) be maintained in an uncluttered, clean and orderly manner, free of all obstructions and hazards; (e) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1- Based on observations, the facility has failed to maintain the building free of hazards by not storing oxygen containers securely to prevent them from falling over or rolling around. This could affect all persons in the facility as the oxygen containers could fall over, damaging the cylinder or nozzle. Findings include: a- There are oxygen bottles in Room 342 that are not properly supported. b- There are oxygen bottles in Room 214 that are not properly supported. c- There are oxygen bottles in Room 241 that are not properly supported. 2- Based on observations, the facility has failed to maintain the building free of hazards by not securing grab bars tightly to the wall. This could affect persons who may need the assistance of a grab bar when seating or rising from the commode. Findings include: a- The grab bar beside the commode in the unisex Bath on the 3rd Floor is loose.	C 166		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL092024	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 01/11/2016
NAME OF PROVIDER OR SUPPLIER BRIGHTON GARDENS OF RALEIGH		STREET ADDRESS, CITY, STATE, ZIP CODE 3101 DURALEIGH ROAD RALEIGH, NC 27612		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 166	Continued From page 4 3- Based on observations, the facility has failed to maintain the building free of hazards by not securing the commode seat tightly to the commode. This could affect anyone who may use the toilet by allowing them to slide off the commode. Findings include: a- The seat is loose on the commode in the Unisex Bathroom on the 3rd Floor b- The seat is loose on the commode in the Unisex Bathroom on the 2nd Floor. 4- Based on observations, the facility has failed to maintain the emergency exiting from the refrigerator. This could allow a person to become locked in the refrigerator with no way of exiting in the event of an emergency. Findings include: a- The emergency exiting hardware on the inside of the refrigerator is broken and cannot be turned to release the lock.	C 166		
C 189	Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities.	C 189		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL092024	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 01/11/2016
NAME OF PROVIDER OR SUPPLIER BRIGHTON GARDENS OF RALEIGH		STREET ADDRESS, CITY, STATE, ZIP CODE 3101 DURALEIGH ROAD RALEIGH, NC 27612		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 189	Continued From page 5 This Rule is not met as evidenced by: 1- Based on observations, the facility has failed to ensure that the building is safe by not maintaining the fire resistance of building components. This deficiency directly affect all residents, personnel, and visitors by allowing the possible spread of smoke beyond the compartment of origin. Findings include: a- There is a kick-down device on the corridor door of the Staff Breakroom. b- There is a kick-down device on the corridor door of the Maintenance Office. c- In the Community Laundry Rooms, there is a hole approximately 1-inch in diameter above the door for data cabling that is not sealed. d- In the 1st Floor Storage Room, there is a communications conduit that is not sealed on the ends. e- In the 1st Floor Storage Room, there are several electrical conduits where the wall above them is not sealed. f- In the Main Mechanical Room, there is a hole around a conduit above the corridor door that is not sealed. g- In the Main Mechanical Room, there is a conduit above the telephone equipment that is not sealed on the end. h- In the 3rd Floor in the Laundry, there is an open gap above the door at the closer. i- The corridor door to the Maintenance Office does not latch when closed. 2- Based on observations, the facility has failed to maintain the safety systems in operating condition. This could affect all occupants of the	C 189		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL092024	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 01/11/2016
NAME OF PROVIDER OR SUPPLIER BRIGHTON GARDENS OF RALEIGH		STREET ADDRESS, CITY, STATE, ZIP CODE 3101 DURALEIGH ROAD RALEIGH, NC 27612		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 189	Continued From page 6 building in the event of a power failure. Findings include: There is a pattern of emergency lights that do not illuminate on battery. Locations to include but not limited to: a- EL #96 b- EL #28 c- EL #14 d- Stair 1, Level 1 3- Based on observations, the facility has failed to maintain the building electrical system safe and operating. This deficiency may affect those persons using the receptacles by allowing the possibility of electrical shock. Findings include: a- In the Beauty Parlor, there are quad GFCI receptacles beside the two sinks that are within 2 feet of the sinks but are not GFCI protected. b- There is a light fixture in the 2nd Floor Storage Room that is not secure to the wall. c- There is an open junction box on the ceiling in the Main Mechanical Room.	C 189		