

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL063011	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED C 02/03/2016
NAME OF PROVIDER OR SUPPLIER TARA PLANTATION OF CARTHAGE		STREET ADDRESS, CITY, STATE, ZIP CODE 820 S. MCNEILL STREET CARTHAGE, NC 28327		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments Report of Complaint Survey by Frank Strickland on 02/03/2016: This facility was first licensed on 09/23/1997 as a Home for the Aged serving Eighty (80) Residents with Forty (40) Residents being in a Alzheimer's wing. Therefore, this facility must meet the 1996 and the applicable portions of the 2005 Rules for the Licensing of Adult Care Homes and the 1996 North Carolina State Building Code- Section 409 Institutional Occupancy (Group I-2). Site survey findings substantiated the complaint with cited deficiencies and a Plan of Correction is required.	C 000		
C 164	Housekeeping and Furnishings-Clean, Repaired SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0306 HOUSEKEEPING AND FURNISHINGS (a) Adult care homes shall: (1) have walls, ceilings, and floors or floor coverings kept clean and in good repair; (2) have no chronic unpleasant odors; (3) have furniture clean and in good repair; (e) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1-Based on observation, the facility had a fire in the Laundry Room that started in the clothes hamper from linens that just came out of the dryer that later spontaneously combusted. a. The smoke detector in the room was partially destroyed due to the fire. b. There were portions of the ceiling and	C 164		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL063011	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED C 02/03/2016
NAME OF PROVIDER OR SUPPLIER TARA PLANTATION OF CARTHAGE		STREET ADDRESS, CITY, STATE, ZIP CODE 820 S. MCNEILL STREET CARTHAGE, NC 28327		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 164	Continued From page 1 surrounding walls that received smoke damage. c. The RFP panels in the corner where the fire originated were damaged due to the fire.	C 164		