

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: FCL079089	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 02/12/2016
NAME OF PROVIDER OR SUPPLIER SAFE HAVEN # 2		STREET ADDRESS, CITY, STATE, ZIP CODE 157 GLENDALE DRIVE EDEN, NC 27288		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments Report by Glenn Hoppin DHSR Construction Section conducted a Biennial Survey on February 12, 2016 from 2:00pm until 3:30pm at the above referenced facility. DHSR records indicate the home was first licensed on August 1, 2012 as a Family Care Home for six (6) ambulatory Residents (able to evacuate and respond without any physical or verbal assistance during a fire or other emergency). Based on this information we are requiring the home to maintain compliance with the following: the 2005 Rules 10A NCAC 13G for Family Care Homes, the 2009 North Carolina State Building Code - Section 421.2 - Residential Care Homes At the time of our visit, we cited deficiencies that require an acceptable plan of correction. They are as follows:	C 000		
C 174	Building Equipment Maintained Safe, Operating SECTION .0300 - THE BUILDING 10A NCAC 13G .0317 BUILDING SERVICE EQUIPMENT (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in a family care home shall be maintained in a safe and operating condition. (j) This Rule shall apply to new and existing family care homes. This Rule is not met as evidenced by: 1. Observations revealed that the range hood was not working at the time of the survey. Have a qualified technician repair or replace the range hood. Provide receipts and photo documentation to the DHSR Construction Section when this repair is completed.	C 174		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: FCL079089	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED 02/12/2016
NAME OF PROVIDER OR SUPPLIER SAFE HAVEN # 2		STREET ADDRESS, CITY, STATE, ZIP CODE 157 GLENDALE DRIVE EDEN, NC 27288		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 174	Continued From page 1 2. Observations revealed that the rear railing on the back porch was rusted and separating from the building. Have a qualified technician repair or replace the railing. Provide photo documentation to the DHSR Construction Section when this repair is complete. 3. Observations revealed lint and clothes behind the dryer. Clean all lint and remove all clothes from behind the dryer. Provide photo documentation to the DHSR Construction Section. 4. Observations revealed that there was furniture blocking the windows in the resident bedroom #2. Rearrange the furniture so that there is one operable window available for emergency egress in the event of a fire or other emergency. Provide the DHSR Construction Section with photo documentation when this is complete.	C 174		