

PRINTED: 11/29/2016
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL095008	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED R 11/16/2016
NAME OF PROVIDER OR SUPPLIER DEERFIELD RIDGE ASSISTED LIVING		STREET ADDRESS, CITY, STATE, ZIP CODE 287 BAMBOO ROAD BOONE, NC 28607		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 000}	Initial Comments Report of Follow-up Survey by Dennis Harrell on 11-16-2016. Not all deficiencies were corrected. Further action is required.	{C 000}		
{C 166}	Housekeeping-Maintained Free of Hazards SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0306 HOUSEKEEPING AND FURNISHINGS (a) Adult care homes shall: (5) be maintained in an uncluttered, clean and orderly manner, free of all obstructions and hazards; (e) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: Based on observation, the hoses on the shower wands at both sinks in the Beauty Salon were long enough to reach the sink basins and there were no vacuum breakers provided. Hoses on water fixtures that are long enough to reach the flood rim of the fixture present the possibility of siphoning contaminated water into the water system unless a vacuum breaker is installed.	{C 166}	On 11.18.16 - Vacuum breaker installed. Education completed with beautician on why vacuum breaker must be kept in place. Maintenance will follow up weekly for the next 90 days to ensure breakers are working properly & quarterly thereafter. ON 11.16.16 was when education was completed with beautician.	11-18-16

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

STATE FORM

6899

4CYN22

If continuation sheet 1 of 1