

PRINTED: 04/18/2017
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL088011	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED R 04/06/2017
NAME OF PROVIDER OR SUPPLIER RICH SQUARE MANOR		STREET ADDRESS, CITY, STATE, ZIP CODE 400 N MAIN STREET RICH SQUARE, NC 27869		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
(C 000)	Initial Comments Report of Follow-up Survey by Dennis Harrell on 4-6-2017. Some deficiencies were not corrected. Further action is required.	(C 000)		
(C 188)	Housekeeping-Maintained Free of Hazards SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0306 HOUSEKEEPING AND FURNISHINGS (a) Adult care homes shall: (5) be maintained in an uncluttered, clean and orderly manner, free of all obstructions and hazards; (e) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: Based on observation, the building was not maintained in a safe manner by not properly handling portable medical oxygen cylinders. This could affect all residents, staff and visitors if cylinders fall, breaking their valves, propelling the cylinder and turning it into a dangerous projectile. Finding includes: A portable medical oxygen cylinder were stored in no approved container in the med room. Finding on 4-6-2017: Several portable medical oxygen cylinders were now stored in an unapproved beverage crate. Note: This deficiency was corrected during the survey.	(C 188)		
(C 189)	Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER	(C 189)		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

STATE FORM

0000

XQJV22

Administrator

May 2, 2017

If continuation sheet 1 of 2

