


Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL021008	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 05/04/2017
NAME OF PROVIDER OR SUPPLIER EDENTON PRIME TIME RETIREMENT VILLAGE		STREET ADDRESS, CITY, STATE, ZIP CODE 105 MARK DRIVE EDENTON, NC 27932		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments Construction Section Biennial Survey report by Frank Strickland on 05/04/2017: The A, B, C wings of this facility were first licensed on 09/05/1985 as a Home for the Aged. This facility is currently licensed for 60 Beds w/10 BED SCU. Therefore, this facility was surveyed for conformance with the applicable portions of the 2005 Rules for Licensing of Adult Care Homes of Seven or More Beds, the 1978 (Revision 5) Edition of the North Carolina State Building Code(s)-Institutional Occupancy, and the 1984 Minimum Standards and Regulations for Homes for the Aged in effect at time of initial licensure. The rear D wing of the facility was built in 2010 must meet the 2009 NC State Building Code, Institutional Occupancy and the 2005 Rules for Adult Care Homes The facility is currently licensed for 60 Beds. Deficiencies have been cited and a Plan of Correction is required.	C 000		
C 160	Outside Premises-Clean, Safe SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0305 PHYSICAL ENVIRONMENT (m) The requirements for outside premises are: (1) The outside grounds of new and existing facilities shall be maintained in a clean and safe condition; This Rule is not met as evidenced by: 1- Based on observation, this facility has failed to maintain the exterior finish components around doors and windows.	C 160		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

Mitchell Moran



TITLE

Director of Maintenance

(X6) DATE

6/2/17

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL021008	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/04/2017
NAME OF PROVIDER OR SUPPLIER EDENTON PRIME TIME RETIREMENT VILLAGE		STREET ADDRESS, CITY, STATE, ZIP CODE 105 MARK DRIVE EDENTON, NC 27932		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 160	Continued From page 1 Findings on 05/04/2017: The plastic window shutter has become unfastened to the brick veneer outside Room 125.	C 160 A	reattached to building picture is attached	5/22/17
C 164	Housekeeping and Furnishings-Clean, Repaired SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0306 HOUSEKEEPING AND FURNISHINGS (a) Adult care homes shall: (1) have walls, ceilings, and floors or floor coverings kept clean and in good repair; (2) have no chronic unpleasant odors; (3) have furniture clean and in good repair; (e) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1-Based on observation, this facility has failed to maintained the interior doors and door operating hardware in a safe and operating condition. Findings on 05/04/2017: The entry door from the Dining Hall into the Kitchen top hinge that is unsecured and the door did not latch.	C 164 A	Hinge was seceured to frame and door will latch picture is attached	5/22/17
C 189	Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e)	C 189		

Division of Health Service Regulation
STATE FORM