

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL086006	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 06/22/2017
NAME OF PROVIDER OR SUPPLIER DUNMORE PLANTATION		STREET ADDRESS, CITY, STATE, ZIP CODE 515 W. KAPP STREET DOBSON, NC 27017		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments Report of a Construction Section Biennial Survey by Suzanna Fay conducted on June 22, 2017. Records indicate this facility was first licensed on March 1, 1973. The facility is currently licensed for sixty Beds including a thirty Bed Special Care Unit. Therefore the facility was surveyed for conformance with the 2005 Rules for Licensing of Adult Care Homes of Seven or More Beds and applicable portions of the 1967 Edition of the North Carolina Building Code, Institutional Occupancy, and the 1971 Rules for Licensing of Adult Care Homes of Seven or More Beds in effect at the time of initial licensure.	C 000		
C 111	Must Have Current San. & Fire Safety Reports SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0302 DESIGN AND CONSTRUCTION f) The facility shall have current sanitation and fire and building safety inspection reports which shall be maintained in the home and available for review. This Rule is not met as evidenced by: 1. Review of records revealed that the facility did not maintain current fire inspection reports in the facility for review. Findings on June 22, 2017: a. A copy of the annual fire inspection report was not available for review. A current fire inspection report received on June 26, 2017 was not approved.	C 111	Annual Fire Inspection Report was completed and in Facility Inspections binder Fire Marshals report was conducted on 3/7/17 and in Facility Inspections binder Fire Marshal was contacted on 3/8/17 for followup	9/14/16
C 132	Bathrooms-Must Provide Privacy	C 132		

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

STATE FORM

6900

N1ST21

If continuation sheet 1 of 5

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL086006	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 06/22/2017
NAME OF PROVIDER OR SUPPLIER DUNMORE PLANTATION		STREET ADDRESS, CITY, STATE, ZIP CODE 515 W. KAPP STREET DOBSON, NC 27017		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 132	Continued From page 1 SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0305 PHYSICAL ENVIRONMENT (e) The requirements for bathrooms and toilet rooms are: (5) The bathrooms and toilet rooms shall be designed to provide privacy. Bathrooms and toilet rooms with two or more water closets (commodes) shall have privacy partitions or curtains for each water closet. Each tub or shower shall have privacy partitions or curtains; This Rule is not met as evidenced by: 1. Observations revealed that the facility failed to provide privacy for the commodes in one bathroom. Findings on June 22, 2017: a. B Hall Main bath - the commodes had one privacy curtain for both toilets.	C 132		
C 164	Housekeeping and Furnishings-Clean, Repaired SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0306 HOUSEKEEPING AND FURNISHINGS (a) Adult care homes shall: (1) have walls, ceilings, and floors or floor coverings kept clean and in good repair; (2) have no chronic unpleasant odors; (3) have furniture clean and in good repair; (e) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1. Observations revealed that the ceilings were not maintained in good repair. Findings on June 22, 2017:	C 164	Will add privacy curtain to existing partition	8/15/17

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL086006	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 06/22/2017
NAME OF PROVIDER OR SUPPLIER DUNMORE PLANTATION		STREET ADDRESS, CITY, STATE, ZIP CODE 515 W. KAPP STREET DOBSON, NC 27017		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 164	Continued From page 2 a. Dining room - there is an 18" long oval water stain on the ceiling near the side exit. The ceiling finish is splitting open at the middle of this stain. 2. Observations revealed that the floors were not maintained in good repair. Findings on June 22, 2017: a. Room 124 - the threshold at the corridor door is broken and approximately 2/3's of the threshold is missing. 3. Observations revealed that the exit doors are not maintained in good repair. Findings on June 22, 2017: a. The door at Exit 7 (at B Wing lounge) is dragging on the frame making it difficult to open. b. The door hardware at Exit 2 (to SCU courtyard) is loose.	C 164	Contractor has been contacted 8/15/17 to repair ceiling Threshold repaired A) Door will be repaired B) Hardware repaired and in good working condition	8/15/17 6/22/17 8/15/17 6/22/17
C 189	Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Based on observation there is a failure to maintain the facility's fire safety equipment in a safe operating condition. The occupants in the	C 189		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL086006	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 06/22/2017
NAME OF PROVIDER OR SUPPLIER DUNMORE PLANTATION		STREET ADDRESS, CITY, STATE, ZIP CODE 515 W. KAPP STREET DOBSON, NC 27017		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 189	Continued From page 3 smoke compartment could be effected if doors do not completely close and latch to help limit the spread of smoke or fire to the area of origin. Findings on June 22, 2017: a. The door separating the dining room and kitchen did not close and latch when released by the fire alarm. The floor magnetic hold open devices were loose. 2. Based on observation the facility's fire safety equipment is not maintained in operating condition. Failure to maintain fire safety equipment in operating condition could effect occupants of the facility if the equipment did not operate properly to provide the required protection function. Findings on June 22, 2017: a. The exit light at the kitchen back door did not illuminate on emergency test. b. The emergency light outside of Room 119 (B Wing) was not working. 3. Based on observation there is a failure to maintain the facility's fire safety equipment in a safe operating condition. To be able to resist the passage of smoke resident room doors must not have gaps or openings in the doors. Findings on June 22, 2017: a. Med Room on SCU side - the door hardware is loose creating a hole in the door.	C 189	Repaired and in good working Condition 6/22/17 A) Exit Light in good working Condition 7/20/17 B) Emergency light replaced 6/23/17 and in good working Condition Repaired and in good working Condition 7/3/17	
C 199	Exhaust Ventilation SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS	C 199		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL086006	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 06/22/2017
NAME OF PROVIDER OR SUPPLIER DUNMORE PLANTATION		STREET ADDRESS, CITY, STATE, ZIP CODE 515 W. KAPP STREET DOBSON, NC 27017		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 199	Continued From page 4 (g) The spaces listed in this Paragraph shall be provided with exhaust ventilation at the rate of two cubic feet per minute per square foot. This requirement does not apply to facilities licensed before April 1, 1984, with natural ventilation in these specified spaces: (1) soiled linen storage; (2) soil utility room; (3) bathrooms and toilet rooms; (4) housekeeping closets; and (5) laundry area. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Observations revealed that some of the bathrooms did not have a working exhaust to provide ventilation at the rate of two cubic feet per minute per square foot. Findings on June 22, 2017: a. Room 126 - the bathroom exhaust fan was not working. b. Room 112 - the bathroom exhaust fan was not working.	C 199	New exhaust fans purchased 7/3/17 and delivered for repair 8/15/17	

**SURRY COUNTY
FIRE MARSHAL'S OFFICE
FIRE PREVENTION INSPECTION REPORT**

ORDER TO COMPLY

DATE 3/7/17

PAGE 1 OF 1

OCCUPANT Dunmore Plantation

INSPECTION POINTED OUT TO _____

REASON FOR INSPECTION: ADDITION _____ ALTERATION _____ COMPLAINT _____

FINAL _____ FPI ☒ INSTALL _____ NEW CONST _____ PERMIT _____

REPAIR _____ REMODEL _____ ROUGH-IN _____ UPFIT _____ VSI _____

PERMITS _____

VIOLATION	CORRECTION
Emergency Light out	Repaired 3/8/2017
Fire Alarm system needs testing	Annual Test completed 9/14/16
Fire Extinguishers need's servicing	9/14/16 and 3/8/2017
Hood system need's	Serviced 3/8/2017

SEE ATTACHED FORMS

PURSUANT TO NCGS 153A-365 AND 160A-425 ALL VIOLATIONS/HAZARDS NOTED ABOVE OR ON ANY ATTACHED FORMS SHALL BE CORRECTED IMMEDIATELY. THE PREMISIS WILL BE REINSPECTED IN NO LESS THAN _____ DAYS FROM THE DATE LISTED AT THE TOP OF THIS REPORT. IF YOU HAVE ANY QUESTIONS, YOU MAY CONTACT THE SURRY COUNTY FIRE MARSHAL'S OFFICE AT 336-783-9040.

FIRE PREVENTION INSPECTOR'S SIGNATURE

Jimmy Ashburn

OCCUPANT/OWNER'S SIGNATURE

INSPECTION AND TESTING FORM

DATE: 9-14-16TIME: 12:50 pm

SERVICE ORGANIZATION

Name: Industrial Fire & SafetyAddress: 766 N. Smith Street Mt. AiryRepresentative: Jim FellLicense No: 18778Telephone: 336-789-5400

PROPERTY NAME (USER)

Name: DunmoreAddress: Dunson

Owner Contact: _____

Telephone: _____

MONITORING ENTITY

Contact: 911Telephone: 336 374-3000

Monitoring Account Ref. No: _____

APPROVING AGENCY

Contact: _____

Telephone: _____

TYPE TRANSMISSION

☐ McCulloh☐ Multiplex☐ Digital☐ Reverse☐ RF☒ Other(specify) Dialer

SERVICE

☐ Weekly☐ Monthly☐ Quarterly☐ Semiannually☒ Annually☐ Other (specify) _____Control Unit Manufacturer: ESLCircuit Styles: BNumber of Circuits: 5Software Rev.: CLast Date System Had Any Service Performed: 7-15Last Date that Any Software or Configuration Was Revised: FactoryModel No: 1505

Serial No: _____

ALARM - INITIATING DEVICES AND CIRCUIT INFORMATION

Quantity

Circuit Style

6B03210B5400Alarm verification feature is disabled _____ enabled NA

Manual Fire Alarm Boxes

Ion Detectors

Photo Detectors

Duct Detectors

Heat Detectors

Water flow Switches

Supervisory Switches

Other (Specify) _____

FIGURE 10.6.2.3. Example of an Inspection and Testing Form

2002 National Fire Alarm Code

ALARM NOTIFICATION APPLIANCES AND CIRCUIT INFORMATION

Quantity	Circuit Style	
3	B	BELLS
0		HORNS
0		CHIMES
1	B	STROBES
	B	SPEAKERS
		Other (Specify) _____

No. of alarm notification appliance circuits: 2

Are circuits monitored for integrity? ☒ Yes ☐ No

SUPERVISORY SIGNAL-INITIATING DEVICES AND CIRCUIT INFORMATION

Quantity	Circuit Style	
NA		Building Temp.
		Site Water Temp.
		Site Water Level
		Fire Pump Power
		Fire Pump Running
		Fire Pump Auto Position
		Fire Pump or Pump Controller Trouble
		Generator in Auto Position
		Generator or Controller Trouble
		Switch Transfer
		Generator Engine Running
		Other (Specify) _____

SIGNALING LINE CIRCUITS

QUANTITY and Style (see NFPA 72, Table 3-6) of signaling line circuits connected to system:

Quantity 1 Style B

SYSTEM POWER SUPPLIES

- A. Primary (main): Nominal Voltage 120 V Amps 8.5
 Overcurrent Protection: Type Breaker Amps 20
 Location (of Primary Supply Panel board): Itall Nurses Desk
 Disconnecting Means Location: Elec. Room
- B. Secondary (standby):
2-12 volt Storage Battery: Amp-Hr. Rating 7 Ah
 Calculated capacity to operate system, in hours: ✓ 24 60
NA Engine-driven generator dedicated to fire alarm system
 Location of Fuel Storage: _____

TYPE BATTERY

- ☐ Dry Cell
☐ Nickel-Cadmium
☒ Sealed Lead-Acid
☐ Lead-Acid
☐ Other (specify): _____

- C. Emergency or standby system used as a backup to primary power supply, instead of using a secondary power supply:

NA Emergency system described in NFPA 70, Article 700
NA Legally required standby described in NFPA 70, Article 701
NA Optional standby system described in NFPA 70, Article 702
 which also meets the performance requirements of Article 700 or 701

PRIOR TO ANY TESTING

NOTIFICATIONS ARE MADE

	YES	NO	WHO	TIME
Monitoring Entity	☒	☐		
Building Occupants	☒	☐		
Building Management	☒	☐		
Other (specify)	☐	☐		
AHJ (notified) of any Impairments	☐	☐		

SYSTEM TESTS AND INSPECTIONS

TYPE	Visible	Functional	Comments
Control Unit	☒	☒	
Interface Equipment	☒	☒	
Lamps/LEDS	☐	☐	
Fuses	☐	☐	
Primary Power Supply	☐	☐	
Trouble Signals	☐	☐	
Disconnect Switches	☐	☐	
Ground Fault Monitoring	☐	☐	

SECONDARY POWER

TYPE	Visible	Functional	Comments
Battery Condition	☒		
Load Voltage		☒	
Discharge Test		☒	
Charger Test		☒	
Specific Gravity		☐	
Transient Suppressors	☐	☐	
Remote Annunciators	☐	☐	
Notification Appliances	☒	☒	
Audible	☐	☒	
Visual	☒	☒	
Speakers	☐	☐	
Voice Clarity		☐	

INITIATING AND SUPERVISORY DEVICE TESTS AND INSPECTIONS

Loc. & S/N	Device Type	Visual Check	Functional Test	Factory Setting	Meas. Setting	Pass	Fail
		☐	☐			☐	☐
		☐	☐			☐	☐
	NA	☐	☐			☐	☐
		☐	☐			☐	☐
		☐	☐			☐	☐
		☐	☐			☐	☐
Comments							

EMERGENCY COMMUNICATIONS EQUIPMENT

	Visual	Functional	Comments
Phone Sets	☐	☐	
Phone Jack	☒	☒	
Off-Hook Indicator	☐	☐	
Amplifier	☐	☐	
Tone Generator	☐	☐	
Call-in Signal	☒	☒	
System Performance	☒	☒	

INTERFACE EQUIPMENT

(Specify) <u>Door mag.</u>	Visual	Device Operation	Simulated Operation
(Specify) _____	☒	☒	☒
(Specify) _____	☐	☐	☐
(Specify) _____	☐	☐	☐

SPECIAL HAZARD SYSTEMS

(Specify) _____	Visual	Device Operation	Simulated Operation
(Specify) _____ <u>NA</u>	☐	☐	☐
(Specify) _____	☐	☐	☐
(Specify) _____	☐	☐	☐

Special Procedures: _____

Comments: _____

Supervising Station Monitoring	YES	NO	TIME	Comments
Alarm Signal	☒	☐		
Alarm Restoration	☒	☐		
Trouble Signal	☒	☐		
Supervisory Signal	☒	☐		
Supervisory Restoration	☒	☐		

Notifications That Testing Is Complete

	YES	NO	WHO	TIME
Building Management	☒	☐		
Monitoring Agency	☒	☐		
Building Occupants	☒	☐		
Other(specify) _____	☐	☐		

The Following Did Not Operate Correctly: _____

System restored to normal operation: Date: 9-14-16Time: 3:30 pm**THIS TESTING WAS PERFORMED IN ACCORDANCE WITH APPLICABLE NFPA STANDARDS.**Name of Inspector: Jim Pell Date: 9-14-16 Time: 3:35 pmSignature: Jim PellName of Owner or Representative: Zachary R HorneDate: 9-14-16Time: 3:35 pmSignature: Zachary R Horne