

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL008041	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED C 06/07/2017
---	---	--	--

NAME OF PROVIDER OR SUPPLIER

STREET ADDRESS, CITY, STATE, ZIP CODE

WINSTON GARDENS

**205 WEST WATSON STREET
WINDSOR, NC 27983**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------------	--	---------------------	--	--------------------------

C 000 Initial Comments

C 000

Report of a Construction Section Complaint
Survey by Billy S. Bryant and Ed Miller conducted
on 06/07/2017.

Records indicate this facility was first licensed on
10/01/1957. The facility is currently licensed for
25 Beds. Therefore the facility was surveyed for
conformance with the 1971 Rules for Licensing of
Adult Care Homes of Seven or More Beds and
applicable portions of the (current) 2005 Rules for
Licensing of Adult Care Homes of Seven or More
Beds.

The complaint alleged that the facility has no
working bulbs in light fixtures down the hallway
and in the living room.

The complaint was substantiated.

C 189 Building Equipment Maintained Safe, Operating

C 189

SECTION .0300 - PHYSICAL PLANT
10A NCAC 13F .0311 OTHER
REQUIREMENTS

(a) The building and all fire safety, electrical,
mechanical, and plumbing equipment in an adult
care home shall be maintained in a safe and
operating condition.

(k) This Rule shall apply to new and existing
facilities with the exception of Paragraph (e)
which shall not apply to existing facilities.

This Rule is not met as evidenced by:

1. Based on observation all of the fire safety
equipment was not maintained in a safe and
operating condition as relates to the fire alarm
system.

RECEIVED IN
AUG 25 2017
CONSTRUCTION SECTION

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

DATE FORM

0000

V11021

If continuation sheet 1 of 3

Dianna Turner-Benton

Administrator

8/3/17

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL008041	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED C 06/07/2017
NAME OF PROVIDER OR SUPPLIER WINSTON GARDENS		STREET ADDRESS, CITY, STATE, ZIP CODE 205 WEST WATSON STREET WINDSOR, NC 27983			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 189	Continued From page 1 Findings on 06/07/2017 a. There was a trouble indicated on the fire alarm system. 2. Based on observation and an interview with the facility manager it was determined that the electrical equipment in the facility is not maintained in operating condition. Findings on 06/07/2017: a. Living Room - There are 2 ceiling fans in the living room both with three lamp holders in each fixture. None of the bulbs were burning when the surveyor arrived on site. b. There are eight residential type light fixtures mounted on the ceiling in the hallway. The fixtures were rated for 60W bulbs. One of the eight fixtures did not have working bulbs when the surveyors were on site. c. An interview with the facility manager revealed that light bulbs in the fixtures burn out and have to be changed anywhere from every two weeks to every month. d. An interview with the facility manager revealed that a licensed electrician has not been called to the facility to trouble shoot the problem.		C 189		
C 197	General Lighting SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (f) In addition to the required emergency lighting, minimum lighting shall be as follows: (1) 30 foot-candle power for reading;		C 197		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL008041	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED C 06/07/2017
---	---	--	--

NAME OF PROVIDER OR SUPPLIER

WINSTON GARDENS

STREET ADDRESS, CITY, STATE, ZIP CODE

**205 WEST WATSON STREET
WINDSOR, NC 27983**

ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
---------------------	--	---------------------	--	--------------------------

C 197 Continued From page 2

(2) 10 foot-candle power for general lighting; and
(k) This Rule shall apply to new and existing
facilities with the exception of Paragraph (e)
which shall not apply to existing facilities.

This Rule is not met as evidenced by:
1. Based on observation the facility appears not
to provide the required minimum lighting.

Finding on 06.07/2017:

a. It appears that the current light fixtures in the
living area do not meet the minimum of 30
foot-candle power for reading and down the
hallway the minimum 10 foot-candle power for
general lighting.

C 197