

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL041033	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED R 06/27/2017
NAME OF PROVIDER OR SUPPLIER BROOKDALE HIGH POINT NORTH			STREET ADDRESS, CITY, STATE, ZIP CODE 1564 SKEET CLUB ROAD HIGH POINT, NC 27265		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
{C 000}	Initial Comments Report of Biennial Follow Up Construction Survey by Ed Miller, on June 27, 2017. Deficiencies were cited that will require a new Plan of Correction.	{C 000}			
{C 101}	Existing Licensed Fac- No less than '71 Rules SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0301 APPLICATION OF PHYSICAL PLANT REQUIREMENTS The physical plant requirements for each adult care home shall be applied as follows: (2) Except where otherwise specified, existing licensed facilities or portions of existing licensed facilities shall meet licensure and code requirements in effect at the time of construction, change in service or bed count, addition, renovation, or alteration; however in no case shall the requirements for any licensed facility where no addition or renovation has been made, be less than those requirements found in the 1971 "Minimum and Desired Standards and Regulations" for "Homes for the Aged and Infirm", copies of which are available at the Division of Health Service Regulation at no cost; This Rule is not met as evidenced by: 1. Based on observations, the special locking did not meet the requirements of the code requirements at the time of licensure. Findings on June 27, 2017: a. Front Exit and Sun Room Exit - the key override for these exit doors are momentary switches. The switch has be in the locked position to remove the key. The doors lock back when the key is removed which could trap	{C 101}	<i>front door and back gate exit lock was repaired with new locks</i>	<i>7-12-17</i>	

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

STATE FORM

5530

885J22

Executive Director

07/14/17

If continuation sheet 1 of 6

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL041033	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED R 06/27/2017
NAME OF PROVIDER OR SUPPLIER BROOKDALE HIGH POINT NORTH		STREET ADDRESS, CITY, STATE, ZIP CODE 1564 SKEET CLUB ROAD HIGH POINT, NC 27285		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 101}	Continued From page 1 Residents in the facility if the door hardware fails to operate during an emergency. Per the Maintenance Director and Alarm Tech, these doors will be fixed next week. b. The kitchen exit did not release when the fire alarm was activated. Per the Maintenance Director and Alarm Tech a new power supply is on order and will be in next week.	{C 101}	<i>Door release switch was installed 7-17-17 by Advance Fire & Communication</i>	
{C 111}	Must Have Current San. & Fire Safety Reports SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0302 DESIGN AND CONSTRUCTION f) The facility shall have current sanitation and fire and building safety inspection reports which shall be maintained in the home and available for review. This Rule is not met as evidenced by: 1. Review of records revealed that the facility did not have current sanitation and fire safety inspection reports. Findings on June 27, 2017: b. Records indicate that the last Fire Inspection was conducted on September 11, 2015. Per the Maintenance Director, he has requested inspection.	{C 111}		
{C 164}	Housekeeping and Furnishings-Clean, Repaired SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0306 HOUSEKEEPING AND FURNISHINGS (a) Adult care homes shall: (1) have walls, ceilings, and floors or floor coverings kept clean and in good repair; (2) have no chronic unpleasant odors;	{C 164}		

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL041033	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED R 06/27/2017
NAME OF PROVIDER OR SUPPLIER BROOKDALE HIGH POINT NORTH		STREET ADDRESS, CITY, STATE, ZIP CODE 1564 SKEET CLUB ROAD HIGH POINT, NC 27265		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 164}	Continued From page 2 (3) have furniture clean and in good repair; (e) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1. Observations revealed that the ceiling was not maintained in good repair. Findings on June 27, 2017: f. Mechanical Room (back hall) - there are open penetrations in the one hour ceiling assembly that are not fire caulked.	{C 164}		
{C 189}	Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Based on observation, the cross corridor doors were not maintained in a safe and operating condition. Findings on June 27, 2017: b. The front leaf of the cross corridor doors outside of Room 118 had a 3/4" gap at the top edge when closed. The foam material used as a smoke seal is not approved for fire-resistance-rated door construction	{C 189}	<i>holes was repaired with fire caulking 7-6-17</i> <i>(Bob). Heritage Repairs will return on 7-19-17 to complete repairs.</i>	

Division of Health Service Regulation
STATE FORM

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL041033	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED R 06/27/2017
NAME OF PROVIDER OR SUPPLIER BROOKDALE HIGH POINT NORTH			STREET ADDRESS, CITY, STATE, ZIP CODE 1564 SKEET CLUB ROAD HIGH POINT, NC 27265		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
{C 189}	Continued From page 4 observed sitting on the floor in the first closet. 10. Observations revealed that the exterior facade was not maintained in good condition. Findings on June 27, 2017: a. Outside the sunroom, a portion of the exterior aluminum soffit had fallen off where the roof lines intersect. b. Outside the sunroom, a panel covering the exterior sheathing had fallen off where the roof lines intersect. 16. Based on observation, the ice machine in the kitchen was not maintained in a safe and operating condition. Findings on June 27, 2017: a. The drain line was dripping directly into the drain and did not have a minimum 1 1/2" vacuum break. Per the Maintenance Director, another drain line was adjusted.	{C 189}	<i>soffit was repaired by James Pickett</i> <i>removed old return line & replaced with new line. line is now 1 1/2 off floor.</i>	7-13-17 7-7-17	
{C 169}	Building Service Equipment-Ventilation IV. The Building D. Building Service Equipment (10 NCAC 42D .1605) 7. Ventilation The spaces listed below must be provided with exhaust ventilation at the rate of two cubic feet per minute per square foot. This requirement does not apply to facilities licensed before April 1, 1984, with adequate natural ventilation in these specified spaces. a. soiled linen storage; b. soil utility room; c. bathrooms and toilet rooms; d. housekeeping closet; and	{C 169}	<i>Exhaust fan was installed on</i>	7-14-17	

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL041033	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED R 06/27/2017
NAME OF PROVIDER OR SUPPLIER BROOKDALE HIGH POINT NORTH		STREET ADDRESS, CITY, STATE, ZIP CODE 1564 SKEET CLUB ROAD HIGH POINT, NC 27265		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 169}	Continued From page 5 e. laundry area. This Rule is not met as evidenced by: 1. Observations revealed that required ventilation was not provided in one space. Findings on June 27, 2017: a. Mechanical Room/Housekeeping 4 - did not have mechanical exhaust. The room contained a mop sink and had bleach and other cleaning supplies stored in the room. The chemical have been removed but the room still has an odor.	{C 169}	Exhaust fan was installed in mechanical Room.	7/14/17

Pre-Engineered Restaurant Fire Suppression Systems Report

SERVICE COMPANY

CFEAS

704-718-0040

DATE OF SERVICE

7-11-17

TIME

A.M.

P.M.

ANNUAL

SEMI-ANNUAL

RECHARGE

INSTALLATION

RENOVATION

LOCATION OF SYSTEM CYLINDERS

Wall Rt. of Hood

UL 300

☐ YES ☐ NO

MANUFACTURER

MODEL NUMBER

WET

DRY CHEMICAL

Pyrotech

PCL 300

☒

CYLINDER SIZE MASTER

CYLINDER SIZE SLAVE

CYLINDER SIZE SLAVE

3.0

FUSE LINKS 380° F.

FUSE LINKS 450° F.

FUSE LINKS 500° F.

OTHER

2

FUEL SHUT-OFF

ELECTRIC

GAS

SIZE

mechanical
micro switch

—

—

SERIAL NUMBER

LAST TEST DATE

LAST RECHARGE DATE

12

MANUFACTURER'S MANUAL REFERENCE

PAGE NUMBER:

DRAWING NUMBER:

DATE

CUSTOMER

Name 18400 Brookdale H. Point North

Address 1564 Street Club Rd.

City High Point State NC ZIP

Telephone Store No.

Owner or Manager Juan Monte

COOKING APPLIANCE LOCATIONS: LEFT TO RIGHT

Fryer / Flat grill

1. All appliances properly covered w/correct nozzles
2. Duct and plenum covered w/correct nozzles
3. Check positioning of all nozzles.
- System installed in accordance w/MFG UL listing
5. Hood/duct penetrations sealed w/weld or UL device
6. Check if seals intact, evidence of tampering
7. If system has been discharged, report same
8. Pressure gauge in proper range (If gauged)
9. Check cartridge weight (If applicable)
10. Hydrostatic test date
11. 6 year maintenance date
12. Inspect cylinder and mount
13. Operate system from terminal link
14. Test for proper operation from remote
15. Check operation of micro switch Alarm
16. Check operation of gas valve
17. Clean nozzles
18. Proper nozzle covers in place
19. Check fuse links and clean

Replaced
2024
N/A
C-14

20. Replaced fuse links
21. Check travel of cable nuts/S-hooks
22. Piping & conduit securely bracketed
23. Proper separation between fryers & flame
24. Proper clearance-flame to filters
25. Exhaust fan in operating order
26. All filters in place
27. Fuel shut-off in on position
28. Manual & remote set/seals in place
29. Replace systems covers
30. System operational & seals in place
31. Slave system operational
32. Clean cylinder & mount
33. Fan warning sign on hood
34. Personnel instructed in manual operation of system
35. Proper hand portable extinguishers
36. Portable extinguishers properly serviced
37. Service & Certification tag on system

2017
Recommend
Splash Guard

NOTE DISCREPANCIES OR DEFICIENCIES BELOW

COMMENTS: 14 In case of fire pull Remote to Activate System.

Hood cleaned on 7-11-17

CFEAS not responsible for Accidents.

On this date, this pre-engineered fire suppression system was inspected and operationally tested in accordance with the fire suppression system requirements of NFPA17 or 17A, 96 and the manufacturer's manual with the results indicated above.

X

SERVICE TECHNICIAN

PERMIT NO.

DATE:

TIME:

AM

PM

CUSTOMER'S AUTHORIZED AGENT

The above service technician certifies that the system was personally inspected and found conditions to be as indicated on this report.

Pre-Engineered Restaurant Fire Suppression Systems Report

SERVICE COMPANY
CFEAS 704-718-0043

DATE OF SERVICE 1-9-17		TIME		A.M.	P.M.
ANNUAL	SEMI-ANNUAL	RECHARGE	INSTALLATION	RENOVATION	
LOCATION OF SYSTEM CYLINDERS Wall Rt of Hood				UL 300 ☒ YES ☐ NO	
MANUFACTURER Pyrotech	MODEL NUMBER AL300	WET ☒	DRY CHEMICAL		
CYLINDER SIZE MASTER 3.0	CYLINDER SIZE SLAVE	CYLINDER SIZE SLAVE			
FUSE LINKS 360° F. 2	FUSE LINKS 450° F.	FUSE LINKS 500° F.	OTHER		
FUEL SHUT-OFF Manual	ELECTRIC	GAS	SIZE		
SERIAL NUMBER	LAST HYDRO TEST DATE 12	LAST RECHARGE DATE			
MANUFACTURER'S MANUAL REFERENCE					
PAGE NUMBER:		DRAWING NUMBER:		DATE	

CUSTOMER	
Name	Brookdale High Point North
Address	1564 Street Club Road
City	High Point
State	NC
ZIP	
Telephone	
Store No.	
Owner or Manager	

COOKING APPLIANCE LOCATIONS: LEFT TO RIGHT

Fryer / Flat grill		

- All appliances properly covered w/correct nozzles
- Duct and plenum covered w/correct nozzles
- Check positioning of all nozzles.
- System installed in accordance w/MFG UL listing
- Hood/duct penetrations sealed w/weld or UL device
- Check if seals intact, evidence of tampering
- If system has been discharged, report same
- Pressure gauge in proper range (If gauged)
- Check cartridge weight (If applicable)
- Hydrostatic test date
- 6 year maintenance date
- Inspect cylinder and mount
- Operate system from terminal link
- Test for proper operation from remote
- Check operation of micro switch
- Check operation of gas valve
- Clean nozzles
- Proper nozzle covers in place
- Check fuse links and clean

2024
N/A
C-14

20. Replaced fuse links
21. Check travel of cable nuts/S-hooks
22. Piping & conduit securely bracketed
23. Proper separation between fryers & flame
24. Proper clearance-flame to filters
25. Exhaust fan in operating order
26. All filters in place
27. Fuel shut-off in on position
28. Manual & remote set/seals in place
29. Replace systems covers
30. System operational & seals in place
31. Slave system operational
32. Clean cylinder & mount
33. Fan warning sign on hood
34. Personnel instructed in manual operation of system
35. Proper hand portable extinguishers
36. Portable extinguishers properly serviced
37. Service & Certification tag on system

2017
Recommend splash guard

NOTE DISCREPANCIES OR DEFICIENCIES BELOW

COMMENTS: (10) In Case of fire pull Remote to Activate System.

(*) Hood Cleaned on 1-9-17

CFEAS not Responsible for Accidents.

On this date, this pre-engineered fire suppression system was inspected and operationally tested in accordance with the fire suppression system requirements of NFPA17 or 17A, 96 and the manufacturer's manual with the results indicated above.

X						
SERVICE TECHNICIAN	PERMIT NO.	DATE:	TIME:	AM	PM	CUSTOMER'S AUTHORIZED AGENT

Fire Protection Systems Report of Inspections

Work Order #: _____

Date: 6-15-17

Site Name: BL/Claire Bridge High Point
Address: 1564 Skelton Club
City: High Point State: NC
Zip: _____ Phone: _____

Owner: _____
Address: _____
City: _____ State: _____
Zip: _____ Phone: _____

PART I INSPECTOR'S SECTION (all responses reference current inspection)

A. General

	Yes	N/A	No
1. Is the hydraulic data plate in place, permanently marked and securely attached?	☒		
2. Is the fire department connection(s) in satisfactory condition, couplings free, caps in place, check valves tight and accessible and visible?	☒		
3. Has the system check valve(s) been internally inspected within the last 5 years? (Date <u>2015</u>)	☒		
4. Is the visible exterior of the system piping in good condition and free from damage? (Date checked <u>2017</u>)	☒		
5. Are visible hangers in place, securely attached and free of corrosion? (Date checked <u>2017</u>)	☒		
6. Are system gauges (water/air) in good condition and showing normal pressures?	☒		
7. Were system gauges (water/air) checked against a calibrated gauge or replaced in the last 5 years? (Date <u>2014</u>)	☒		

B. Wet Systems

1. Are areas protected by wet systems inside the property properly heated?	☒		
2. There is no leakage from drain pipes indicating problems with retard chambers, alarm drains or main drain?	☒		
3. Are inspection and flow test tags in place and filled out completely?	☒		
4. Was a flow test performed from Inspector's test valve and did the alarms operate?	☒		
5. Are cold weather valves in the appropriate (open) / (closed) position?	☒		
6. Are antifreeze test results satisfactory?	☒		
Test Results: Solution Type _____ Freeze Point _____			

C. Dry Systems (see trip test report dated: _____)

1. Are the air pressure and priming water level in accordance with the manufacturer's instructions?	☒		
2. Is the air (compressor) or nitrogen supply in service and operating properly?	☒		
3. Are quick-opening devices in service? (Semiannual test performed on <u>N/A</u>)	☒		
4. Are air maintenance device(s) installed and operating properly?	☒		
5. Is the intermediate chamber free from leakage and the velocity check free & clear?	☒		
6. Were low points drained during this inspection? (Quantity Drained <u>3</u>) (see Part III.J)	☒		
7. Did the heating equipment in the valve enclosure operate at the time of inspection?	☒		

D. Special Systems (Deluge, Preaction) (see trip test report dated: _____)

1. Did detection devices test satisfactorily during this inspection?	☒		
2. Did the release/activation devices operate properly during detection testing?	☒		
3. Is the air pressure and priming water level for the preaction system in accordance with manufacturer's instructions?	☒		

E. Alarms (Wet, Dry, Preaction & Deluge)

1. Are the alarm trim valves in the proper position, sealed and/or locked?	☒		
2. Did the water motor and gong/electrical alarms (pressure and water flow) operate properly during testing?	☒		
3. Did the central station/monitoring system receive all alarms?	☒		
4. Did the low/high air alarms for the system piping/detection operate properly?	☒		
5. Did tamper devices operate properly?	☒		

F. Sprinklers

1. Is the proper clearance maintained between the top of the storage and sprinkler deflector?	☒		
2. Are all sprinklers free from corrosion, loading or obstruction to spray discharge?	☒		
3. Are standard sprinklers in service for less than 50 years / dated after 1920?	☒		
4. Are fast response sprinklers in service for less than 20 years?	☒		
5. Is a spare head cabinet with spare sprinklers and proper wrenches installed at system riser?	☒		
6. Are sprinklers near heating devices of proper temperature rating?	☒		

G. Control Valves (see Item G.1)

1. Are sprinkler system control valves in the appropriate position?	☒		
2. Were operating stems of all O.S.&Y. valves lubricated, completely closed and reopened? (Date _____)	☒		
3. Were all control valves operated through full range and returned to normal position? (Date <u>6-15-17</u>)	☒		
4. Are valves free from external leaks?	☒		
5. Are valves properly identified with signs?	☒		
6. Are pressure regulating control valves open, not leaking, maintaining downstream pressure and free from physical damage? (Date tested _____)	☒		

Fire & Life Safety America, Inc
Addendum Report of Inspection

Pg _____ of _____

Work Order #: _____

Location: _____

Test Date: _____

SUMMATION ITEMS

Form #

Corrections *, Comments & Suggestions - All items marked with an asterisk (*) are required corrections

All System Normal

System restored to normal operation, alarm panel is clear, all parties on Summary Inspection Form notified, and any required corrections, comments and suggestions fully explained except as noted above.

Billy Buchanan
Lead Inspector/Technician:

Billy Buchanan
Signature

6.13.17
Date

Owner Representative

Signature

Date

Food Establishment Inspection Report

Score: 95.5

Establishment Name: CLARE BRIDGE OF HIGH POINT

Establishment ID: 3041160075

Location Address: 1564 SKEET CLUB RD

☒ Inspection ☐ Re-Inspection

City: HIGH POINT

State: NC

Zip: 27265 County: 41 Guilford

Date: 01/24/2017 Status Code: A

Time In: 08:00 am Time Out: 10:30 am

Total Time: 2 hrs 30 minutes

Permittee: BROOKDALE SENIOR LIVING

Category #: 1

Telephone:

FDA Establishment Type: Nursing Home

Wastewater System: ☒ Municipal/Community ☐ On-Site System

No. of Risk Factor/Intervention Violations: 2

Water Supply: ☒ Municipal/Community ☐ On-Site Supply

No. of Repeat Risk Factor/Intervention Violations: 1

Foodborne Illness Risk Factors and Public Health Interventions									
Risk factors: Contributing factors that increase the chance of developing foodborne illness.									
Public Health Interventions: Control measures to prevent foodborne illness or injury.									
IN	OUT	NA	NO	Compliance Status	OUT	CDI	R	VR	
Supervision: 2652									
1	☒	☐	☐	PIC Present; Demonstration-Certification by accredited program and perform duties	2	0			
Employee Health: 2652									
2	☒	☐	☐	Management, employees knowledge; responsibilities & reporting	3	15	0		
3	☒	☐	☐	Proper use of reporting, restriction & exclusion	3	15	0		
Good Hygienic Practices: 2652, 2653									
4	☒	☐	☐	Proper eating, tasting, drinking, or tobacco use	2	1	0		
5	☒	☐	☐	No discharge from eyes, nose or mouth	1	0	0		
Preventing Contamination by Hands: 2652, 2653, 2655, 2656									
6	☒	☐	☐	Hands clean & properly washed	4	2	0		
7	☒	☐	☐	No bare hand contact with RTE foods or pre-approved alternate procedure properly followed	3	15	0		
8	☒	☐	☐	Handwashing sinks supplied & accessible	2	1	0		
Approved Source: 2653, 2655									
9	☒	☐	☐	Food obtained from approved source	2	1	0		
10	☒	☐	☐	Food received at proper temperature	2	1	0		
11	☒	☐	☐	Food in good condition, safe & unadulterated	2	1	0		
12	☐	☐	☒	Required records available: shellstock tags, parasite destruction	2	1	0		
Protection from Contamination: 2653, 2654									
13	☒	☐	☐	Food separated & protected	3	15	0		
14	☐	☒	☐	Food-contact surfaces: cleaned & sanitized	3	X	0		
15	☒	☐	☐	Proper disposition of returned, previously served, reconditioned, & unsafe food	2	1	0		
Potentially Hazardous Food Time/Temperature: 2653									
16	☒	☐	☐	Proper cooking time & temperatures	3	15	0		
17	☐	☐	☒	Proper reheating procedures for hot holding	3	15	0		
18	☒	☐	☐	Proper cooling time & temperatures	3	15	0		
19	☒	☐	☐	Proper hot holding temperatures	3	15	0		
20	☒	☐	☐	Proper cold holding temperatures	3	15	0		
21	☒	☐	☐	Proper date marking & disposition	3	15	0		
22	☐	☐	☒	Time as a public health control: procedures & records	2	1	0		
Consumer Advisory: 2653									
23	☐	☐	☒	Consumer advisory provided for raw or undercooked foods	1	0	0		
Highly Susceptible Populations: 2653									
24	☒	☐	☐	Pasteurized foods used; prohibited foods not offered	3	15	0		
Chemicals: 2653, 2657									
25	☒	☐	☐	Food additives: approved & properly used	1	0	0		
26	☐	☒	☐	Toxic substances properly identified stored, & used	2	X	0		
Conformance with Approved Procedures: 2653, 2654, 2656									
27	☒	☐	☐	Compliance with variance, specialized process, reduced oxygen packing criteria or HACCP plan	2	1	0		

Good Retail Practices									
Good Retail Practices: Preventative measures to control the addition of pathogens, chemicals, and physical objects into foods.									
IN	OUT	NA	NO	Compliance Status	OUT	CDI	R	VR	
Safe Food and Water: 2653, 2655, 2658									
28	☐	☐	☒	Pasteurized eggs used where required	1	0	0		
29	☒	☐	☐	Water and ice from approved source	2	1	0		
30	☐	☐	☒	Variance obtained for specialized processing methods	1	0	0		
Food Temperature Control: 2653, 2654									
31	☒	☐	☐	Proper cooling methods used; adequate equipment for temperature control	1	0	0		
32	☒	☐	☐	Plant food properly cooked for hot holding	1	0	0		
33	☒	☐	☐	Approved thawing methods used	1	0	0		
34	☒	☐	☐	Thermometers provided & accurate	1	0	0		
Food Identification: 2653									
35	☒	☐	☐	Food properly labeled: original container	2	1	0		
Prevention of Food Contamination: 2652, 2653, 2654, 2656, 2657									
36	☒	☐	☐	Insects & rodents not present; no unauthorized animals	2	1	0		
37	☒	☐	☐	Contamination prevented during food preparation, storage & display	2	1	0		
38	☒	☐	☐	Personal cleanliness	1	0	0		
39	☒	☐	☐	Wiping cloths: properly used & stored	1	0	0		
40	☒	☐	☐	Washing fruits & vegetables	1	0	0		
Proper Use of Utensils: 2653, 2654									
41	☒	☐	☐	In-use utensils: properly stored	1	0	0		
42	☒	☐	☐	Utensils, equipment & linens: properly stored, dried & handled	1	0	0		
43	☒	☐	☐	Single-use & single-service articles: properly stored & used	1	0	0		
44	☒	☐	☐	Gloves used properly	1	0	0		
Utensils and Equipment: 2653, 2654, 2653									
45	☐	☒	☐	Equipment, food & non-food contact surfaces approved, cleanable, properly designed, constructed, & used	2	X	0		
46	☐	☒	☐	Warewashing facilities: installed, maintained, & used; test strips	1	X	0		
47	☒	☐	☐	Non-food contact surfaces clean	1	0	0		
Physical Facilities: 2654, 2655, 2656									
48	☒	☐	☐	Hot & cold water available; adequate pressure	2	1	0		
49	☒	☐	☐	Plumbing installed; proper backflow devices	2	1	0		
50	☒	☐	☐	Sewage & waste water properly disposed	2	1	0		
51	☐	☐	☐	Toilet facilities: properly constructed, supplied & cleaned	1	0	0		
52	☒	☐	☐	Garbage & refuse properly disposed; facilities maintained	1	0	0		
53	☐	☒	☐	Physical facilities installed, maintained & clean	1	X	0		
54	☒	☐	☐	Meets ventilation & lighting requirements; designated areas used	1	0	0		
Total Deductions:									4.5



North Carolina Department of Health & Human Services • Division of Public Health • Environmental Health Section • Food Protection Program



INSPECTION AND TESTING FORM

Date 03/17/2017

Time:

SERVICE ORGANIZATION

Name: Advanced Fire & Communication, Inc

Address: PO Box 336

Cooleemee, NC 27014

Representative: Jimmy McLeod

License No: 23237-SP-FA/LV

Telephone: 336-776-0302

PROPERTY NAME (USER)

Name: Clare Bridge at High Point Place

Address: 1564 Skeet Club Rd.

High Point, NC 27265

Owner Contact:

Telephone: 336.869.4188

18400

MONITORING ENTITY

Contact:

Telephone:

Monitoring Account Ref. No: F9F8

APPROVING AGENCY

Contact: Loss Prevention Services

Telephone: 1.800.526.8781

TYPE TRANSMISSION

☐ McCulloh

☐ Multiplex

☒ Digital

☐ Reverse Priority

☐ RF

☐ Other (Specify)

SERVICE

☐ Weekly

☐ Monthly

☐ Quarterly

☐ Semiannually

☒ Annually

☐ Other (Specify)

Control Unit Manufacturer: FireLite

Circuit Styles:

Number of Circuits:3

Software Rev.:

Last Date System Had Any Service Performed:

Last Date That Any Software or Configuration Was Revised:

Model No: MS9600UDLS

ALARM-INITIATING DEVICES AND CIRCUIT INFORMATION

Quantity

Circuit Style

9

Manual Fire Alarm Boxes

82

Ion Detectors

14

Photo Detectors

10

Duct Detectors

1

Heat Detectors

4

Waterflow Switches

1

Supervisory Switches

Other (Specify): Kitchen Hood

Alarm verification feature is disabled ☐ enabled ☒

ALARM NOTIFICATION APPLIANCES AND CIRCUIT INFORMATION

Quantity Circuit Style

20 Bells

10 Horn/Strobes

Chimes

Strobes

Speakers

Other (Specify):

No. of alarm notification appliance circuits:

Are circuits monitored for integrity? ☒ Yes ☐ No

SUPERVISORY SIGNAL-INITIATING DEVICES AND CIRCUIT INFORMATION

Quantity Circuit Style

Building Temp.

Site Water Temp.

Site Water Level

Fire Pump Power

Fire Pump Running

Fire Pump Auto Position

Fire Pump or Pump Controller Trouble

Fire Pump Running

Generator in Auto Position

Generator or Controller Trouble

Switch Transfer

Generator Engine Running

Other:

SIGNALING LINE CIRCUITS

Quantity and style of signaling line circuits connected to system (see NFPA 72, Table 6.6.1):

Quantity Style(s)

SYSTEM POWER SUPPLIES

(a) Primary (Main): Nominal Voltage 120vac Amps 20

Overcurrent Protection: Type Circuit Breaker Amps 20

Location (of Primary Supply Panelboard): D

Disconnecting Means Location: 12

(b) Secondary (Standby):

2 - 12v 25AH Storage Battery: Amp-Hr. Rating

Calculated capacity to operate system, in hours: X 24 60

Location of fuel storage:

Engine-driven generator dedicated to fire alarm system:

TYPE BATTERY

- ☐ Dry Cell
- ☐ Nickel-Cadmium
- ☒ Sealed Lead-Acid
- ☐ Lead-Acid
- ☐ Other (Specify)

(c) Emergency or standby system used as a backup to primary power supply, instead of using a secondary power supply:

Emergency system described in NFPA 70, Article 700

Legally required standby described in NFPA 70, Article 701

Optional standby system described in NFPA 70, Article 702, which also meets the performance requirements of Article 700 or 701.

NOTIFICATIONS ARE MADE

PRIOR TO ANY TESTING

Yes

No

Who

Time

Monitoring Entity
Building Occupants
Building Management
Other (Specify)
AHJ Notified of Any Impairments

☒
☐
☒
☐
☒
☐
☐
☐
☐
☐

SYSTEM TESTS AND INSPECTIONS

TYPE

Visual

Functional

COMMENTS

Control Unit
Interface Equipment
Lamps/LEDS
Fuses
Primary Power Supply
Trouble Signals
Disconnect Switches
Ground-Fault Monitoring

☒
☒
☒
☒
☒
☒
☒
☒
☒
☒
☒
☒
☒
☒
☒
☒

SECONDARY POWER

TYPE

Visual

Functional

COMMENTS

Battery Condition
Load Voltage
Discharge Test
Charger Test
Specific Gravity

☒
☐
☒
☒
☒
☒

TRANSIENT SUPPRESSORS
REMOTE ANNUNCIATORS
NOTIFICATION APPLIANCES

☐
☐
☒
☒

Audible
Visible
Speakers
Voice Clarity

☒
☒
☒
☒
☐
☐
☐

INITIATING AND SUPERVISORY DEVICE TESTS AND INSPECTIONS

Loc. & S/N

Device Type

Visual Check

Functional Test

Factory Setting

Measured Setting

Pass

Fail

☐
☐
☐
☐
☐
☐
☐
☐
☐
☐
☐
☐
☐
☐
☐
☐
☐
☐
☐
☐
☐
☐
☐
☐

EMERGENCY	Visual	Functional	Comments
COMMUNICATIONS EQUIPMENT			
Phone Set	☐	☐	
Phone Jacks	☒	☒	
Off-Hook Indicator	☐	☐	
Amplifier(s)	☐	☐	
Tone Generator(s)	☐	☐	
Call-in Signal	☒	☒	
System Performance	☒	☒	
INTERFACE EQUIPMENT			
	Visual	Device Operation	Simulated Operation
(Specify)	☐	☐	☐
(Specify)	☐	☐	☐
(Specify)	☐	☐	☐
SPECIAL HAZARD SYSTEMS			
(Specify)	☐	☐	☐
(Specify)	☐	☐	☐
(Specify)	☐	☐	☐
Special Procedures:			

Comments: 1. All smoke doors closed on general alarm.
 2. All HVAC shutdown on general alarm.
 3. All outside doors released on general alarm.
 4. all emergency & exit lights passed 90 minute test.

SUPERVISING STATION	Yes	No	Time	Comments
MONITORING				
Alarm Signal	☒	☐		
Alarm Restoration	☒	☐		
Trouble Signal	☒	☐		
Supervisory Signal	☒	☐		
Supervisory Restoration	☒	☐		
NOTIFICATIONS THAT TESTING	Yes	No	Who	Time
IS COMPLETE				
Building Management	☒	☐		
Monitoring Agency	☒	☐		
Building Occupants	☒	☐		
Other (Specify)	☐	☐		
The following did not operate correctly:				

System restored to normal operation:

Date 03/17/2017 Time

THIS TESTING WAS PERFORMED IN ACCORDANCE WITH APPLICABLE NFPA STANDARDS.

Name of Inspector: Jeff McLeod

Date 03/17/2017 Time

Signature

Name of Owner or Representative:

Date:

Time:

Signature:

** Advanced Fire & Communication certifies that the alarm system is in the order detailed above as of this day. We are not responsible if someone other than Advanced Fire & Communication works on/modifies/tampers with said system after this date and time.

Initial: T.L.S.

INSPECTION AND TESTING FORM

Date 03/17/2017

Time:

SERVICE ORGANIZATION

Name: Advanced Fire & Communication, Inc

Address: PO Box 336

Cooleemee, NC 27014

Representative: Jimmy McLeod

License No: 23237-SP-FA/LV

Telephone: 336-776-0302

PROPERTY NAME (USER)

Name: Clare Bridge at High Point Place

Address: 1564 Skeet Club Rd.

High Point, NC 27265

Owner Contact:

Telephone: 336.869.4188

MONITORING ENTITY

Contact:

Telephone:

Monitoring Account Ref. No: F9F8

APPROVING AGENCY

Contact: Loss Prevention Services

Telephone: 1.800.526.8781

TYPE TRANSMISSION

☐ McCulloh

☐ Multiplex

☒ Digital

☐ Reverse Priority

☐ RF

☐ Other (Specify)

SERVICE

☐ Weekly

☐ Monthly

☐ Quarterly

☐ Semiannually

☒ Annually

☐ Other (Specify)

Control Unit Manufacturer: FireLite

Circuit Styles:

Number of Circuits:3

Software Rev.:

Last Date System Had Any Service Performed:

Last Date That Any Software or Configuration Was Revised:

Model No: MS9600UDLS

ALARM-INITIATING DEVICES AND CIRCUIT INFORMATION

Quantity

Circuit Style

9

82

14

10

1

4

1

Manual Fire Alarm Boxes

Ion Detectors

Photo Detectors

Duct Detectors

Heat Detectors

Waterflow Switches

Supervisory Switches

Other (Specify): Kitchen Hood

Alarm verification feature is disabled ☐ enabled ☒

ALARM NOTIFICATION APPLIANCES AND CIRCUIT INFORMATION

Quantity

Circuit Style

Bells
Horn/Strobes
Chimes
Strobes
Speakers
Other (Specify):

No. of alarm notification appliance circuits:

Are circuits monitored for integrity? ☒ Yes ☐ No

SUPERVISORY SIGNAL-INITIATING DEVICES AND CIRCUIT INFORMATION

Quantity

Circuit Style

Building Temp.
Site Water Temp.
Site Water Level
Fire Pump Power
Fire Pump Running
Fire Pump Auto Position
Fire Pump or Pump Controller Trouble
Fire Pump Running
Generator in Auto Position
Generator or Controller Trouble
Switch Transfer
Generator Engine Running
Other:

SIGNALING LINE CIRCUITS

Quantity and style of signaling line circuits connected to system (see NFPA 72, Table 6.6.1):

Quantity

Style(s)

SYSTEM POWER SUPPLIES

(a) Primary (Main):

Nominal Voltage 120vac

Amps 20

Overcurrent Protection:

Type Circuit Breaker

Amps 20

Location (of Primary Supply Panelboard): D

Disconnecting Means Location: 12

(b) Secondary (Standby):

2 - 12v 25AH

Storage Battery: Amp-Hr. Rating

Calculated capacity to operate system, in hours:

X 24

60

Location of fuel storage:

Engine-driven generator dedicated to fire alarm system:

TYPE BATTERY

- ☐ Dry Cell
☐ Nickel-Cadmium
☒ Sealed Lead-Acid
☐ Lead-Acid
☐ Other (Specify)

(c) Emergency or standby system used as a backup to primary power supply, instead of using a secondary power supply:
Emergency system described in NFPA 70, Article 700
Legally required standby described in NFPA 70, Article 701
Optional standby system described in NFPA 70, Article 702, which also meets the performance requirements of Article 700 or 701.

NOTIFICATIONS ARE MADE	Yes	No	Who	Time
Monitoring Entity	☒	☐		
Building Occupants	☒	☐		
Building Management	☒	☐		
Other (Specify)	☐	☐		
AHJ Notified of Any Impairments	☐	☐		

TYPE	Visual	Functional	COMMENTS
Control Unit	☒	☒	
Interface Equipment	☒	☒	
Lamps/LEDS	☒	☒	
Fuses	☒	☒	
Primary Power Supply	☒	☒	
Trouble Signals	☒	☒	
Disconnect Switches	☒	☒	
Ground-Fault Monitoring	☒	☒	

Battery Condition	☒	☒
Load Voltage		☒
Discharge Test		☒
Charger Test		☒
Specific Gravity		☒
TRANSIENT SUPPRESSORS	☐	
REMOTE ANNUNCIATORS	☒	☒
NOTIFICATION APPLIANCES		
Audible	☒	☒
Visible	☒	☒
Speakers	☐	☐
Voice Clarity		☐

[illegible]

EMERGENCY COMMUNICATIONS EQUIPMENT	Visual	Functional	Comments
Phone Set	☐	☐	
Phone Jacks	☒	☒	
Off-Hook Indicator	☐	☐	
Amplifier(s)	☐	☐	
Tone Generator(s)	☐	☐	
Call-in Signal	☒	☒	
System Performance	☒	☒	
INTERFACE EQUIPMENT	Visual	Device Operation	Simulated Operation
(Specify)	☐	☐	☐
(Specify)	☐	☐	☐
(Specify)	☐	☐	☐
SPECIAL HAZARD SYSTEMS			
(Specify)	☐	☐	☐
(Specify)	☐	☐	☐
(Specify)	☐	☐	☐
Special Procedures:			

Comments: 1. All smoke doors closed on general alarm.
 2. All HVAC shutdown on general alarm.
 3. All outside doors released on general alarm.
 4. all emergency & exit lights passed 90 minute test.

SUPERVISING STATION MONITORING	Yes	No	Time	Comments
Alarm Signal	☒	☐		
Alarm Restoration	☒	☐		
Trouble Signal	☒	☐		
Supervisory Signal	☒	☐		
Supervisory Restoration	☒	☐		
NOTIFICATIONS THAT TESTING IS COMPLETE	Yes	No	Who	Time
Building Management	☒	☐		
Monitoring Agency	☒	☐		
Building Occupants	☒	☐		
Other (Specify)	☐	☐		

The following did not operate correctly:

System restored to normal operation:

THIS TESTING WAS PERFORMED IN ACCORDANCE WITH APPLICABLE NFPA STANDARDS.

Name of Inspector: Jeff McLeod

Date 03/17/2017 Time

Signature

Date 03/17/2017 Time

Name of Owner or Representative:

Date:

Time:

Signature:

** Advanced Fire & Communication certifies that the alarm system is in the order detailed above as of this day. We are not responsible if someone other than Advanced Fire & Communication works on/modifies/tampers with said system after this date and time.

Initial: T.C.S