

PRINTED: 08/28/2017
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL039009	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 07/27/2017
NAME OF PROVIDER OR SUPPLIER GRANVILLE HOUSE		STREET ADDRESS, CITY, STATE, ZIP CODE 200 COVENTRY DRIVE OXFORD, NC 27565		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 000	Initial Comments Report of Construction Section Biennial Survey by Ed Miller on July 27, 2017. Records indicate this facility was first licensed on 11/26/1997 as a HA. This facility is currently licensed for 80 Beds with a 14 Bed Special Care Unit. Therefore, this facility was surveyed for conformance with the applicable portions of the 2005 Rules for Licensing of Adult Care Homes of Seven or More Beds, and applicable portions of the 1998 Edition, of the North Carolina Building Code(s), Institutional Occupancy, and the 1998 Minimum Standards and Regulations for Homes for the Aged in effect at time of initial licensure. Deficiencies were cited that require a Plan of Correction.	C 000		
C 101	Existing Licensed Fac- No less than '71 Rules SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0301 APPLICATION OF PHYSICAL PLANT REQUIREMENTS The physical plant requirements for each adult care home shall be applied as follows: (2) Except where otherwise specified, existing licensed facilities or portions of existing licensed facilities shall meet licensure and code requirements in effect at the time of construction, change in service or bed count, addition, renovation, or alteration; however in no case shall the requirements for any licensed facility where no addition or renovation has been made, be less than those requirements found in the 1971 "Minimum and Desired Standards and Regulations" for "Homes for the Aged and Infirm", copies of which are available at the Division of Health Service Regulation at no cost;	C 101		

Division of Health Service Regulation

LABORATORY SECTION'S OR PROVIDER'S REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

STATE FORM

6860

045C21

If continuation sheet 1 of 10


 Administrator 9-13-2017

PRINTED: 08/28/2017
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL032009	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 07/27/2017
NAME OF PROVIDER OR SUPPLIER GRANVILLE HOUSE		STREET ADDRESS, CITY, STATE, ZIP CODE 200 COVENTRY DRIVE OXFORD, NC 27565		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 111	Continued From page 2 2016. c. The current annual Fire Marshal Inspection Report was not available for review. d. The current annual Fire Alarm System Inspection and Testing Report in accordance with NFPA 72, was not available for review. e. The current annual Sprinkler System Inspection and Testing Report in accordance with NFPA 25, was not available for review.	C 111	C. Fire Report Completed D. Fire alarm inspection completed E. Sprinkler system test completed	9-1-17 3-28-17 8-3-17
C 135	Bathrooms-Not to Be Utilized for Storage SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0305 PHYSICAL ENVIRONMENT (e) The requirements for bathrooms and toilet rooms are: (10) Resident toilet rooms and bathrooms shall not be utilized for storage or purposes other than those indicated in item (4) of this Rule; This Rule is not met as evidenced by: 1. Based on observation, the facility failed to ensure that resident toilet rooms and bathrooms are not utilized for storage. Findings on July 27, 2017: a. 200 Hall Spa - this area was being utilized to store housekeeping equipment, supplies, wheelchairs, and other items.	C 135	Spa/Bathroom has been cleaned out and removed all objects in the bathroom completed by Josh Hall	9-5-17
C 164	Housekeeping and Furnishings-Clean, Repaired SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0305 HOUSEKEEPING AND FURNISHINGS (a) Adult care homes shall: (1) have walls, ceilings, and floors or floor coverings kept clean and in good repair; (2) have no chronic unpleasant odors;	C 164		

PRINTED: 08/28/2017
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL039009	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 07/27/2017
NAME OF PROVIDER OR SUPPLIER GRANVILLE HOUSE		STREET ADDRESS, CITY, STATE, ZIP CODE 200 COVENTRY DRIVE OXFORD, NC 27565		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 164	Continued From page 3 (3) have furniture clean and in good repair; (e) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1. Based on Observation, the facility failed to keep the ceiling clean and in good repair. Findings on July 27, 2017: a. 300 Hall Women - the texture ceiling was in disrepair and falling off the ceiling. 2. Based on observation, the building mechanical systems are not kept clean and in good repair. Findings on July 27, 2017: a. Dining Room - the HVAC return and ventilation grilles with their radiation dampers have an excessive accumulation of dust/lint. b. Bedroom 215 - the PTAC units cover was loose. c. Beauty Shop - the ventilation grille with its radiation damper has an excessive accumulation of dust/lint. d. SCU Restroom near Smoke Barrier - the ventilation grille with its radiation damper has an excessive accumulation of dust/lint. e. Kitchen Mop Room - the ventilation grille with its radiation damper has an excessive accumulation of dust/lint. f. Kitchen - the ventilation grilles with its radiation damper has an excessive accumulation of dust/lint.	C 164	A. removed popcorn ceiling and repaint. Completed by Josh Hall A. taking vent down in dining room and cleaned. Completed by Josh Hall B. repaired by Josh Hall C. vent taken down and cleaned by Josh Hall D. vent taken down and cleaned by Josh Hall E. Kitchen - taken down and cleaned by Josh Hall F. cleaned both vent in Kitchen by Josh Hall	9-15-17 9-13-17 9-13-17 9-13-17 8-17-17 8-17-17
C 175	Bedroom Furnishings-Clean Towel, Towel Bar SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0300 HOUSEKEEPING AND FURNISHINGS (b) Each bedroom shall have the following	C 175		

PRINTED: 08/28/2017
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL039009	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED 07/27/2017
NAME OF PROVIDER OR SUPPLIER GRANVILLE HOUSE		STREET ADDRESS, CITY, STATE, ZIP CODE 200 COVENTRY DRIVE OXFORD, NC 27565			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
C 175	Continued From page 4 furnishings in good repair and clean for each resident: (7) individual clean towel, wash cloth and towel bar in the bedroom or an adjoining bathroom; and (e) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1. Based on observation, the facility failed to provide residents areas, with the required individual towels and/or towel bars for each resident. Findings on July 27, 2017: a. Bedroom 215 - this double occupant bedroom had one of its two towel bars broken.	C 175	A. Replace towel rack completed by Josh Hall	9-5-17	
C 185	Fire Safety-Rehearsals on Each Shift SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0300 PLAN FOR EVACUATION (b) There shall be rehearsals of the fire plan quarterly on each shift in accordance with the requirement of the local Fire Prevention Code Enforcement Official. (c) Records of rehearsals shall be maintained and copies furnished to the county department of social services annually. The records shall include the date and time of the rehearsals, the shift, staff members present, and a short description of what the rehearsal involved. (f) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: 1. Based on Record review and interview with Director of Residence Care, the facility failed to maintain in the facility, rehearsal records. Findings on July 27, 2017:	C 185	Fire Drills provided Jan - Aug 2017 see copy attached. plan provided		

PRINTED: 08/28/2017
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL039009	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED 07/27/2017
NAME OF PROVIDER OR SUPPLIER GRANVILLE HOUSE		STREET ADDRESS, CITY, STATE, ZIP CODE 200 COVENTRY DRIVE OXFORD, NC 27565			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
C 185	Continued From page 5	C 185	Record covered - see attached.		
C 189	a. There were no records available for review. Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Based on observation, the Building was not maintained in a safe and operating condition, because the door(s) protecting the opening in the smoke barrier did not close completely and latch to restrict smoke. This could affect all residents, staff, and visitors by not containing the smoke of the fire in the compartment of origin. Findings on July 27, 2017: a. 400 Hall Smoke Barrier Wall - the right leaf of the double-egress cross-corridor doors, hits the floor, and did not close when the fire alarm system released the doors. 2. Based on observation, the building's emergency equipment was not maintained in a safe and in operating condition. This would affect residents, staff, and visitors if they could not promptly find their way to an exit during an emergency. Findings on July 27, 2017: a. 400 Hall Smoke Barrier - the exit sign on the backside did not illuminate on backup power	C 189		A. Door removed and replaced by maint. to assure compliance by Josh Hall and Dan Koon A. Exit lights checked for battery and bulb replaced by Josh Hall	9-29-17 8-19-17

PRINTED: 08/28/2017
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HA1039009	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 07/27/2017
NAME OF PROVIDER OR SUPPLIER GRANVILLE HOUSE		STREET ADDRESS, CITY, STATE, ZIP CODE 200 COVENTRY DRIVE OXFORD, NC 27565		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 189	Continued From page 6 when tested. b. SCU Corridor near Bedroom 511 - the back headlight on the wall-mounted self-contained emergency light did not illuminate on backup power when the test button was pushed. 3. Based on observation, the Building was not maintained in a safe and operating condition, because the commercial kitchen hood's fire suppression system lacked the inspections, maintenance, and documentation required to ensure a properly working system. Findings on April 19, 2017: a. Kitchen - the fryer unit is not under the commercial kitchen's hood so there no hood suppression system protection, and no nozzles are aimed at the fryer. b. Kitchen - since the last semi-annual maintenance of the commercial kitchen hood's fire suppression system, there has been no documentation of the monthly inspections. 4. Based on observation, the interior doors were not maintained in a safe and operating condition. Findings on July 27, 2017: a. Bedroom 215 - the corridor door hits the doorframe preventing it from closing and latching. b. Bedroom 311 - the corridor door's latch bolt was retracted, not allowing the door to latch. c. Living Room - the back leaf of the pair of corridor doors, hit the detached door closer arm and will not close and latch. d. Bedroom 402 - the corridor door did not close and latch. 5. Based on Observation, the Building was not maintained in a safe condition. This could affect all by not containing smoke and fire in the room of origin. Findings on July 27, 2017:	C 189	replace and fix by Josh Hall/Dan Loom A. nozzle has been repositioned to cover fryer. Completed by Josh Hall B. maint. has been instructed to monitor the suppression system each month A > B > D Door has been adjusted + is able to close properly. C was told if door is left open closer arm could be disconnected.	9-15-17 9-5-17 8-1-17 8-15-17

Division of Health Service Regulation
STATE FORM

1000

Q49C21

If continuation sheet 7 of 10

PRINTED: 08/28/2017
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL039009	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 07/27/2017
NAME OF PROVIDER OR SUPPLIER GRANVILLE HOUSE		STREET ADDRESS, CITY, STATE, ZIP CODE 200 COVENTRY DRIVE OXFORD, NC 27565		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 189	Continued From page 7 a. Bedroom 206 - the corridor door had a wedge holding the door open, preventing the rapid release of the door with a light push or pull of the door, to close and latch. 6. Based on observation, the building was not maintained in a safe manner by failing to ensure that clothes dryer duct is not damaged. This could affect all residents, staff and visitors by allowing lint to accumulate (fuel for a fire) Findings on July 27, 2017: a. Beauty Shop - the clothes dryer transition duct is disconnected from the dryer outlet. 7. Based on observations, the Building fire safety was not maintained in a safe and operating condition. This could expose all to fire/smoke if not contained in Room or compartment of origin. Findings on July 27, 2017: a. AL Med Room - there is a gap around a cable not firestopped as it penetrates the fire-resistance-rated ceiling assembly. b. Private Dining - the HVAC grille did not completely cover the hole penetrating the fire-resistance-rated ceiling assembly. 8. Based on observation, the Building Sprinkler System was not maintained in a safe and operating condition. This could affect all residents, staff, and visitors if smoke/fire is not contained in the Room or compartment of origin. Findings on July 27, 2017: a. Living Room Porch - two-fire sprinkler escutcheon plate do not cover the complete holes through the fire-resistance-rated ceiling. 9. Based on observation, the Facility failed to maintain the electrical system in a safe and operating condition. Findings on July 27, 2017:	C 189 A.	removed wedge to assure proper closing by Josh Hall B. Maint. reconnected the vent. Housekeeping cleaned area by Josh Hall 7A. fire caulked hole in med room. by Josh Hall B. maint. fixed grill in private dining room. by Josh Hall 8A. Fire caulk sprinklers on porch completed by Josh Hall	9-5-17 9-5-17 9-1-17 9-13-17 9-10-17

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL039009	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 07/27/2017
NAME OF PROVIDER OR SUPPLIER GRANVILLE HOUSE		STREET ADDRESS, CITY, STATE, ZIP CODE 200 COVENTRY DRIVE OXFORD, NC 27565		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
G 199	Continued From page 9 REQUIREMENTS (g) The spaces listed in this Paragraph shall be provided with exhaust ventilation at the rate of two cubic feet per minute per square foot. This requirement does not apply to facilities licensed before April 1, 1984, with natural ventilation in these specified spaces: (1) soiled linen storage; (2) soil utility room; (3) bathrooms and toilet rooms; (4) housekeeping closets; and (5) laundry area. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Based on Observation and testing with a thin plastic sheet, the facility failed to maintain the ventilation system in proper working order. This could affect all residents, staff, and visitors by preventing the exhausting of odors. Findings on July 27, 2017: a. Bedroom 215 Bathroom - the exhaust ventilation system did not work, and there was a musty odor. b. SCU Restroom near Smoke Barrier - the exhaust ventilation system did not work, and there was a musty odor.	G 199	A. took vent down and vacuumed area inside the exhaust for better airflow. B. took down vent + vacuumed area inside the exhaust for better airflow	9-30-17 9-30-17

OFFICIAL USE ONLY:

DATE PAID / /20

INITIAL: _____

FD 0079



**City of Oxford
Fire Department
112 E. McClanahan St.
Oxford, N.C. 27565**

Page

1 of 3

Square Footage

26,242

Number of Units

Occupant Load

Land Use

PAYMENT IS DUE WITHIN 30 DAYS OF INSPECTION DATE

Business Name: Granville House Phone: 919-692-1315
Address: 200 Canyon Dr.
Emergency Contact: Marah Gable / Josh Hall Phone: 919-530-9530
Mailing Address: same as above
Property Mgmt.: _____ Phone: _____
704 Placard

Red		Yellow		White		Blue	
-----	--	--------	--	-------	--	------	--

Inspection Type	Occ. Class	Date	Time In	Time Out	Fee Applied	Next Reinspection Date
Annual	Asst. Lock	9/11/17	9:45	10:30	\$ 200.00	10/2/17

☐ No Deficiencies Noted

☐ Please correct the listed violation(s) on or before the date listed

[illegible]

Inspected By: JPW Shift / Admin

Violations corrected on

Extinguishers: 11/16 Extinguishing Sys: 1/1 Spill/leak: 8/31/17 Fire Alarm: 3/28/17 Kitchen Hood Cleaned: 4/12/17

Methods of Payments

Pay In Person: City Municipal Building, 300 Williamsboro St. The City accepts cash, checks, or money orders.

Please make check payable to **City of Oxford** and note invoice # on check

gy Mail: to P.O. Box 505, Oxford, N.C. 27565.

The City of Oxford is mandated to conduct periodic inspections of all commercial, institutional, and multi-family residential buildings to ensure compliance with fire and life safety regulations and per City Ordinance 8-43. You will be charged the applicable fee. Its purpose is to identify violations of the State of North Carolina Fire Prevention Code, and activities and conditions in buildings, structures and premises that pose dangers of fire, explosions or related hazards. The inspection was intended to be thorough and complete; however, not all violation of the code may have been identified. Failure to comply may result in civil penalties as per City Ordinance 8-44. The Fire Department and City assumes no responsibility for damages or injuries from violations of the North Carolina State Fire Code.

By signing this report, you are acknowledging that these violations have been brought to your attention and that you will comply or forward this report to the appropriate representative for remediation.

Chwone/Chwupani (Prinț Nărilor)

(Signature)

Date _____

ALARM & DETECTION EQUIPMENT TEST REPORT

Test Report No. _____ Contract No. _____

Property Name Grannyville House Assisted Living Contact Sarah Gables
 Street 200 Coventry Drive
 City & State Oxford, NC 27566 Phone No. 919-692-1315

	NAME	PHONE NO.
1. Before Test Notify Proper Authorities		
A. Owner or Owner's Rep.	<u>Sarah Gables</u>	<u>919-692-1315</u>
B. Fire Dept.		
C. Central Station	<u>Security Central (CJ 6962)</u>	<u>800-286-5699</u>

2. Control Panel Status Before Test
- A. Is the Panel connected to the Fire Dept. Master Box ☐
 Lease Line ☐
- B. Is the Power Light On? ☒
- C. Does the Panel indicate Normal Conditions? ☒
- D. Are all Indicating Lamp Bulbs in Operating Order? ☒
- E. Does the Trouble Light Operate? ☒
- F. Does the Silence Switch Operate? ☒
- G. Does this Panel have Active Zones? No. 0
- H. Does the Panel have Inactive Zones? No. 0
- I. Does the Panel have Battery Backup? ☒
- J. Do the Batteries indicate they are Properly Charged? ☒
- K. Have Fire Dept. and/or Lease Lines been disconnected before continuing tests? ☒

YES	N.A.	NO
X		
X		
X		
X		
X		
		X
		X
X		
X		
X		

Comments: This system includes a Firelite 9200 panel and a Notifier ECPS-2488 supply located in Nurses Station.
411UD dieler located in Janitors closet behind Nurses Station

3. Extinguishing Systems
- A. Are Halon Systems installed on Property? No. 0
 Is Halon at Recommended Pressure? ☒
- B. Are CO2 Systems installed on Property? No. 0
 Is CO2 at recommended pressure? ☒
- C. Are any other Type Systems installed on Property? No. 1

YES	N.A.	NO
		X
	X	
		X
	X	
X		

Comments: This building has a wet sprinkler system

Test Verification Name _____ signature _____ printed _____
 (By owner or owner's rep.) Title _____ Date _____
 Inspector Patterson Group Services, Inc. Date 3/28/17
 Phone Number 919-776-2403

cc: Owner (Name) _____ Address _____
 Insurance Co. _____ Address _____
 Fire Marshall _____ Address _____
 ISO _____ Address _____

ALARM & DETECTION EQUIPMENT TEST REPORT

Equipment	Total Number	No. Tested Prev. Reports	No. Tested This Report	Operational		
				Yes	N.A	No
4. Remote Annunciators	1	1	1	1		
5. Zones						
6. Manual Stations (Pull)						
A. Coded						
B. NonCoded	13	13	13	13		
7. Detectors (See #13)						
A. Photoelectric	88	88	88	88		
B. Ionization						
C. Thermal	3	3	3	3		
D. Flame						
E. Duct (See #14)	8	8	8	8		
8. Audible Alarms						
(Remote & at base)						
A. Bell						
B. Bell Strobe only	8	8	8	8		
C. Horn Mini	28	28	28	28		
D. Horn and Light	27	27	27	27		
9. Video Alarms						
(Remote & at base)						
10. Automatic Door Release	2	2	2	2		
11. Water Flow Switches						
A. Paddle	1	1	1	1		
B. Pressure						
12. Tamper Switches	1	1	1	1		
13. Were Tested Detectors Cleaned? No						X
If "no" answer, explain under comments						
14. Were Tested Detectors Calibrated? No						X
If "no" answer, explain under comments						
15. Did test of Duct Detectors shut down air handling units?				X		
16. Did the monitoring center (Fire Dept. Central Station, Lease-Line) receive signal?				X		
17. Is system reset for normal conditions?				X		
18. Is system restored to operational service?				X		
19. Have proper authorities (See #1) been notified system is back in service?				X		
20. Indicate % of equip. tested this report		25	50	75	100	✓
21. Indicate % of equip. tested YTD		25	50	75	100	✓

Comments for any "No" answers or explanations:

System smoke detectors are self monitoring/adjusting and will generate a trouble signal when cleaning is required

FACP batteries were load tested and labeled with the test date

(1) pull station (M06) at back exit is not working -- REPLACED 4/11/17

The fire alarm panel needs to be replaced as the 24volt non-resettable power on panel is not working. REPLACED 4/11/17

(2) 12v12ah batteries were replaced in the fire alarm panel.

PIEDMONT FIRE PROTECTION SERVICES, LLC

Report of Inspection, Testing and Maintenance For Wet, Dry, Preaction and Deluge Systems

Property Being Inspected:

COVENTRY HOUSE OF ORFED

Systems:

Contact: JOHN HALL

A. Inspections

1. Daily, or weekly if low temperature alarms are installed

Enclosures around dry pipe, preaction or deluge valves maintaining a minimum of 40 deg. F?

☐ Yes ☐ No ☒ N/A

2. Weekly Items

Relief port on reduced pressure backflow prevention assemblies free of continuous discharge?

☐ Yes ☐ No ☒ N/A

3. Weekly inspection items which can be performed monthly if the items are electrically supervised or secured with locks

A. Gauges on dry, preaction and deluge systems in good condition and showing normal air and water pressure?

☒ Yes ☐ No ☐ N/A

B. Control valves and isolation valves on backflow prevention devices

1. In correct (open/closed) position?

☒ Yes ☐ No ☐ N/A

2. Sealed, locked or supervised and accessible?

4. Monthly inspection items

A. Preaction and Deluge Valves

1. Free from physical damage?

☐ Yes ☐ No ☒ N/A

2. Trim valves in (open/closed) position?

☐ Yes ☐ No ☒ N/A

3. Electrical components in service?

☐ Yes ☐ No ☒ N/A

B. Dry Pipe Valves

1. Free from physical damage?

☒ Yes ☐ No ☐ N/A

2. Trim valves in (open/closed) position?

☒ Yes ☐ No ☐ N/A

3. No leakage from intam chamber?

☒ Yes ☐ No ☐ N/A

C. Sprinkler wrench with spare sprinklers?

☒ Yes ☐ No ☐ N/A

D. Gauges on wet-pipe system in good condition and showing normal water supply pressure?

☐ Yes ☐ No ☒ N/A

E. Alarm Valves

1. Gauges show normal supply water pressure?

☐ Yes ☐ No ☒ N/A

2. Free from physical damage?

☐ Yes ☐ No ☒ N/A

3. Valves in (open/closed) position?

☐ Yes ☐ No ☒ N/A

5. Quarterly inspection items

A. Sprinkler Pressure Regulating Control Valves

1. In open position and not leaking?

☐ Yes ☐ No ☒ N/A

2. Maintaining downstream pressure per design criteria?

☐ Yes ☐ No ☒ N/A

3. In good condition with handwheels not broken?

☐ Yes ☐ No ☒ N/A

B. Fire Department Connections

1. Visible and accessible?

☒ Yes ☐ No ☐ N/A

2. Couplings and elbows not damaged and rotate smoothly?

☒ Yes ☐ No ☐ N/A

3. Plugs/caps in place and undamaged?

☒ Yes ☐ No ☐ N/A

4. Gaskets in place & good condition?

☒ Yes ☐ No ☐ N/A

5. Identification signs in place?

☒ Yes ☐ No ☐ N/A

6. Check valve is not leaking?

☒ Yes ☐ No ☐ N/A

7. Automatic drain valve in place and operating properly?

☒ Yes ☐ No ☐ N/A

Note: If plugs or caps are not in place, inspect the interior for obstructions and verify that the valve clipper is operational over its full range)

C. Alarm devices free of physical damage?

☐ Yes ☐ No ☒ N/A

D. Hydraulic nameplate, if provided, securely attached to riser and legible?

☒ Yes ☐ No ☐ N/A

1. Annual inspection items

A. Proper # and type of spare sprinklers?

☒ Yes ☐ No ☐ N/A

B. Visible sprinklers:

1. Free of corrosion?

☒ Yes ☐ No ☐ N/A

2. Free of obstructions to spray patterns?

☒ Yes ☐ No ☐ N/A

3. Free of foreign materials including paint?

☒ Yes ☐ No ☐ N/A

4. Free of physical damage?

☒ Yes ☐ No ☐ N/A

6. Annual inspection items (Continued)

C. Visible Pipe

1. In good condition?

☒ Yes ☐ No ☐ N/A

2. Free of mechanical damage & leaking?

☒ Yes ☐ No ☐ N/A

3. No external corrosion?

☒ Yes ☐ No ☐ N/A

4. Properly aligned?

☒ Yes ☐ No ☐ N/A

5. No external loads?

☒ Yes ☐ No ☐ N/A

D. Visible pipe hangers and seismic braces not damaged or loose?

E. Must be done before cold weather

☐ Yes ☐ No ☒ N/A

1. Adequate heat in areas with wet piping?

☐ Yes ☐ No ☒ N/A

2. Low temperature alarms in dry pipe, preaction and deluge valve enclosures functioning?

☐ Yes ☐ No ☒ N/A

3. Interior of pipe in preaction and dry pipe systems which passes through freezers free of ice blockage?

☒ Yes ☐ No ☐ N/A

7. Annual, or every Fifth Year for Valves which can be reset without opening:

☐ Yes ☐ No ☒ N/A

interior of dry pipe, preaction and deluge valves passed internal inspection?

☐ Yes ☐ No ☒ N/A

B. Fifth Year Inspection Items

A. Alarm valves and their associated strainers, filters and restriction orifices passed internal inspection?

☐ Yes ☐ No ☒ N/A

B. Check valves internally inspected and all parts operate properly, move freely and in good condition?

☐ Yes ☐ No ☒ N/A

C. Strainers, filters, restricted orifices and diaphragm chambers on dry pipe, preaction and deluge valves passed internal inspection?

☐ Yes ☐ No ☒ N/A

8. Testing

The following tests are to be performed at the noted intervals. Report any failures on sheet 2 under comments.

1. Quarterly Testing

A. Sprinkler system main drain test static residual

1. Record Static Pressure 5 psi and Residual Pressure 5 psi

Was flow observed?

☒ Yes ☐ No ☐ N/A

2. Are results comparable to previous test?

☒ Yes ☐ No ☐ N/A1. Record Static Pressure psi and Residual Pressure psi

Was flow observed?

☐ Yes ☐ No ☒ N/A

2. Are results comparable to previous test?

☐ Yes ☐ No ☒ N/A1. Record Static Pressure psi and Residual Pressure psi

Was flow observed?

☐ Yes ☐ No ☒ N/A

2. Are results comparable to previous test?

☐ Yes ☐ No ☒ N/A

9. Waterflow alarm devices passed tests?

1. Inspector's test connection opened? (wet pipe when not in freezing weather).

☐ Yes ☐ No ☒ N/A

2. Bypass connection opened? (wet pipe in freezing weather dry pipe preaction or deluge)

☐ Yes ☐ No ☒ N/A

3. Alarms activated and flow observed?

☐ Yes ☐ No ☒ N/A

C. Control valves (OSSY and gear-operated indicating butterfly valves) opened until spring or tension is felt in rod then closed back one quarter of a turn?

☒ Yes ☐ No ☐ N/A

D. Dry pipe and preaction systems:

1. Priming water level correct?

☒ Yes ☐ No ☐ N/A

2. Low air pressure signal passed test?

☒ Yes ☐ No ☐ N/A

E. Quick opening devices passed test?

☒ Yes ☐ No ☐ N/A

F. Valve supervisory switches indicate movement?

☒ Yes ☐ No ☐ N/A

2. Annual Tests

A. Are all sprinklers in service dated 1929 or later?

☒ Yes ☐ No ☐ N/A

B. Fast response sprinklers in service for less than 20 years?

☒ Yes ☐ No ☐ N/A

If no, test sample now and every 10 yrs

☒ Yes ☐ No ☐ N/A

GRANVILLE HOUSE

Fire Drill Record

Date January 17, 2016
 Time 1800
 Area 2nd Hall
 Duration 10 minutes

☒ 7-3 SHIFT
☐ 3-11 SHIFT
☐ 11-7 SHIFT

Response of personnel GOOD FAIR NOT ACCEPTABLE
 Attitude of personnel GOOD FAIR NOT ACCEPTABLE
 Efficiency of personnel GOOD FAIR NOT ACCEPTABLE

Personnel instructed as follows:

Transmission of alarm YES NO
 Response to alarm YES NO
 Isolation of area YES NO
 Use of fire safety equipment YES NO
 Preparing building for evacuation YES NO
 Evacuation of area YES NO

Discussion after drill (list any questions asked by personnel)

Fire drill conducted on 7-3 shift. All staff/employees participated.
Minimal time outside of residents 2 evacuations. Staff expressed
understanding of getting residents out of building in a timely
manner.


 Signature of Person Conducting Drill

to residents importance of fire drills and practicing in the
event of a real emergency.


 Signature of Person Conducting Drill

GRANVILLE HOUSE

Fire Drill Record

Date May 17, 2017
Time 9pm
Area Kitchen
Duration 15 minutes

✓ 7-3 SHIFT
3-11 SHIFT
11-7 SHIFT

Response of personnel	<u>GOOD</u>	FAIR	NOT ACCEPTABLE
Attitude of personnel	GOOD	<u>FAIR</u>	NOT ACCEPTABLE
Efficiency of personnel	<u>GOOD</u>	FAIR	NOT ACCEPTABLE

Personnel instructed as follows:

Transmission of alarm	<u>YES</u>	NO
Response to alarm	<u>YES</u>	NO
Isolation of area	<u>YES</u>	NO
Use of fire safety equipment	<u>YES</u>	NO
Preparing building for evacuation	<u>YES</u>	NO
Evacuation of area	<u>YES</u>	NO

Discussion after drill (list any questions asked by personnel)

Conducted a fire drill on 3-11 shift. Residents instructed
to stand at door 2 rapping outside. No issues noted.

Sarah Gabel
Signature of Person Conducting Drill

GRANVILLE HOUSE

Fire Drill Record

Date June 20, 2017
Time 12 mn
Area 400 Hall
Duration 15 minutes

 7 - 3 SHIFT
 3 - 11 SHIFT
✓ 11 - 7 SHIFT

Response of personnel	<u>GOOD</u>	FAIR	NOT ACCEPTABLE
Attitude of personnel	GOOD	<u>FAIR</u>	NOT ACCEPTABLE
Efficiency of personnel	<u>GOOD</u>	FAIR	NOT ACCEPTABLE

Personnel instructed as follows:

Transmission of alarm	<u>YES</u>	NO
Response to alarm	<u>YES</u>	NO
Isolation of area	<u>YES</u>	NO
Use of fire safety equipment	<u>YES</u>	NO
Preparing building for evacuation	<u>YES</u>	NO
Evacuation of area	<u>YES</u>	NO

Discussion after drill (list any questions asked by personnel)

Remnants stood at doors inside during drill.
NO ISSUES NOTED.

Sarah Gabel
Signature of Person Conducting Drill

GRANVILLE HOUSE

Fire Drill Record

Date July 18, 2017
Time 2300
Area Lobby
Duration 12 minutes

☒ 7-3 SHIFT
☐ 3-11 SHIFT
☐ 11-7 SHIFT

Response of personnel	<u>GOOD</u>	FAIR	NOT ACCEPTABLE
Attitude of personnel	GOOD	<u>FAIR</u>	NOT ACCEPTABLE
Efficiency of personnel	<u>GOOD</u>	FAIR	NOT ACCEPTABLE

Personnel instructed as follows:

Transmission of alarm	<u>YES</u>	NO
Response to alarm	<u>YES</u>	NO
Isolation of area	<u>YES</u>	NO
Use of fire safety equipment	<u>YES</u>	NO
Preparing building for evacuation	<u>YES</u>	NO
Evacuation of area	<u>YES</u>	NO

Discussion after drill (list any questions asked by personnel)

Fire drill protocol reviewed with staff and residents.
NO ISSUES NOTED.

Sarah Baker
Signature of Person Conducting Drill

GRANVILLE HOUSE

Fire Drill Record

Date August 9, 2017
Time 3pm
Area no alarm pulled
Duration 0

 7 - 3 SHIFT
✓ 3 - 11 SHIFT
 11 - 7 SHIFT

Response of personnel	GOOD	FAIR	NOT ACCEPTABLE
Attitude of personnel	GOOD	FAIR	NOT ACCEPTABLE
Efficiency of personnel	GOOD	FAIR	NOT ACCEPTABLE

Personnel instructed as follows:

Transmission of alarm	YES	NO
Response to alarm	YES	NO
Isolation of area	YES	NO
Use of fire safety equipment	YES	NO
Preparing building for evacuation	YES	NO
Evacuation of area	YES	NO

Discussion after drill (list any questions asked by personnel)

Currently on fire watch 2. Mechanical issue with
fire alarm. Verbal instruction provided by D.C. and
GIA by staff. Reviewed policies and procedures to staff

Susan Gubel
Signature of Person Conducting Drill

PNC-

Mike Baumit

