

PRINTED: 09/28/2017
FORM APPROVED

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL051024	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____		(X3) DATE SURVEY COMPLETED R 08/30/2017
NAME OF PROVIDER OR SUPPLIER BROOKDALE SMITHFIELD		STREET ADDRESS, CITY, STATE, ZIP CODE 830 BERKSHIRE ROAD SMITHFIELD, NC 27577			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
(C 000)	Initial Comments Report of a Biennial Follow Up Construction Survey by Billy S. Bryant conducted on 08/30/2017. There are deficiencies that remain to be corrected.	(C 000)			
C 189	Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing facilities with the exception of Paragraph (a) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Based on observation the facility's fire safety equipment (the fire sprinkler system) is not maintained in operating condition. Failure to maintain fire safety equipment in operating condition could effect occupants of the facility if the equipment (the fire sprinkler system) did not operate properly to provide the required protection function. New Finding on 08/30/2017: a. The valve for the pipe to the fire sprinkler system accelerator accelerator was in the off position and the pressure gauge for the accelerator indicated no pressure on the line.	C 189	Simplex, Repair Co. for system out to look and check accelerator valve on 10/2/17. Found valve needs replacing. Ordered part & said would be replaced by 10/13/17.	10/3/17	

Division of Health Service Regulation

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Andrew Wheeler, II

Executive Director

10/3/17

STATE FORM

0000

NJ2023

If continuation sheet 1 of 1